

Chris Sandve

Chief Regulatory Officer Phone: 604-623-3726 Fax: 604-623-4407

bchydroregulatorygroup@bchydro.com

January 31, 2022

Patrick Wruck Commission Secretary and Manager Regulatory Support British Columbia Utilities Commission Suite 410, 900 Howe Street Vancouver, BC V6Z 2N3

Dear Patrick Wruck:

RE: British Columbia Utilities Commission (BCUC or Commission)

British Columbia Hydro and Power Authority (BC Hydro)

Annual Reporting of Reliability Indices

Annual Response to Directive 26 of BCUC Decision on F2005/F2006

Revenue Requirements Application (F05/F06 RRA)

Fiscal 2021 Updated Attachment 1

BC Hydro writes to provide revised information on BC Hydro's Fiscal 2021 Annual Reporting of Reliability Indices dated June 4, 2021.

As mentioned in our letter to the BCUC dated January 11, 2022, in the course of responding to BCUC Staff Questions, BC Hydro became aware of a potential issue with the Fiscal 2021 Transmission-Related Reliability Indices.

Upon investigating this potential issue further, we determined that, in calculating certain transmission-related indices, multiple outages of one particular Transmission Service customer should have been excluded from these indices because the problem was on a privately-owned portion of a transmission line serving the customer and not within BC Hydro's area of responsibility.

This customer has the option to enable or block trips due to high corona losses. The purpose of a high corona loss trip is to eliminate revenue metering charges as a result of excessive corona losses, which typically occur during the winter months when hoar frost conditions exist.

Trips due to high corona losses are not common causes of outages at BC Hydro and was incorrectly interpreted as being a problem related to the BC Hydro system. As a result of identifying this error, BC Hydro reviewed all fiscal 2021 outage events to ensure that we have included only those outage events within BC Hydro's area of responsibility to determine our updated fiscal 2021 transmission-related reliability indices. This is

January 31, 2022
Patrick Wruck
Commission Secretary and Manager
Regulatory Support
British Columbia Utilities Commission
Annual Reporting of Reliability Indices
Annual Response to Directive 26 of BCUC Decision on F2005/F2006 Revenue
Requirements Application (F05/F06 RRA)
Fiscal 2021 Updated Attachment 1



Page 2 of 2

consistent with Canadian Electricity Association's definition for outage reporting of the Bulk Electric System.

As a result of these corrected transmission-related reliability indices, fiscal 2021 T-SAIDI, SARI, and DPUI numbers are lower than originally reported. Compared to fiscal 2020, T-SAIDI increased by a smaller margin, from 2.74 in fiscal 2020 to 3.76 in fiscal 2021. SARI increased from 3.08 in fiscal 2020 to 5.78 in fiscal 2021. DPUI decreased from 46.30 in fiscal 2020 to 44.42 in fiscal 2021.

A black-lined copy of the Attachment 1, Distribution and Transmission Reliability Indices, correcting this error, is attached. The updated version of Attachment 1 also reflects the correction which was made to CEMI-4% as part of BC Hydro's response to BCUC Staff IR 1.1.1 filed on January 11, 2022.

In addition, BC Hydro is filing at the same time, an errata to the Fiscal 2023 to Fiscal 2025 Revenue Requirements Application which includes this corrected Attachment 1, and a revised BC Hydro response to the Residential Consumer Intervener Association IR 1.97.1.

For further information, please contact Alicia Henderson at 604-623-4381 or by email at bchydroregulatorygroup@bchydro.com.

Yours sincerely.

Chris Sandve

Chief Regulatory Officer

bf/ma

Enclosure



Chris Sandve

Chief Regulatory Officer Phone: 604-623-3918 Fax: 604-623-4407

bchydroregulatorygroup@bchydro.com

June 4, 2021

Mr. Patrick Wruck Commission Secretary and Manager Regulatory Support British Columbia Utilities Commission Suite 410, 900 Howe Street Vancouver, BC V6Z 2N3

Dear Mr. Wruck:

RE: British Columbia Utilities Commission (BCUC or Commission)

British Columbia Hydro and Power Authority (BC Hydro)

Annual Reporting of Reliability Indices

Annual Response to Directive 26 of BCUC Decision on F2005/F2006

Revenue Requirements Application (F05/F06 RRA)

BC Hydro writes to provide an annual reporting of reliability indices, as required by Directive 26 of BCUC Order No. G-96-04 on BC Hydro's F2005 to F2006 Revenue Requirements Application.¹

Directive 26 states that BC Hydro is expected to present reliability indices (SAIFI, SAIDI, CAIDI, ASAI, SARI, MAIFI, generation forced outages, availability, and generation outage rates), both combined and disaggregated (where applicable), on an annual basis with comparisons to Canadian Electricity Association (**CEA**) averages.

In this filing, BC Hydro is providing reliability indices for distribution, transmission and generation performance through fiscal 2021. As in previous years, BC Hydro reliability statistics are provided on a fiscal year basis and compared with the CEA calendar year data.

BC Hydro submitted its initial distribution and generation reliability indices compliance filing in September 2005, and subsequently reported the available reliability indices in May 2006 as part of the F2007/F2008 RRA. Starting in May 2007, BC Hydro began filing annual reports with the Commission on these reliability indices. Transmission system reliability indices for the years prior to fiscal 2012 were provided separately by the British Columbia Transmission Corporation (BCTC) in its Transmission System Capital Plan filings. BC Hydro provided the transmission system reliability indices starting in fiscal 2012, subsequent to the integration of BC Hydro and BCTC in fiscal 2011.

June 4, 2021
Mr. Patrick Wruck
Commission Secretary and Manager
Regulatory Support
British Columbia Utilities Commission
Annual Reporting of Reliability Indices
Annual Response to Directive 26 of BCUC Decision on F2005/F2006 Revenue
Requirements Application (F05/F06 RRA)



Page 2 of 3

Distribution and Transmission Update

The most recent annual CEA reports for distribution and transmission are the 2019 Annual Service Continuity data on Distribution System Performance in Electrical Utilities and the Bulk Electricity System. CEA data on distribution and transmission performance for the 2020 calendar year are not yet available. The comparative reliability indices, both combined and disaggregated, for BC Hydro's distribution and transmission systems, are presented in Attachment 1, in tabular and graphical form through to fiscal 2021.

Generation Performance Update

The most recent annual CEA report on generation performance is the 2019 Generation Equipment Status Annual Report. CEA data on generation performance for the 2020 calendar year are not yet available.

The comparative reliability indices, both combined and disaggregated, for BC Hydro's generation system are presented in Attachment 2, in tabular and graphical form for the 10-year period ending fiscal 2021.

To reflect BC Hydro's investment strategies and operating practices of prioritizing Key Generating Facilities (large MW capacity units) over Available Generating Facilities (small MW capacity units), weighted averages of the reliability indices are also included in Attachment 2. CEA weighted averages for these indices were not available at the time of submission and will be provided for comparison starting next year. BC Hydro will continue to include this additional information in future reports.

Reliability Indices Performance Highlights

BC Hydro highlights the following with regard to its reliability indices performance through fiscal 2021:

- BC Hydro's SAIFI results (blue line) continue to perform better than the CEA community average (red line);
- On average, BC Hydro's SAIDI performance is better than the CEA average SAIDI;
- On average, BC Hydro's CAIDI performance is within 15 minutes of the CEA average CAIDI, except during years of notable storm events;
- BC Hydro's Transmission SAIDI and DPUI (Delivery Point Unavailability Index) performance are higher than previous years due to more outages and longer duration outages to our Transmission Voltage Customers;
- For generation, all aggregate reliability measures included improved slightly in fiscal 2021 compared to fiscal 2020;

June 4, 2021

Mr. Patrick Wruck

Commission Secretary and Manager

Regulatory Support

British Columbia Utilities Commission

Annual Reporting of Reliability Indices

Annual Response to Directive 26 of BCUC Decision on F2005/F2006 Revenue

Requirements Application (F05/F06 RRA)



Page 3 of 3

- The aggregate measures (all plants) for forced outage factor and availability factor were negatively impacted by our smallest facilities with the main contributor being the forced extension of a planned outage at Aberfeldie due to leaks found in the penstock, which were subsequently repaired;
- On average, BC Hydro's aggregate availability factor is lower than the CEA average by 5 per cent to 7 per cent as BC Hydro spends more time than the CEA average on planned outages; and
- The 60-Month Rolling Forced Outage Factor for Key Facilities, which is included as
 one of BC Hydro's Service Plan metrics, was 1.21 per cent at the end of fiscal 2021,
 which meets the Service Plan target of less than or equal to 1.8 per cent.

For further information, please contact Chris Sandve at 604-974-4641 or by email at bchydroregulatorygroup@bchydro.com.

Yours sincerely,

Chris Sandve

Chief Regulatory Officer

ls/rh

Enclosure



F05/F06 Revenue Requirements Application Annual Response to Directive 26 of BCUC Decision

F2021 Annual Reporting of Reliability Indices

Attachment 1

Distribution and Transmission Reliability Indices





This section includes the following distribution and transmission indices:

SAIFI	a measure of the number of sustained interruptions (longer than one minute) an average distribution customer will experience in a year
T-SAIFI-MI	a measure of transmission interruptions of less than one minute in duration that a delivery point experiences in a year
T-SAIFI-SI	a measure of transmission interruptions of one minute or more that a delivery point experiences in a year
T-SAIDI	a measure of the average total interruption duration, in hours that a delivery point experiences in a year
SAIDI	a measure of the amount of time, in hours, an average distribution customer is without power in a year
CAIDI	a measure of the average interruption, in hours, per interrupted distribution customer in a year
%ASAI	a measure of the percentage of time service is available in the year
CEMI-4	percentage of customers experiencing four or more outages in a year
MAIFI	a measure of the frequency of momentary (less than one minute) interruptions per distribution customer served in a year
DPUI	a measure of overall bulk electricity system performance in terms of a composite index of unreliability expressed in system minutes in a year. It takes into account all forced and planned outages except interruptions attributed to generators
SARI	a measure of the average restoration time, in hours, for each transmission delivery point in a year

As noted in Provision 9x of the F2011 Revenue Requirements Application Negotiated Settlement Agreement, BC Hydro is also reporting its CEMI-4 reliability metric, and SAIFI, SAIDI, CAIDI, ASAI, and CEMI-4 metrics normalized using the IEEE 2.5 Beta method. CEMI-4 is not benchmarked externally as utilities are at varying stages in their development of this metric.



Table 1 Reliability Indices – BC Hydro Overall and CEA Overall (All-Event Indices, Not Normalized)

Year		BC Hy	dro Overal	I	CEA Overall					
	SAIFI	SAIDI	CAIDI	%ASAI	SAIFI	SAIDI	CAIDI	%ASAI		
F2012	1.92	5.08	2.65	99.942	2.63	6.16	2.34	99.930		
F2013	1.59	3.70	2.33	99.958	2.54	4.66	1.83	99.947		
F2014	1.83	5.19	2.83	99.941	2.72	9.49	3.49	99.892		
F2015	1.72	5.11	2.97	99.942	2.39	6.38	2.67	99.927		
F2016	2.29	10.69	4.66	99.878	2.32	5.08	2.19	99.942		
F2017	2.17	5.50	2.53	99.937	3.10	5.65	1.82	99.936		
F2018	2.13	6.56	3.08	99.913	2.61	7.91	3.04	99.910		
F2019	1.90	8.58	4.51	99.902	2.84	8.46	2.98	99.903		
F2020	1.96	4.78	2.44	99.945	2.65	8.38	3.16	99.904		
F2021	1.98	5.73	2.90	99.935	n/a	n/a	n/a	n/a		

Table 2 Reliability Indices – BC Hydro (Distribution) and CEA (Distribution) (All Event Indices, Not Normalized)

Year		BC Hydro	(Distribut	ion)	CEA (Distribution)				
	SAIFI	SAIDI	CAIDI	%ASAI	SAIFI	SAIDI	CAIDI	%ASAI	
F2012	1.37	4.40	3.22	99.950	2.09	5.59	2.68	99.936	
F2013	1.06	3.08	2.92	99.965	1.86	4.13	2.22	99.953	
F2014	1.45	4.66	3.20	99.947	2.05	8.59	4.19	99.902	
F2015	1.34	4.44	3.31	99.949	1.79	5.67	3.16	99.935	
F2016	1.91	10.13	5.30	99.884	1.79	4.54	2.53	99.948	
F2017	1.74	4.83	2.77	99.945	2.44	5.08	2.08	99.942	
F2018	1.69	5.82	3.44	99.934	2.05	5.33	2.60	99.939	
F2019	1.63	8.08	4.95	99.908	2.23	7.16	3.21	99.918	
F2020	1.41	3.83	2.71	99.956	2.10	7.51	3.57	99.914	
F2021	1.61	4.91	3.05	99.944	n/a	n/a	n/a	n/a	



Table 3 Reliability Indices – BC Hydro Overall –
Normalized using IEEE 2.5 Beta Method

Year		-	Overall – Norma EE 2.5 Beta meth	•	
	SAIFI	SAIDI	CAIDI	CEMI-4 (%)	%ASAI
F2012	1.67	3.89	2.34	15.37	99.956
F2013	1.46	3.33	2.28	10.45	99.962
F2014	1.68	4.14	2.46	12.52	99.953
F2015	1.35	3.37	2.49	10.13	99.962
F2016	1.60	3.42	2.14	14.00	99.961
F2017	1.88	4.37	2.33	16.43	99.950
F2018	1.67	3.94	2.36	14.55	99.955
F2019	1.39	3.21	2.32	10.65	99.963
F2020	1.68	3.56	2.12	14.59	99.959
F2021	1.56	3.52	2.25	19.19 14.35	99.960

Table 4 Reliability Indices – BC Hydro CEMI 4
Overall
(All-Event Indices, Not Normalized)

Year	BC Hydro Overall	
	CEMI-4 %	
F2012	17.43	
F2013	12.88	
F2014	15.10	
F2015	15.15	
F2016	23.77	
F2017	19.45	
F2018	20.87	
F2019	17.14	
F2020	18.39	
F2021	20.17	

Note: CEA does not survey for CEMI-4 or IEEE 2.5 Beta.



F2021 Annual Reporting of Reliability Indices Attachment 1 – Distribution and Transmission Reliability Indices

Table 5 Reliability Indices – BC Hydro

(Transmission) and CEA (Transmission)

(Forced Data)

(All-Event Indices, Not Normalized)


Year		BC Hydro (Tra	ansmission	CEA (Transmission) (Forced)						
	T-SAIFI-MI	T-SAIFI-SI	T-SAIDI	DPUI	SARI	T-SAIFI-MI	T-SAIFI-SI	T-SAIDI	DPUI	SARI
F2012	0.43	0.86	1.55	19.39	1.81	0.84	0.81	1.73	23.35	2.13
F2013	0.56	0.74	1.64	17.16	2.19	0.84	0.90	4.48	51.18	4.98
F2014	0.74	0.87	2.57	25.18	3.01	0.86	0.83	2.59	27.07	3.11
F2015	0.83	0.74	2.11	26.41	2.86	0.72	0.83	2.56	19.24	3.10
F2016	0.79	0.63	2.46	27.77	3.90	0.85	0.74	2.15	15.60	2.90
F2017	0.63	0.61	2.52	33.61	4.13	0.70	0.75	1.93	22.33	2.58
F2018	0.30	0.69	2.50	30.13	3.62	0.55	0.77	2.24	20.02	2.90
F2019	0.57	0.34	0.92	7.61	2.71	0.65	1.06	3.48	33.87	3.27
F2020*	0.90	0.89	2.74	46.30	3.08	0.82	0.89	2.63	30.07	2.94
F2021	0.70	0. 75 <u>65</u>	7.10 3.76	64.75 <u>44.42</u>	9.47 <u>5.78</u>	n/a	n/a	n/a	n/a	n/a


Note: The CEA Bulk Electricity Study program reports only on forced outage results as not all the participating utilities report planned outages.

^{*} F2020 BC Hydro (Transmission) Forced numbers filed last year were incorrect; the table has been updated to reflect the corrected numbers.





Distribution Graphs


















Note: The customer momentary interruptions and the resulting MAIFI may not apply to the utility's total customer population in the CEA comparison. Momentary outages are any interruptions on the feeders of less than one-minute duration, caused by disturbance on the distribution, substation or transmission system.





Transmission Graphs





























F05/F06 Revenue Requirements Application Annual Response to Directive 26 of BCUC Decision

F2021 Annual Reporting of Reliability Indices

Attachment 2 Generation Reliability Indices

	BC Hydro Hydroelectric Units -Total Average					BC Hydro Hydroelectric Units - Weighted Average Note 6						CEA Hydroelectric Units -Total Average					
Fiscal Year	Average Availability Factor (%)	Average Operating Factor (%)	Average Forced Outage Count (Including starting failures) (Internal) Note 1	Average Forced Outage Factor (%) (Including starting failures) (Internal) Note 1	Failure Rate	Weighted Availability Factor (%)	Weighted Operating Factor (%)	Weighted Forced Outage Count (Including starting failures) (Internal) Note 1	Weighted FOF (%) (Including starting failures) (Internal) Note 1	Weighted Failure Rate	Calendar Year	Average Availability Factor (%)	Average Operating Factor (%)	Average Forced Outage Count (Including starting failures) (Internal) Note 1	Average Forced Outage Factor (%) (Including starting failures) (Internal) Note 1	Failure Rate	
F2012	82.2	69.8	2.4	5.0	2.7	85.4	69.9	2.3	1.8	2.6	C2011	88.4	72.5	2.5	3.9	2.2	
F2013	82.7	72.6	2.0	3.4	2.3	82.6	72.1	1.7	0.5	2.2	C2012	89.2	72.0	2.5	3.8	2.3	
F2014 Note 2	80.5	64.7	2.5	4.7	2.7	81.3	65.8	2.3	1.7	2.6	C2013	87.9	74.0	2.4	3.9	2.1	
F2015 Note 3	81.1	65.1	2.4	3.7	2.9	83.5	62.4	2.6	1.3	3.7	C2014	87.5	73.5	2.4	5.0	2.1	
F2016 Note 3	82.2	65.9	2.0	4.1	2.4	85.1	66.7	1.8	2.6	2.3	C2015	87.9	70.4	3.2	4.7	2.1	
F2017 Note 3	81.7	67.6	1.8	4.4	1.9	83.4	65.2	2.3	3.5	3.2	C2016	86.7	71.7	3.1	4.8	1.9	
F2018 Note 3	80.5	65.5	1.7	2.6	2.0	84.1	66.0	1.8	0.7	2.4	C2017	86.7	73.0	3.3	4.9	2.2	
F2019 Note 3	79.6	61.9	2.0	2.8	2.3	86.0	63.4	1.9	0.6	2.0	C2018	85.6	67.8	3.7	5.0	2.1	
F2020 Note 4	78.8	59.1	2.0	4.3	2.3	81.4	61.3	1.8	1.6	2.1	C2019	87.1	70.8	3.3	3.7	1.9	
F2021 Note 4	81.4	63.8	1.9	2.8	2.2	86.4	68.7	1.8	1.3	1.9	C2020	n/a	n/a	n/a	n/a	n/a	

Definitions

Availability Factor = Operating Time + Available-But-Not-Operating Time / In Commercial Service Time Note 5

Forced Outage Count = Average Number of Forced Outages / Unit / Year (including Starting Failures)(Internal)

Forced Outage Factor = Forced Outage Time (including Starting Failures)(Internal) / In Commercial Service Time Note 5

Failure Rate = Forced Outage Count (excluding Starting Failures)(Internal) / Operating Time X In Commercial Service Time Note 5

Notes

- 1. Outages with causes that were external to Generation, such as Transmission System forced outages, are excluded from this measure.
- 2. Data excludes ALU Unit 1 and SHU Unit 1, which have been forced out of service for an extended period.
- 3. Data excludes ALU Unit 1, SHU Unit 1 and ELK Units 1 and 2 which have been forced out of service for an extended period.
- 4. Data excludes ALU Unit 1, SHU Unit 1, ELK Units 1 and 2 and SPN Unit 1,2 and 3 which have been forced out of service for an extended period.
- 5. In Commercial Service Time represents the number of hours in the measurement period that the unit(s) were considered part of the active fleet.
- 6. Average reliability indices are weighted by unit maximum capacity rating.

