

BC HYDRO

T&D SYSTEM OPERATIONS

SYSTEM OPERATING ORDER 7T-41

VANCOUVER ISLAND SYSTEM OPERATION
Supersedes SOO 7T-41 dated 26 November 2021

Effective Date: 22 April 2022

Review Year: 2026

APPROVED BY:

Original Signed by

Bob Cielen
Operations Planning Manager,
T&D System Operations

- Requires same day posting on bchydro.com and on BCRC Extranet upon release.
- Requires same day MRS conveyance notification upon posting

Indicates Revision

||

CONTENTS

1.0	GENERAL.....	4
2.0	RESPONSIBILITIES	5
3.0	OPERATING PROCEDURES	6
3.1	Normal Energizing and Synchronizing 2L129 with TBY 2RX1 in Service.....	6
3.2	Energizing and Synchronizing 2L129 without TBY 2RX1.....	6
3.3	Adjusting ARN 230 kV Bus Voltage.....	6
3.4	VIT Phase Shifting Transformer (PST).....	7
3.4.1	General.....	7
3.4.2	Methods of Control.....	7
3.4.3	Overload Protection.....	7
3.4.4	Switching VIT PST1	7
3.5	1L115 and 1L116 Overload Protection Scheme.....	8
3.5.1	Single Line Operation:.....	8
3.5.2	Parallel Line Operation:	8
3.6	VIT 230 kV / 132 kV Transformers (T5/T6/T9/T10) Outage.....	8
3.7	Vancouver Island Load-Supply Capability	9
3.8	Transmission Overloads – Bulk Customer/Generation Reductions.....	10
3.9	Peak Load-Shaving Voltage Reduction (PSVR) Scheme.....	10
4.0	VOLTAGE REGULATION.....	12
4.1	Capacitors	12
4.2	Shunt Reactors.....	12
4.3	DMR Static VAR Compensator.....	12
4.4	Tap Changers.....	12
4.5	Synchronous Condensers.....	12
4.6	Harmonic Filters.....	13
4.7	Voltage Levels.....	13
4.7.1	High Voltage Conditions.....	13
4.7.2	Low Voltage Conditions	14
4.7.3	General Guidelines for Voltage Contingencies.....	14
5.0	REMEDIAL ACTION SCHEMES	15
5.1	General	15
5.2	VI Remedial Action Scheme (VI RAS)	15
5.2.1	VI Load Shedding RAS.....	15
5.2.2	Generation Shedding RAS for Loss of the 500kV LM-VI Path	16
5.2.3	Direct Transfer Tripping RAS (DTT RAS).....	16
5.2.4	VI RAS Pre-Outage and Post Contingency Requirements	16
5.3	5L29/5L31 OL RAS	16
5.4	1L10/1L11/1L14 Overload RAS and RMR Requirement for Voltage Stability	16
5.5	North Vancouver Island RAS (NVI RAS).....	17
5.6	2L142 RAS	17
5.7	1L115 and 1L116 Overload Protection.....	17
6.0	KEY FACILITY RATINGS	18
6.1	2L129 Rating.....	18
6.2	DMR 500/230 kV Transformer T1 & T2 Temperature Adjusted and Short Term Rating	18
	Table 1: Temperature Adjusted Continuous Rating.....	18
	Table 2: Temperature Adjusted Short Term Emergency (20 minutes) Rating	18
6.3	VIT Transformers (T5/T6/T9/10) Rating	19
	Table 4: Temperature Adjusted Short Term Emergency Rating. Error! Bookmark not defined.	
7.0	2L129 PROTECTION AND RECLOSE	19
7.1	Overvoltage Protection.....	19
7.2	Overcurrent Protection.....	19
7.3	Auto Reclosing	19
8.0	TSA-PM IMPLEMENTATION.....	20
9.0	REVISION HISTORY.....	21
	ATTACHMENT 1 - Pre-outage Restrictions.....	22

1.1	Pre-Outage Restrictions – with VIT PST in Service.....	25
1.2	Pre-Outage Restrictions – without VIT PST.....	33
ATTACHMENT 2 - Load Shedding and Generation Shedding Requirements - with or without 2L129 in Service.....		43
Table 2.3	Generation Shedding Requirements – with or without 2L129	44
ATTACHMENT 3 – Line Ratings and RAS Load Shedding Candidates		45
ATTACHMENT 4 – Vancouver Load Supply Capability.....		48
A4.1	System Normal, or one of (1L12, 2L144, 5L44, 5L45, DMR T4 or T5, VIT T5 or T9) OOS.	49
A4.2	2L123 or 2L128 OOS.....	50
A4.3	DMR SVC and VARMaster OOS (With 6 5RXs on line).....	51
A4.4	One of (5L29, 5L31, DMR T1, DMR T2) OOS.....	52
A4.5	One of (2L126, 2L170, GTP Capacitor) OOS.....	53
A4.6	One of (1L10,1L11,1L14,2L142,2L143,2L145,2L146,5L30,5L32,5L42) OOS or one of (PVO, ESQ, CLD, HSY, SNY) Capacitor OOS.....	54
ATTACHMENT 5 – Vancouver Island Load Supply Capability (Alternate).....		55
A5.1	System Normal.....	56
A5.2	1L10 OOS.....	57
A5.3	1L11 OOS.....	58
A5.4	1L12 OOS.....	59
A5.5	1L14 OOS.....	60
A5.6	2L123 or 2L128 OOS.....	61
A5.7	2L126 or 2L170 OOS.....	62
A5.8	2L142 OOS.....	63
A5.9	2L143 OOS.....	64
A5.10	2L144 OOS.....	65
A5.11	2L145 OOS.....	66
A5.12	2L146 OOS.....	67
A5.13	5L29 or 5L31 OOS.....	68
A5.14	5L30 or 5L32 OOS.....	69
A5.15	5L42 OOS.....	70
A5.16	5L44 OOS.....	71
A5.17	5L45 OOS.....	72
A5.18	VIT T5 OOS.....	73
A5.19	VIT T9 or T10 OOS	74
A5.20	DMR T1 or T2 OOS.....	75
A5.21	DMR T4 or T7 OOS.....	76
A5.22	DMR T5 or T6 OOS.....	77
A5.23	HSY CX OOS.....	78
A5.24	ESQ CX OOS.....	79
A5.25	SNY CX OOS.....	80
A5.26	GTP CX OOS.....	81
A5.27	CLD CX OOS.....	82
A5.28	PVO CX OOS.....	83
A5.29	SVC OOS with DMR 5-5RX on line.....	84
A5.30	SVC OOS with 6-5RX online.....	85

1.0 GENERAL

This System Operating Order (SOO) provides the operating instructions, operating limits, alarms, outage requirements, and RAS arming requirements for operating the Vancouver Island – Lower Mainland connection. The System Operating Order provides details rules and procedures for load shedding, for generation shedding, outage requirements, load supply capability requirements for the Vancouver Island operating area. Further detailed in this SOO are the rules for RAS arming and alarming implemented by the Energy Management System (EMS) Transient Stability Analysis (TSA-PM) application, for automated actions and to support BCHCC Operator awareness.

The transmission paths to supply Vancouver Island (VI) loads from the Lower Mainland (LM) include:

- 2L129 - a single 230 kV circuit connecting Arnott Substation (ARN) to Vancouver Island Terminal (VIT) via submarine cable and overhead transmission and a phase shifting transformer, VIT PST1, to control flow on 2L129.
- a 500 kV interconnection path which is composed of the following sections from Kelly Lake (KLY) and Meridian (MDN) to Cheekye (CK5) / Malaspina (MSA) / Dunsmuir (DMR):
 - 5L42 from KLY – CK5
 - 5L45 from MDN – CK5
 - 5L30 and 5L32 from CK5 – MSA
 - 5L29 and 5L31 from MSA – DMR, and DMR T1 and T2 transformers.

The 2L129 circuit consists of 2 sections:

- 24.5 kilometres of submarine cables crossing Georgia Strait and Trincomali Channel, and
- 39 kilometres of overhead lines on Lower Mainland, South Gulf Islands and Vancouver Island.

The reactive power compensation associated with 2L129 is:

- A 230kV 66.1 MVAR switchable shunt reactor at Sahtlam (SAT) bus (SAT 2RX1), and
- A 230kV 66.1 MVAR fixed line shunt reactor at Taylor Bay (TBY) side (TBY 2RX1).

Operation of the 500 kV interconnection is addressed in SOO 7T-40 “Cheekye-Dunsmuir 500 kV System”. Together with 2L129 and its phase shifting former VIT PST1, the 500 kV system and 230 kV circuit form the Vancouver Island – Lower Mainland (VI-LM Interconnection).

The requirements in these operating orders cover the worst case operating conditions. Variations from the instructions, limits and arming conditions will be provided through additional Operating Plans, for specific operating conditions on a case basis. Operating Plans are engineered to support outages and short term operating requirements, superseding as necessary **any** requirements in this order.

References:

- SOO 1J-11 “Power System Operation – Authority and Responsibility”
- SOO 1T-11 “Transfer of Operating Authority and Guarantee of No Reclose Procedures Within the Control Centre”
- SOO 1T-11A “Operating Responsibility and Operating Authority Assignment to Desks”
- SOO 1T-22 “Outage Scheduling and Coordination”
- SOO 2T-34A “JHT/ICG/EFM Remedial Action Schemes”
- SOO 2T-34B “1L115/1L116 Local Area Protection Scheme”
- SOO 2T-34C “5L29/31, DMR T1/T2 Remedial Action Scheme”
- SOO 5T-10 “Ratings For All Transmission Circuits 60 kV or Higher”
- SOO 6T-29 “Emergency Manual Load Shedding and Peak Load Reduction Procedures”
- SOO 6T-34 “Automatic Undervoltage Load Shedding (AUMLS)”
- SOO 7T-12 “Reliability Must Run Generation Requirements”
- SOO 7T-22 “System Voltage Control”
- SOO 7T-40 “Cheekye-Dunsmuir 500 kV System” describes the Cheekye-Dunsmuir 500kV Interconnection and Transmission System.
- SOO 7T-45 “Vancouver Island 5th Harmonic Resonance”
- OO 3T-VIT-01 “Vancouver Island Terminal Substation Operation”

- OO 3T-ARN-01 "Arnott Substation Operation"

Definitions: (a selected list of terms and stations used in this System Operating Order)

EMS - Energy Management System

HF2 - Harmonic Filters located at ARN and VIT Substations

PST - Phase Shifting Transformer

RAS - Remedial Action Scheme

TECMP - Transmission Emergency Constraint Management Process

TSA-PM - the Energy Management System's Transient Stability Analysis application

LM - Lower Mainland operating area

VI - Vancouver Island operating area

SVI – Southern portion of the Vancouver Island operating area

VI-LM Interconnection – the connection of the VI and LM operating areas via 2-500 kV circuits and
1-230 kV circuit with Phase Shifting Transformer

VI Dependable Generation – term used only in calculation of RMR requirements, defined in
Attachment 1, Table 1.1.1

ARN - Arnott Substation located in the LM, and also a terminus for 2L129

CK5 - Cheekye 500 kV Substation

DMR - Dunsmuir Substation which connects VI to LM via 2 500 kV cable and OH circuits, and transfers
energy into the North-Central VI

EFM – NTE Discovery Park Ltd. – Duncan Bay Substation

||

GLD - Gold River Substation

ICG - Island Generation Facility

JHN - John Hart Generating Station

JHT - John Hart 138 kV Transmission Switchyard and Dam Facilities

KLY - Kelly Lake Substation

PAL - Port Alberni Substation

MSA - Malaspina Substation

VIT - Vancouver Island Terminal, a terminus for 2L129 with PST for
flow control to the Central-South VI area.

2.0 RESPONSIBILITIES

Refer to SOO's 1T-11 and 1T-11A for the assigned responsibilities within the BC Hydro Control Centre (BCHCC).

Refer to SOO 1T-22 for Outage Scheduling and Coordination responsibilities.

3.0 OPERATING PROCEDURES

3.1 Normal Energizing and Synchronizing 2L129 with TBY 2RX1 in Service

2L129 is normally energized from Arnott (ARN) as the "LEAD" end. The voltage at ARN 230 kV bus prior to energizing the line shall be below 237 kV (1.03 pu) assuming that the TBY shunt reactor is in-service.

Energizing 2L129 from VIT as the "LEAD" end is possible. The voltage at the VIT 230 kV bus prior to energizing the line shall be below 232kV (1.01 pu) assuming that the TBY shunt reactor is in-service.

Phase angle telemetering will be provided at VIT and ARN. The synchrocheck relay will allow the circuit breaker to close if the phase angle across the circuit break is 20 degrees or less.

If Vancouver Island is connected to the Mainland via the 500 kV path then 2L129 can be manually closed at either ARN or VIT when the phase angle across the circuit breaker is below 15 degrees.

If phase angle telemetry is not available the circuit breakers associated with 2L129 then call out CPC technicians to the appropriate station to measure the angle.

3.2 Energizing and Synchronizing 2L129 without TBY 2RX1

If TBY 2RX1 is not available, energizing 2L129 from ARN as the "LEAD" end requires the voltage at ARN 230kV bus below 235 kV (1.02 pu).

3.3 Adjusting ARN 230 kV Bus Voltage

To meet the energizing voltage requirement at ARN 230 kV bus, the Operator can:

- Disable the ING and MDN Auto-Var schemes and manually reduce the ING 230 kV voltage by switching off/inserting ING and/or MDN capacitors / reactors or absorbing MVARs at Burrard Synchronous Condenser Station (BSY) until ARN 230 bus voltage below the required voltage.

After synchronizing 2L129, manually adjust voltage at ING 230 and MDN 230 bus within the normal system operating range, then enable the ING and MDN Auto-VAR schemes.

Note: DO NOT re-energize any shunt capacitor until 5 minutes after it was de-energized (Refer to Section 1.0 of SOO 7T-22).

3.4 VIT Phase Shifting Transformer (PST)

3.4.1 General

The phase shifting transformer at VIT is designated VIT PST1, and is rated at 650 MVA with has 33 taps for phase angle range of +/-25°. The PST can regulate the power flow on the 2L129 operating with 5L29/31 in parallel. See OO 3T-VIT-01 for additional operational details.

3.4.2 Methods of Control

In MW control mode, the taps will automatically change to maintain the selected MW flow. In TAP control mode, the tape is fixed until it is changed via supervisory control. The TAP control mode is the normal mode to minimize wear on the tap changer.

3.4.3 Overload Protection

Within the PST protection, there are redundant (in both the primary and standby relays) overcurrent elements for sensing various system conditions:

- Severe overload (greater than about 900MVA) is detected by an overcurrent relay with the setting of 2260 amps and a 15 second dropout timer (i.e.: tap changer remains blocked for 15 seconds after the current drops below 2260A). When a severe overload occurs, a "LTC Overload" alarm as well as a "LTC Control Blocked" alarm will be raised.
- Moderate overload (about 715 MVA to 900 MVA) is detected by an overcurrent relay with the setting of 1796 amps. When a moderate overload occurs, runback will be triggered at about 715 MVA and a "2L129/PST1 Overload" alarm will be raised. If the tap changer reaches tap position 1 and an overload condition is still sensed, a "Runback Unsuccessful" alarm is asserted.
- Very light load is detected if the PST current is below 100A. The relay asserts a contact that indicated the PST is out of service. This blocks automatic operation of tapchanger.

The runback conditions will force the controller into the tap control mode. When the overload conditions disappear, it will be the Operator's discretion on whether to manually set the controller back into MW control mode.

Loss of the northern LM-VI 500 kV path or loss of both 2L123 and 2L128 will signal the controller to block tap changer operation and assert a "LTC Control Blocked" alarm until the controller is reset by the Operator (see Attachment 2, Note 6 of Table 2.1 and Note 5 of Table 2.2).

When control is switched to the MW control mode, the controller will adjust the taps (either raise or lower) to keep the power flow on 2L129 at the specified MW setpoint (either set locally by the field technician or remotely by the Operator) within a pre-defined dead band.

3.4.4 Switching VIT PST1

VIT PST1 can be energized and de-energized from either locally or remotely, provided the metal oxide surge arresters on both ends of the PST are in service.

With 2L129 in service, PST switching can proceed as follows:

The PST can be bypassed/inserted (i.e. close/open VIT 2CB42) without off-loading 2L129. Interlocks have been provided so that it can only be bypassed when tap changer is in the zero shift position (tap position 17).

3.5 1L115 and 1L116 Overload Protection Scheme

Refer to System Operating Order 2T-34B for details. The scheme protects 1L115 and 1L116 circuits from conductor damage due to sustained overloads. There are two types of transfer trip schemes:

3.5.1 Single Line Operation:

If 1L115 or 1L116 is out-of-service or open-ended at DMR, an overload (trip signal from 49LS thermal relay) of the remaining line would send DTT to open line at LTZ (LTZ 1CB3 or 1CB1 respectively.)

3.5.2 Parallel Line Operation:

If both 1L115 and 1L116 are in-service an overload (trip signal from 49LS thermal relay) from either of the lines would open both 1L115 and 1L116 at JPT (JPT 1CB4 or 1CB6.)

Note: 1L115 and 1L116 do not have stand alone line protection for sections DMR to LTZ or LTZ to JPT; 1L115 and 1L116 line protection protects 1L115 and 1L116 from DMR to LTZ to JPT as one zone.

3.6 VIT 230 kV / 132 kV Transformers (T5/T6/T9/T10) Outage

A single contingency outage of VIT T5 or VIT T6 will result in loss of both transformers as they are in the same protection zone. Loss of the two transformers may cause heavy overloading on the remaining VIT transformers and 1L115/1L116. 1L115 and 1L116 may be tripped open at Jingle Pot substation (JPT) by their overload protection scheme.

Scheduling of VIT T9 or T10 outages needs a great deal of care, especially during high VI load conditions, as loss of VIT T5 & T6 will severely overload the remaining 230/132 kV transformer bank at VIT. 1L115 and 1L116 tripping at JPT by overload protection will follow and it may result in voltage-collapsing the Central and South 132 kV loads.

If these contingencies happen, the BC Hydro Operator shall take the following actions as soon as possible:

- Bring JOR online if it is available and increase the output, and/or
- Curtail loads at Crofton (CFT), Prevost (PVO), Ladysmith (LDY), Harewood (HWD), Koksilah (KSH), Shawnigan (SHA), Colwood (CLD) and Sooke (SOO).

For Harewood West Substation (HWW) T1 or T2 outages during periods when VI system load exceeds 2000 MW a "VIT T5 & T6" contingency may also result in moderately overloading VIT T9/T10.

3.7 Vancouver Island Load-Supply Capability

Attachments 4 and 5 are to be used by Operations Planners and Operators to assess load-supply capability when the transmission system is stressed (i.e. VI load is high and at a significant transmission asset in the Attachment's tables is OOS). These attachments have been developed to aid in identifying the load-supply capability and RMR requirements to avoid voltage collapse on the loss of 2L129 in stressed conditions. As such these attachments are used to support operation through specific N-1-1 events.

Further, a process has been developed to coordinate resources to maximize the supply to Vancouver Island (VI). The Transmission Emergency Constraint Management Process (TECMP) was established to coordinate all parties managing resource (transmission, generation, and load curtailment) that will be utilized to meet VI load demand under stressed system conditions, whether the stressed conditions are due to very high VI load or due to significant equipment outages. The TECMP process was intended not only to create operating plans but also specifies involvement, responsibilities and actions for teams from the greater organization. Please refer to the specific Transmission Emergency Constraint Management Process (TECMP) plan when issued by TDSO Operations Planning, for the detailed plans and procedures. When a TECMP plan is issued, it may supersede requirements noted in this SOO (see Section 1.0).

Attachment 4 provides the VI load-supply capability with and without the associated PST for various system conditions, and the assumptions used to determine the capability. The purpose of Attachment 4 is to provide recommendations on the VAR requirements for voltage support under increasing loads supplied from AC sources (typically the winter heavy loading). In a forced outage scenario, for Real Time Operations purposes, Attachment 4 is preferred to assess immediate operating requirements. Attachment 4 is not implemented in TSA-PM.

Attachment 5 introduces a load ratio definition. VI load supply capability is sensitive to VI load patterns, which can be described as VI load ratio. Higher load ratios will result in a lower VI load supply capability. Conversely lower VI load ratio values will result in higher VI load supply capability.

For the purposes of Attachment 5:

$$\text{Load Ratio} = (\text{C&VI Load})/(\text{VI load})$$

In addition to load ratio, Attachment 5 also includes more transmission component outage scenarios. For preparing operating plans following sustained forced outages or for use in preparing a TECMP, Attachment 5 is recommended to prepare the detailed plans. Attachment 5 is not implemented in TSA-PM.

The assumptions used in Attachment 4 and Attachment 5 are:

- The VI load supply capability includes AC injections from AC transmission sources, and island generation.
- 1L18 is available to supply the South Gulf Island load either from the VI side or the LM side.
When VI load is at or above 2000 MW, the South Gulf Island load shall be radially supplied from the LM side.
- The priority sequence to serve Vancouver Island load are as follows:
 1. Central & North VI generation (C&N VI Gen)
 2. Jordan Generation
- The half-hour emergency rating of 231 MVA at 0°C ambient temperature is used for each of VIT T5 and T6.
- The continuous rating of 185 MVA at 0°C ambient temperature is used for each of 1L115 and 1L116.

Under stressed conditions the supply may not be able to meet the load demand. Load Shedding will be used as the last resort.

3.8 Transmission Overloads – Bulk Customer/Generation Reductions

Overloads on transmission facilities to DMR, JHT, PAL, or Crofton (CFT) may occur for various system configuration or contingencies.

See SOO 2T-34A for JHT/ICG/EFM Remedial Action Schemes (RAS) to protect transmission lines between ICG to JHT and DMR from overloading.

1L117 would be thermally overloaded for loss of 1L118 when 2L154 is OOS. Similarly, 1L117 would be thermally overloaded for loss of 2L154 when 1L118 is OOS.

- The total combined transfer from LDR on 1L117 and 1L118 circuits must be limited to the 1L117 rating as it is the lower of the two circuit ratings when 2L154 is OOS.
- The total combined transfer from LDR on 1L117 and 2L154 from GLD must be limited to the 1L117 rating when 1L118 is OOS.
- Local generations, such as KKS, CSS, SCA, or LDR would be restricted when 2L154 or 1L118 is OOS.

Loss of either 1L105 or 1L114 may limit the PAL mill loading. The total combined transfer from DMR on 1L114 and 1L105 circuits must be limited to the 1L105 rating as it is the lower of the two circuit ratings. This is necessary to protect 1L105 from thermal overload after loss of 1L114.

- There is no automatic overload protection on these lines.
- With low local generation (such as ASH G1 OOS or at low output) while the area load is heavy, Operators' manual actions for load curtailment (the mill load at PAL Substation) may be required pre-contingency.
- If either 1L105 or 1L114 is out of service at the same time that ASH G1 is down, the mill load at PAL Substation may have to be limited to the thermal rating of the remaining line.
- Load can be manually shed if necessary using load shedding screen.

Loss of either 1L139 or 1L140 would limit the CFT mill loading to the thermal capacity of the remaining line. The Operator must monitor the loading on the two circuits to ensure the remaining line will not be overloaded because there is no automatic overload protection on these lines. Load can be manually curtailed or shed if necessary using load shedding screen.

3.9 Peak Load-Shaving Voltage Reduction (PSVR) Scheme

Facilities have been installed in the VI System to reduce load at the larger distribution substations when required during emergencies. These facilities were installed primarily to minimize load curtailment requirements when VI capacity is severely constrained, for example during the loss of both MSA-DMR 500 kV circuits and regional line constraints such as loss of 1L14. Under these conditions, the Operator can reduce the load at the participating substations 5% to 7% by reducing their distribution bus voltage levels by 5%.

Generally, the PSVR scheme will be used in conjunction with operational plans developed to resolve potential VI supply deficiencies.

The following 8 substations are participating in the PSVR scheme:

- Comox (CMX)
- Port Alberni (PAL)
- Qualicum Beach (QLC)
- Parksville (PVL)
- Lantzville (LTZ)
- Koksilah (KSH)
- Prevost (PVO)
- Puntledge (PUN)

Based on field tests, the peak VI load during this period could be reduced by approximately 25MW via the PSVR scheme.

Control facilities are presently in place to facilitate individual substation load reductions when required. The load-shaving voltage reduction scheme is also capable of being initiated via a master control switch at VIT, with the exception of PVO which will be controlled separately. When initiated, the set points on the tap changers' voltage regulating relays will be automatically reduced by approximately 5%. In response to the change in control settings, the tapchanger will begin to lower the distribution bus voltage after the tapchanger time delay has elapsed. When the voltage reduction has been completed, the load should be reduced at the participating substations by a minimum of 5%. This process should be completed within a minute or so. Over time, the load reduction will decrease as diversity between resistive heating elements (i.e., space heaters, stoves, ovens, etc.) decreases due to their reduced voltage and output. Within 4 hours, the load reduction will be reduced to approximately 85% of its initial reduction. After 8 hours, the load reduction will reach a steady-state limit of approximately 70% of the initial load reduction.

4.0 VOLTAGE REGULATION

Voltage regulation requires the best possible use of all VAR sources. In general, VARs should be generated as close as possible to the load that is consuming them so that VAR transfer over the transmission lines is reduced to minimize losses. VAR production should be managed to

- minimize system losses on the transmission system,
- achieve target voltage levels on key station buses,
- maintain "swinging room" on the VIT synchronous condensers, and
- keep PVO capacitor control on all of the time.

4.1 Capacitors

The most efficient way to produce VARs is through the use of fixed capacitors. Substation capacitor banks that can be switched by supervisory control should be used to provide the VAR requirements for the station in which they are located. Capacitor banks can also be used to help control "system" VAR requirements provided this does not result in overvoltage conditions on the substation low voltage buses (which might be caused if the on-load tap changers reach their maximum "buck" position and cease to regulate).

4.2 Shunt Reactors

The 500 kV -135 MVAR reactors at DMR Substation are used to control the reactive power produced by the 500 kV submarine cables. They are designated as "Level 1" equipment in accordance with SOO 1J-11. PIK and SAT 230 kV – 75 MVAR reactors are Level 4.

4.3 DMR Static VAR Compensator

The DMR Static VAR Compensator (SVC) has a dynamic range of +165 MVAR to -135 MVAR. When it is online and operating in the automatic mode, it will regulate the DMR 138 kV bus voltage at the level set by the Operator. The SVC can also control the switching of the DMR 500 kV shunt reactors and the on-load tap changers on DMR T4, T5, T6 and T7 (see SOO 7T-40). The SVC control of the DMR T4, T5, T6 and T7 tap changers have been turned off as recommended by Transmission Operations Services (TOS).

4.4 Tap Changers

Tap changers on DMR T4, T5, T6 and T7 can be controlled from the Control Centre and are used to help regulate the PAL and JHT area voltages.

The tapchangers on GLD T1 and T4 can be controlled by remotely. The taps should be adjusted to regulate the GLD bus voltage. Coordination with the operation of the GLD capacitor banks is required.

4.5 Synchronous Condensers

It is important to have as much synchronous condenser capacity as possible in service to control transient voltage swings, particularly those that occur when cable circuits to the mainland trip. VARs should be absorbed by Dunsmuir (DMR) 500 kV reactors or be produced by substation capacitors to keep the Vancouver Island Terminal (VIT) synchronous condensers operating in the slightly "bucking" or close to zero, if possible. During the summer light load period, to keep the 230 kV voltage in the Victoria area within the cable ratings, synchronous condensers might have to be operated in the maximum bucking region. VIT SC1 is permanently unavailable and planned to be removed from the system. When the 3 synchronous condensers, VIT SC2, SC3, SC4, are on line then the acceptable operating range is -206 MVARS to 255 MVARs. Normally all three synchronous condensers will be in service with their control set for automatic voltage regulation.

Automatic control of the three synchronous condensers is linked to 138 kV capacitor banks at Prevost Substation (PVO). A PLC at VIT inserts or removes capacitors at PVO to keep the synchronous condensers loading near 0 MVARS. The Operator has supervisory control to turn on or off this feature at PVO.

SOO 6T-34 describes the automatic undervoltage load shedding scheme which is implemented to prevent a voltage collapse of the integrated electric system following the loss of major transmission or reactive power support facilities. The Operator will arm and disarm the scheme in accordance with system conditions. Arming is implemented in either the LM area, or VI area or both operating areas.

4.6 Harmonic Filters

VIT and VIT harmonic filter contribute a total of 94.7 MVAR @ 60 Hz at their respective station buses at nominal system voltage. The individual filter contributions at each station are:

- 5HF2 21.6 MVAR
- 7HF2 12.0 MVAR
- 11HF2 15.4 MVAR
- 13HF2 11.1 MVAR
- HP2 34.6 MVAR

The VIT harmonic filters contribute to high voltages in the South VI area in light load conditions, particularly experienced in spring, summer and early fall. It is recommended to remove the higher harmonic filters, leaving in service only the 5th & 7th to address 5th harmonic resonances in the South VI area (see SOO 7T-45 for further information). In heavy load conditions, particularly experienced in winter, all of the filters should be returned to in-service to prop up voltage under increasingly higher South VI area loading.

The ARN filters reduce the natural 5th harmonic voltage/current present in the Metro South area. Normally, the system is operated with all of the ARN filters in-service year round.

If any of the individual HF2 filters need to be taken out of service, the appropriate protection must be blocked. It is not possible to have only one of the individual HF2 filters in operation by itself, as the protection works in a balanced scheme that involves 2 filter sections. Either the 5th + 7th harmonic filters in service or the 5th + 11th harmonic filters in service are acceptable operating configurations. The BC Hydro Control Centre Operator must have Field CPC techs block parts of the HF2 protection to operate in these configurations.

Individual filters (5th, 7th etc.) can be isolated in pairs and the remaining filter sections can be kept in service in pairs (e.g. 5th and 7th together) by locking open the designated manual disconnect switches. This will require the bank to be de-energized before these switches can be opened. See Operating Orders 3T-VIT-01 and 3T-ARN-01 for detailed requirements.

4.7 Voltage Levels

Voltage levels listed below are intended as guides to **normal** operation. See SOO 7T-22 for normal target voltage levels at selected substations when the 500 kV cable circuits are in service.

4.7.1 High Voltage Conditions

High voltage can be a problem in the Victoria area 230 kV system due to the O/V constraints on the 230 kV cable systems. These cables have a maximum continuous rating of 241.5 kV and a 15 minute emergency rating of 253 kV.

230 kV cables should never be operated for more than 15-20 minutes with cable overvoltage alarm coming in from the station or if 230 kV is above 244 kV.

In general, high voltages on the Vancouver Island System can be reduced by one or more of the following:

- a) switching in any available reactors at Pike Lake (PIK), Sahtlam (SAT), DMR, and MSA.
- b) switching out substation capacitor banks, and switching out harmonic filters VIT 11HF2 and VIT 13HF2 and HP2.
- c) Increase MVAR absorption on Island Generation.
- d) Increase the VIT to ARN flow on 2L129. Consider reducing ARN end voltage further with LM Autovar schemes, ARN harmonic filter switching, etc.
- e) If JOR is available, run in synchronous condenser or generation mode to load the 138 kV lines or absorb MVARS.
- f) Adjust GTP T14 taps to shift VARs to the South Vancouver Island 138 kV system from 230 kV system from SAT to HSY while maintaining 138 kV voltage below 142 kV. If available, JOR may have additional capacity to absorb VARs with changes to GTP taps.
- g) Reducing the 138 kV system voltage by adjusting VIT synchronous condensers and by lowering DMR taps. Use DMR SVC to absorb max amount of MVARS (-135 MVARS); keep PVO capacitor control in auto all of the time.
- h) switch out 2L154 DMR-GLD (29.5 MVARS).
- i) switch out 2L145 PIK-ESQ (49.5 MVARS).
- j) switching out 5L31 (or 5L29). This will make additional reactors available at DMR (last resort).

4.7.2 Low Voltage Conditions

Generally, substations have sufficient voltage regulating facilities to allow voltage drops of 10%. Further, the voltage at John Hart has gone as low as 130 kV. In the Port Hardy area, our transformers have exceptionally wide-range tap changers (20% boost) so they can adjust to large changes in system voltage. The Victoria area substations were originally designed for a base bus voltage of 132 kV. The substation transformer tapchanger ranges ($\pm 12.5\%$) allow the SVI voltage to sag to 120 kV before a max tap position is reached.

4.7.3 General Guidelines for Voltage Contingencies

In general, the Operator should be guided by SOO 7T-22 which states in part that:

- Voltage deviation of plus or minus 10% can be tolerated for several hours on most equipment except cables; and,
- Voltage deviation of 20% below normal cannot be tolerated for more than 15-20 minutes.
- Cables are normally protected by overvoltage protection and tripping is usually set at 10% above normal. If voltage deviation exceeds 8% above normal then the cable circuit should be dropped first if the correction is not possible within a few minutes. If the voltage exceeds more than 10% then overvoltage protection should trip automatically, but manual tripping should be done as a backup in case the protective relay has failed.

If there is no cable circuit involved and the voltage is still above 10% then the Operator should take lines out of service if necessary. As stated before, 10% above normal voltage can be tolerated for several hours but equipment should not be subjected to 20% above normal voltage for more than a couple of minutes. If voltage falls 20% below normal then shed load to correct the voltage.

Refer to SOO 6T-29 for manual load shedding recommendations.

5.0 REMEDIAL ACTION SCHEMES

5.1 General

This section describes both wide area and local RAS that support VI area operations. The most significant is called VI RAS. Details for VI RAS are found in Sections 5.2 and 5.3.

Additional local RAS schemes for the VI operating area are described in Section 5.4 through 5.7.

5.2 VI Remedial Action Scheme (VI RAS)

Remedial action schemes are applied quickly to shed an appropriate amount of VI loads, shed some generation at G.M. Shrum (GMS), Peace Canyon (PCN), Revelstoke (REV) and/or Mica (MCA) and direct transfer trip some 500kV lines.

The following contingencies use the Vancouver Island Remedial Action Scheme (VI RAS) to resolve problems that simultaneous or sequential contingencies can cause (such as generator transient instability, voltage collapse, or equipment damage):

- A. Loss of the 500kV LM-VI path which means:
 - (a) 5L29 & 5L31, or
 - (b) 5L30 & 5L32, or
 - (c) 5L42 & 5L45, or
 - (d) DMR T1 & T2.
- B. Loss of both DMR-SAT 230kV circuits (2L123 & 2L128).
- C. Loss of 2L129 with 2L123 or 2L128 OOS
- D. Loss of 2L123 or 2L128 with 2L129 OOS

The VI RAS consists of:

- VI Load Shedding RAS,
- MCA/REV/GMS/PCN Generation Shedding RAS, and
- Direct Transfer Tripping RAS

5.2.1 VI Load Shedding RAS

The VI Load Shedding RAS has PLCs which are located at Vancouver Island Terminal (VIT).

- Upon loss of the 500 kV LM-VI path, the RAS will initiate fast load shedding within 15 cycles as well as slow load shedding after a 2 second delay for the first step and 10 second interval for each succeeding step.
- Upon loss of two of 2L123, 2L128, and 2L129 simultaneously or sequentially, the RAS will initiate only slow load shedding after 1 second delay for the first step and 10 second interval for each of the following steps.
- The slow load shedding is supervised by the overload condition of the remaining 230 kV circuit in such a way that load shedding will continue until the current on the remaining 230 kV circuit is below the corresponding setting.

The patterns and amount of the fast load shedding are determined in advance, and armed by TSA-PM.

Please refer to Tables 2.1 and 2.2 of Attachment 2 for the VI load shedding requirements.

Please refer to Attachment 3 for line ratings, forecasted loads and load shedding block information, and the EMS display of the 7T-41 VI Load Shed RAS implementation.

5.2.2 Generation Shedding RAS for Loss of the 500kV LM-VI Path

In response to the VI load shedding for loss of the 500 kV LM-VI path, generation shedding at REV/MCA/GMS/PCN may be required to prevent excessive increase in power transfers to the neighboring transmission systems of BPA and Alberta. Please refer to Table 2.3 of Attachment 2 for the generation shedding requirements.

5.2.3 Direct Transfer Tripping RAS (DTT RAS)

To prevent the Sunshine Coast load from being fed from Vancouver Island and potential high voltages for loss of 5L42 & 5L45 or 5L30 & 5L32, the following Direct Transfer Trip (DTT) RAS are installed:

- Loss of 5L30 & 5L32 simultaneously or sequentially, DTT trip 5L29 & 5L31.
- Loss of 5L42 & 5L45 simultaneously or sequentially, DTT trip 5L30 & 5L32 and 5L29 & 5L31.

These DTT RAS are implemented locally at the stations. There is no arming functions at the BCHCC.

5.2.4 VI RAS Pre-Outage and Post Contingency Requirements

The pre-outage operating restrictions are specified in Attachment 1 and the load shedding and generation shedding requirements in Attachment 2.

The purpose of the pre-operating restrictions, load shedding or/and generation shedding is to achieve one or more of the following objectives following contingencies:

- To prevent system transient instability, or voltage collapse, or cascading outages.
- To prevent post-contingency loading on the remaining 2L129 from exceeding its half-hour emergency rating (see Table 3.1).
- To prevent post-contingency loading on the remaining 2L123 or 2L128 from exceeding its half-hour emergency rating.
- To prevent unacceptable high voltages in the system post contingency and generation shedding.

5.3 5L29/5L31 OL RAS

A RAS scheme for protection of 5L29/31 cables from impacts of moderate to severe overloads is described in **SOO 7T-40, Section 13.0 and SOO 2T-34C**. This scheme will prevent the cables from being damaged by excessive loading on either of the two 500 kV circuits. The scheme utilizes the same locations used by the VI Load Shed RAS, but is set independently, and will eventually trip the line if load current is not reduced below the maximum dynamic rating. This scheme is not addressed in this System Operating Order. Please see 7T-40 Section 13 and 7T-40 Attachment 3 for this RAS implementation.

5.4 1L10/1L11/1L14 Overload RAS and RMR Requirement for Voltage Stability

The RAS protects lines 1L10/11/14 from conductor damage due to sustained overloads. Such overloads may occur due to N-1 (1L14 contingency) or various N-1-1 and N-2 contingencies (combinations of outages to 1L10, 1L11 or 1L14).

A 1L14 contingency will open 2L142 terminal at GTP based on the current GTP station configuration.

The RAS relays will monitor the current in lines 1L10, 1L11 and 1L14 at VIT as well as the ambient temperature at VIT. The RAS is a local detection load shedding scheme, and armed locally. Arming of the RAS is not performed by the EMS.

Five groups of load, GTP A, GTP B, CLD, KSH and SHA; would be tripped one by one every 10 seconds when any line exceeds both its trip temperature and its dynamic ampacity rating. Alarms will be generated when loads are shed. If the overload returns in less than 5 minutes the shedding sequence will continue from where it left off. After 5 minutes with no overload the controller will reset back to the original state.

Refer to SOO 2T-34 Note 5 of Table 3 for more details of this RAS schemes.

However, even with the overload RAS in service when ambient temperature is low in winter, there would still be voltage instability risks. Therefore, the following RMR requirements for voltage stability are required from November 1st to April 30th:

- System Normal and any N-1 system configurations except 1L10 OOS or 1L11 OOS:
Limit: $(1L10 + 1L11 + 1L14) \text{ VIT} - 2L142 \text{ GTP} < 350 \text{ MW}$
- 1L10 OOS or 1L11 OOS
Limit: $(1L10 + 1L11 + 1L14) \text{ VIT} - 2L142 \text{ GTP} < 250 \text{ MW}$

If these limits are exceeded then TSA-PM will initiate an alarm "VI WINTER RMR VIOLATION: SVI VOLTAGE INSTABILITY". The action is to RMR JOR G1 and increase its output to reduce the transfers within the limits.

When SVI load exceeds 350 MW and JOR is not available to be online:

- open GTP 25CB11 in pre-outage

This action prevents low voltage in SVI area, and prevents thermal overload on 1L10 or 1L11, by dropping GTP 40 series feeder load on a contingency of 1L14 or GTP T11.

For system operating conditions with both 1L10 and 1L11 OOS, consult TDSO Operations Planning for operational instructions.

5.5 North Vancouver Island RAS (NVI RAS)

The NVI RAS addresses overload on 1L120 and other 138kV lines on loss of 2L154, that is the result of increased CSS and KKS generation injection to North Vancouver Island 138kV system. The NVI RAS is local to Gold River. Details can be found in OO 3T-GLD-01 and SOO 2T-34.

5.6 2L142 RAS

2L142 RAS is installed, to prevent power flow from SVI 138 kV system to 230 kV system under N-1-1 outages on the 230 kV transmission system between SAT and HSY. This RAS is local to GTP.

GTP 2L142 RAS will trip 2L142 at GTP and HSY if armed under condition of either the power flow into 2L142 at GTP (from the 138 kV system into 2L142) exceeds 40 MW for more than 4 seconds, or GTP 230 kV bus voltage exceeds 248.4 kV for more than 4 seconds.

Details can be found in OO 3T-GTP-01.

5.7 1L115 and 1L116 Overload Protection

Refer to SOO 2T-34B for 1L115/1L116 overload protection.

6.0 KEY FACILITY RATINGS

6.1 2L129 Rating

2L129 Emergency Rating

2L129 half hour ambient temperature dependent ratings are used in the pre-outage restrictions in Tables of Attachment 1. These ratings are shown in Table 3.1 of Attachment 3.

2L129 Single Pumping Plant Operation

With only one pumping station in service from EBT to TBY, 2L129 current rating is 658 Amps for both summer and winter.

6.2 DMR 500/230 kV Transformer T1 & T2 Temperature Adjusted and Short Term Rating

See SOO 5T-14 Transformer Ratings for the normal and emergency rating information.

Each transformer has a nameplate rating of 1200 MVA based on 25 degree C ambient temperature.

The temperature adjusted continuous rating and short-term (20 minute) ratings based on detailed equipment studies are listed in the following Tables 1 and 2 (for tap position 2),

CAUTION: These ratings are not SOLs, as they differ from facility ratings in SOO 5T-14. These values are used in Attachment 1 Table 1.1.3, to provide estimates of overloads, for situational awareness purposes. They are not used for determining load shedding or line tripping in this SOO, as the values differ from ratings documented in SOO 5T-14.

Table 1: Temperature Adjusted Continuous Rating

Ambient temperature	-10 °C	0 °C	10 °C	20 °C	30 °C
Temperature adjusted continuous rating (MVA)	1650	1590	1515	1440	1365
Estimated MW transfer based on 0.97 pf	1601	1542	1470	1397	1324

Table 2: Temperature Adjusted Short Term Emergency (20 minutes) Rating

Ambient temperature	-10 °C	0 °C	10 °C	20 °C	30 °C
Temperature adjusted short term rating (MVA)	1884	1860	1830	1776	1716
Estimated MW transfer (0.97 pf)	1827	1804	1775	1723	1665

6.3 **VIT Transformers (T5/T6/T9/10) Rating**

See SOO 5T-14 Transformer Ratings for the normal and emergency rating information for VIT T5/T6/T9/T10.

These Transformer ratings are used in Attachment 4 and 5 processes, and not used by TSA-PM.

7.0 **2L129 PROTECTION AND RECLOSING**

7.1 **Overvoltage Protection**

The over voltage protection for the submarine cables of 2L129 is set as follows:

- 266 kV, alarm in 1 minute, trip in 14 minutes
- 280 kV, trip in 78 cycles (1.3 Seconds)

7.2 **Overshoot Protection**

The tripping of 2L129 by its overshoot protection at VIT is the backup for the VI RAS. The overshoot protection is set at 2500 A with 15 minutes delay.

7.3 **Auto Reclosing**

Single pole and three pole reclosing have been provided for 2L129. Three pole auto-reclosing must be disabled if TBY reactor 2RX1 is OOS.

8.0

TSA-PM IMPLEMENTATION

The EMS Transient Stability Analysis (TSA-PM) advanced application performs the following functions for all tables in Attachments 1 and 2:

- Arming the load shedding patterns.
- Arming the required generators to be shed and disarming generators on shed when generation shedding is not required.
- Monitors and initiates alarms if there is a limit violation.

The following alarms have been implemented in TSA-PM:

ALARM MESSAGE	REFERENCES
2L123 RATING VIOLATION	Attachment 1: Pre-outage restriction tables
2L128 RATING VIOLATION	
2L123 1/2HR RATING VIOLATION: 2L129CTG	
2L128 1/2HR RATING VIOLATION: 2L129CTG	
2L123 1/2HR RATING VIOLATION: 2L128CTG	
2L128 1/2HR RATING VIOLATION: 2L123CTG	
2L129 ARN CONTINUOUS RATING VIOLATION	
2L129 ARN 1/2HOUR RATING VIOLATION: 5L29OR30 CTG	
2L129 ARN 1/2HOUR RATING VIOLATION: 5L30OR32 CTG	
2L129 ARN 1/2 HOUR RATING VIOLATION: 5L42 CTG	
2L129 ARN 1/2 HOUR RATING VIOLATION: 5L44 CTG	
2L129 ARN 1/2 HOUR RATING VIOLATION: DMR T1ORT2 CTG	
2L129 ARN 1/2HOUR RATING VIOLATION: 2L123OR128 CTG	
5L29(5L31) EMERGENCY RATING VIOLATION	
DMR SVC MUST BE IN SERVICE	
VI RMR VIOLATION: JOR MW < XX VI VOLTAGE STABILITY	Attachment 1: Pre-outage restriction tables
VI RMR VIOLATION: JOR G1 MUST BE ONLINE	
VI RMR VIOLATION: NEED MORE VIT VAR SUPPORT	
VI RMR VIOLATION: 500KV DBL CTGS	
1L115/116 RADIALLY SUPPLIED FROM JPT, CONSULT OPS PLANNING	
VI RMR VIOLATION: PVO AUTO VAR MUST BE I/S	
VI LOAD EXCEEDS MAXIMUM LIMITS	
VIT PST RUN BACK LIMIT VIOLATION: 2L123OR128 CTG	
BOTH VI LOAD SHED PANELS ARE DISABLED (LS_230)	Attachment 2: Table 2.1, Table 2.2 and Table 2.3
BOTH VI LOAD SHED PANELS ARE DISABLED (LS_500)	
BOTH VI LOAD SHED PANELS ARE DISABLED (LS_500_1)	
CLM2VI500 - INSUFFICIENT SHEDDING	
LS_230: INSUFFICIENT LOAD SHED	
LS_500_1: INSUFFICIENT LOAD SHED	
LS_500_2: INSUFFICIENT LOAD SHED	
LS_500_2: OVER LOAD SHED	
VI WINTER RMR VIOLATION: SVI VOLTAGE INSTABILITY	Section 5.4

9.0 REVISION HISTORY

Revised By	Revision Date	Summary of Revision
PH/GW	28 October 2020	<ul style="list-style-type: none"> Section 3.8.- Added a pre-outage restriction to protect 1L117 due to a reduced rating on 1L117.
PH/GW/YLC	05 February 2021	<ul style="list-style-type: none"> Section 5.4: Added pre-outage restriction to prevent low voltage in SVI and thermal overload when SVI load exceeds 350MW and JOR not available. All Attachments: 2L129 continuous rating is changed from 590 MW to 609 MW In all Attachments Attachment 1: The continuous rating of 2L129 is 616 MVA calculated by $1.732 * 1.506 \text{ KA} * 236 \text{ KV}$. Attachment 2: Table 2.1 Note 2 and Table 2.2 Note 2, load shed initiation and cessation levels are updated. Attachment 3: Table 3.1: Half Hour Emergency Rating of 2L129 is updated.
Po Hu	15 June 2021	<ul style="list-style-type: none"> Updated 5L51_MW_Rating and 5L52_MW_Rating in Attachment 2, Table 2.3 in order to be consistent with those used in SOO 7T-18; Removed Diagram 3.1: 5L51 or 5L52 - MW /Amp Ratings vs Ambient Temperature at ING in Attachment 3.
Bob Cielen/ YanLing Cong/ Yingwei Huang/ Derek Clayton	26 November 2021	<ul style="list-style-type: none"> Section 3.9 revised for changes in PSVR stations from 12 to 8 and expected drop of 25 MW. Section 5.2.1 revised for formatting; and note added to describe differences in RAS setting and the present circuit ratings. Attachment 1: <ul style="list-style-type: none"> Updated 5L29 and 5L31 ratings Tables 1.1.2, 1.2.2, 1.2.14: removed notes on 5L29/5L31 RAS settings (information already in 7T-40) updated Attachment 2, Table 2.3, revised reference for 5L51/52 temperature ratings. Attachment 3: Removed PAL APP from Table 3.2 (as this load is decommissioned). Added forecasted summer and winter peak loads, and revised loadshed block information (for identifying included loads). Added capture of the EMS display for the VI Load Shed RAS.
Po Hu, Mari Wood	22 April 2022	<ul style="list-style-type: none"> Section 1.0 – updated EFM customer name. Section 6.2 – transformer ratings reference SOO added. Note added to confirm these ratings are not SOL as they are not based on SOO 5T-14. Section 6.3 revised to remove ratings table and add the reference to 5T-14. Attachment 1: 2L128 continuous and 0.5 hour over ratings for summer and winter seasons are updated. Attachment 2: Note 4 of Table 2.2, VI load shedding supervision level for loss of 2L129 and 2L123 is updated.

ATTACHMENT 1 - Pre-outage Restrictions

Notes for all the tables in Attachment 1:

- The continuous rating of 2L129 is 616 MVA calculated by $1.732 * 1.506 \text{ KA} * 236 \text{ kV}$.
- Both summer and winter continuous ratings of JOR T1 are 91 MVA. JOR T2 has the same summer and winter continuous ratings as JOR T1. If one of JOR T1 and T2 is OOS, the remaining one would be thermally overloaded with high JOR generation output. If TSAPM alarm: "VIOLATION_JOR T1 THERMAL" or "VIOLATION_JOR T2 THERMAL", JOR generation shall be reduced.
- Refer to Table 3.1 in Attachment 3 for the 2L129 ambient temperature dependent half an hour rating "2L129_0.5hr_Rating"
- NVI GEN = (PUN+ASH+SCA+LDR+JHN+ICG) plant MW, Other IPP generation is not included.
- Central & North VI generation = C&N VI Gen = PUN, ASH, SCA, LDR, JHN and ICG total plant MW. Other IPP generation is not included.
- Avoid radial supply to QLC, PVL or LTZ from JPT when VI load is above 1800MW.
- If it cannot be avoided, please consult TDSO Operations Planning.

Definitions:

- "VI Load" = VI AC transfers + VI generation
 - "VI Load" captures the AC source injection dependencies that impact VAR support.
- "C&SVI Load" = 2L129 ARN + (2L123 + 2L128) DMR – (1L115 + 1L116) JPT + JOR MW
 - "C&SVI Load" captures the AC source injection dependencies that impact VAR support.
- "VIT VAR Injection" = total VIT Var supporting capability available or on-line, which includes:
 - VIT Synchronous Condensers, total 250 MVAR (which includes SC2 50 MVAR, SC3 100 MVAR, SC4 100 MVAR),
 - VIT HF2 total 94.7 MVAR (which includes 5HF2/7HF2/11HF2/13HF2 with 21.6/12.0/15.4/11.1 MVAR and VIT HP2 34.6 MVAR),
 - The maximum VIT Var supporting capability is 344.7 MVAR.

Continuous Ratings for Transmission Lines:

The continuous ratings for relevant VI Transmission circuit elements are listed on the following tables. Refer to SOO 5T-10 as the source of the Amp ratings information.

The continuous MW ratings for 138 kV lines are calculated by: $1.732 * \text{Rating in KA} * 138 \text{ kV} * 0.99 \text{ pf}$

The continuous MW ratings for 230 kV lines are calculated by: $1.732 * \text{Rating in KA} * 236 \text{ kV} * 0.99 \text{ pf}$

The continuous MW ratings for 500 kV lines are calculated by: $1.732 * \text{Rating in KA} * 520 \text{ kV} * 0.99 \text{ pf}$

Circuit	Variable name used in GenShed Tables	Conductor Ratings (Amp)		MW Conductor Ratings	
		Summer (30 °C)	Winter (0 °C)	Summer (30 °C)	Winter (0 °C)
1L115	1L115_Rating	635	810	150.3 MW	191.7 MW
1L116	1L116_Rating	590	600	139.6 MW	142 MW
2L123	2L123_Rating	1636	2233	662.1 MW	903.6 MW
2L128	2L128_Rating	1858	2374	751.9 MW	960.7 MW
5L29	5L29_Rating	1321 without shore cooling 1410 with shore cooling	1410	1178 MW without shore cooling 1258 MW with shore cooling	1258 MW
5L31	5L31_Rating	1321 without shore cooling 1410 with shore cooling	1410	1178 MW without shore cooling 1258 MW with shore cooling	1258 MW

Over-Ratings for Transmission Lines:

The half an hour emergency MW ratings for 2L123 and 2L128 are calculated by: $1.732 * \text{Rating in KA} * 236 \text{ kV} * 0.99 \text{ pf}$

Circuit	Variable name used in GenShed Tables	Conductor Ratings (Amp)		MW Conductor Ratings	
		Summer (30 °C)	Winter (0 °C)	Summer (30 °C)	Winter (0 °C)
2L123	2L123_0.5hr_Rating	1810	2233	732.5 MW	903.6 MW
2L128	2L128_0.5hr_Rating	2012	2485	814.2 MW	1005.6 MW
2L129	2L129_0.5hr_Rating	Refer to Attachment 3	Refer to Attachment 3	Refer to Attachment 3	Refer to Attachment 3

Continuous Ratings for Transformers:

Circuit	Variable name used in GenShed Tables	Conductor Ratings (Amp)		MVA Conductor Ratings	
		Summer (30 °C)	Winter (0 °C)	Summer (30 °C)	Winter (0 °C)
DMR T1	DMR T1 Rating	Refer to Section 6.2	Refer to Section 6.2	Refer to Section 6.2	Refer to Section 6.2
DMR T2	DMR T2 Rating	Refer to Section 6.2	Refer to Section 6.2	Refer to Section 6.2	Refer to Section 6.2

1.1 Pre-Outage Restrictions – with VIT PST in Service

In all scenarios (Table 1.1.1 to Table 1.1.13) with VIT PST in service, limit: 2L129 ARN <= 609 MW.

If TSA-PM alarms “2L129 ARN CONTINUOUS RATING VIOLATION”, the BCHCC Operator must reduce the transfer below the limit by:

- Adjusting the tap of the VIT phase shifter transformer, and/or
- Bringing JOR online if it is available and increasing the output, and/or
- Bringing more generation online in North and Central VI Areas.

Table 1.1.1 Pre-Outage Restrictions – VI Supply System Normal with VIT PST in Service

Notes: VI Supply System Normal means that 5L29, 5L31, 5L30, 5L32, at least one of 5L42 and 5L45, all major equipment in VI shall be in service.

CONTINGENCY	PRE-OUTAGE RESTRICTIONS																												
2L129	<p>VI Reliability Must Run (VI RMR) is required for voltage stability (required for JOR/2L129/2L123/2L128 contingencies, the most limiting contingency is 2L129).</p> <p>JOR Gen and VIT VAR RMR Requirements</p> <table border="1"> <tr> <td>If VI MW load:</td> <td>≥ 2039</td> <td>≥ 2098</td> <td>≥ 2153</td> <td>≥ 2214</td> <td>≥ 2245</td> <td>(2272~2281)</td> </tr> <tr> <td>Or C&SVI MW load:</td> <td>≥ 1356</td> <td>≥ 1395</td> <td>≥ 1432</td> <td>≥ 1472</td> <td>≥ 1493</td> <td>(1511~1517)</td> </tr> <tr> <td>then Jordan MW output must be:</td> <td>on line</td> <td>≥ 50</td> <td>≥ 100</td> <td>≥ 130</td> <td>≥ 150</td> <td>170</td> </tr> <tr> <td>and available VIT MVAR must be:</td> <td colspan="2">≥ 195</td> <td>≥ 245</td> <td>≥ 295</td> <td colspan="2">= 345</td> </tr> </table> <p>If the above condition violates, TSA-PM will alarm “VI RMR VIOLATION: JOR MW < XX VI VOLTAGE STABILITY” or “VI RMR VIOLATION: NEED MORE VIT VAR SUPPORT”, then BCHCC Operator shall take the following actions:</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increasing the output, and/or • Check status of 1L18, VIT SCs, VIT HF2 <p>If VI Load or C&SVI Load exceeds the maximum limit in above table, TSA-PM will alarm “VI LOAD EXCEEDS MAXIMUM LIMITS”, then BCHCC Operator shall contact TDSO Operations Planning.</p>	If VI MW load:	≥ 2039	≥ 2098	≥ 2153	≥ 2214	≥ 2245	(2272~2281)	Or C&SVI MW load:	≥ 1356	≥ 1395	≥ 1432	≥ 1472	≥ 1493	(1511~1517)	then Jordan MW output must be:	on line	≥ 50	≥ 100	≥ 130	≥ 150	170	and available VIT MVAR must be:	≥ 195		≥ 245	≥ 295	= 345	
If VI MW load:	≥ 2039	≥ 2098	≥ 2153	≥ 2214	≥ 2245	(2272~2281)																							
Or C&SVI MW load:	≥ 1356	≥ 1395	≥ 1432	≥ 1472	≥ 1493	(1511~1517)																							
then Jordan MW output must be:	on line	≥ 50	≥ 100	≥ 130	≥ 150	170																							
and available VIT MVAR must be:	≥ 195		≥ 245	≥ 295	= 345																								
5L29 & 5L31, or 5L30 & 5L32, or 5L42 & 5L45, or DMR T1 & T2	<p>Note: VI Dependable Generation = (JOR+PUN+ASH+SCA+LDR+JHN+ICG) MW</p> <p>VI Reliability Must Run (VI RMR):</p> <ol style="list-style-type: none"> If VI Load > 2200 MW, then <ul style="list-style-type: none"> • VI Dependable Generation shall be greater than 440 MW, and • At least 3 VIT SCs shall be in service (to be updated). If 1800 MW < VI Load <= 2200 MW, then <ul style="list-style-type: none"> • VI dependable generation shall be greater than 330 MW, and • At least 3 VIT SCs shall be in service (to be updated). If 1400 MW < VI Load <= 1800 MW, then <ul style="list-style-type: none"> • VI Dependable Generation shall be greater than 300 MW, and • At least 2 VIT SCs shall be in service (to be updated). If 1200 MW < VI Load <= 1400 MW, then <ul style="list-style-type: none"> • At least 2 VIT SCs shall be in service, and • If 3 VI SCs are in service, VI Dependable Generation shall be greater than 50MW, or • If 2 VI SCs are in service, VI Dependable Generation shall be greater than 80MW. If VI Load <= 1200 MW, then <ul style="list-style-type: none"> • There is no requirement for VI Dependable Generation, and • At least 2 VIT SCs shall be in service. DMR SVC shall be in service. <p>If the above condition (a - e) violates, TSA-PM will alarm “VI RMR VIOLATION: 500KV DBL CTGS” and if condition f violates, TSA-PM will alarm “DMR SVC MUST BE IN SERVICE”, then the BCHCC Operator must reduce the transfer from LM to VI by:</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increasing the output, and/or • Bring more generation online in north and Central VI areas, and/or • The BCHCC Operator may need to check the VIT SC's minimum units on-line or the status of DMR SVC. 																												
5L29 or 5L31, or 5L30 or 5L32	No restriction.																												
2L123 or 2L128	<p>If $0.5 * (1L115 + 1L116) DMR + 0.19 * 0.5 * (2L123 + 2L128) DMR > 1L116_Rating$ Then limit: $2L129 ARN + 0.32 * 0.5 * (2L123 + 2L128) DMR +$ $0.34 * 0.19 * 2 * 0.5 * (2L123 + 2L128) DMR -$ $0.34 * (1L115 + 1L116) JPT \leq 850$</p> <p>Else limit: $2L129 ARN + 0.32 * 0.5 * (2L123 + 2L128) DMR \leq 850$</p> <p>If the above condition violates, TSA-PM will alarm “VIT PST RUN BACK LIMIT VIOLATION: 2L123OR128 CTG”, then the BCHCC Operator must reduce the transfer on 2L129 and the DMR-SAT 230 kV circuits until the conditions are met by:</p> <ul style="list-style-type: none"> • Adjust the tap of VIT transformer phase shifter to reduce 2L129 flow, and/or • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI area. 																												
DMR T2 or T1	No restriction.																												
5L45	No restriction.																												
1L115 (or 1L116)	<p>Note: 1L116 (or 1L115) may be tripped (open-ended at LTZ) by over-load protection upon loss of 1L115 (or 1L116) when VI load is above 2000MW</p> <p>Possibility of overload:</p> <p>If $1L116 DMR$ (post-contingency) = $1L116 DMR + 0.39 * 1L115 DMR > 1L116_Rating$ If $1L115 DMR$ (post-contingency) = $1L115 DMR + 0.39 * 1L116 DMR > 1L115_Rating$</p>																												

End of Table 1.1.1

Table 1.1.2 Pre-Outage Restrictions – (5L29 or 5L31) OOS with VIT PST in Service

CONTINGENCY	PRE-OUTAGE RESTRICTIONS																												
2L129	<p>VI Reliability Must Run (VI RMR) is required for voltage stability (required for JOR/2L129/2L123/2L128 contingencies; the most limiting contingency is 2L129).</p> <p>JOR Gen and VIT VAR RMR Requirements</p> <table border="1"> <tr> <td>If VI MW load:</td> <td>≥ 1942</td> <td>≥ 1974</td> <td>≥ 2021</td> <td>≥ 2086</td> <td>≥ 2125</td> <td>(2156 ~2164)</td> </tr> <tr> <td>Or C&SVI MW load:</td> <td>≥ 1291</td> <td>≥ 1313</td> <td>≥ 1344</td> <td>≥ 1387</td> <td>≥ 1413</td> <td>(1434 ~1439)</td> </tr> <tr> <td>then Jordan MW output must be:</td> <td>on line</td> <td>≥ 50</td> <td>≥ 100</td> <td>≥ 130</td> <td>≥ 150</td> <td>170</td> </tr> <tr> <td>and available VIT MVAR must be:</td> <td colspan="2">≥ 195</td> <td>≥ 245</td> <td>≥ 295</td> <td colspan="2">= 345</td> </tr> </table> <p>If the above condition violates, TSA-PM will alarm "VIRMR VIOLATION: JOR MW < XX VI VOLTAGE STABILITY" or "VIRMR VIOLATION: NEED MORE VIT SUPPORT", then BCHCC Operator shall take the following actions:</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas, and/or • Check status of 1L18, VIT SCs, VIT HF2 <p>If VI load or C&SVI load exceeds the maximum limit in above table, TSA-PM will alarm "VI AC INJ EXCEEDS MAXIMUM LIMITS"; the BCHCC Operator shall contact TDSO Operations Planning.</p> <p>Note: 1L115 & 1L116 may be tripped (open-ended at JPT) by protection upon loss of 2L129 when VI load is above 2000MW. The estimated overload is calculated as:</p> <ul style="list-style-type: none"> • 1L115 DMR + 0.094 * 2L129 ARN - 1L115_Rating and, • 1L116 DMR + 0.094 * 2L129 ARN - 1L116_Rating <p>Note: 5L31 (or 5L29) may be loaded beyond its continuous rating upon loss of 2L129 when VI load is above 2000MW, but within the overload rating: The estimated overload is calculated as:</p> <ul style="list-style-type: none"> • 5L31 + 1.07 * 2L129 ARN - 5L31_Rating or, • 5L29 + 1.07 * 2L129 ARN - 5L29_Rating 	If VI MW load:	≥ 1942	≥ 1974	≥ 2021	≥ 2086	≥ 2125	(2156 ~2164)	Or C&SVI MW load:	≥ 1291	≥ 1313	≥ 1344	≥ 1387	≥ 1413	(1434 ~1439)	then Jordan MW output must be:	on line	≥ 50	≥ 100	≥ 130	≥ 150	170	and available VIT MVAR must be:	≥ 195		≥ 245	≥ 295	= 345	
If VI MW load:	≥ 1942	≥ 1974	≥ 2021	≥ 2086	≥ 2125	(2156 ~2164)																							
Or C&SVI MW load:	≥ 1291	≥ 1313	≥ 1344	≥ 1387	≥ 1413	(1434 ~1439)																							
then Jordan MW output must be:	on line	≥ 50	≥ 100	≥ 130	≥ 150	170																							
and available VIT MVAR must be:	≥ 195		≥ 245	≥ 295	= 345																								
5L29 with 5L31 OOS, or 5L31 with 5L29 OOS, or 5L30 & 5L32, or 5L42 & 5L45, or DMR T1 & T2	Same VI RMR as Table 1.1.1 for the contingency.																												
5L30 or 5L32	No restriction.																												
2L123 or 2L128	<p>If $0.5 * (1L115 + 1L116) DMR + 0.17 * 0.5 * (2L123 + 2L128) DMR > 1L116_Rating$ Then limit: $2L129 ARN + 0.32 * 0.5 * (2L123 + 2L128) DMR +$ $0.33 * 0.17 * 2 * 0.5 * (2L123 + 2L128) DMR -$ $0.33 * (1L115 + 1L116) JPT \leq 850$ Else limit: $2L129 ARN + 0.32 * 0.5 * (2L123 + 2L128) DMR \leq 850$</p> <p>If the above condition violates, TSA-PM will alarm "VIT PST RUN BACK LIMIT VIOLATION: 2L123OR128 CTG", then the BCHCC Operator must reduce the transfer on 2L129 and the DMR-SAT 230 kV circuits until the conditions are met by:</p> <ul style="list-style-type: none"> • Adjusting the tap of VIT transformer phase shifter to reduce 2L129 flow, and/or • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas. 																												
DMR T2 or T1	No restriction.																												
5L45	No restriction.																												
5L42	No restriction.																												
5L44	No restriction.																												
1L115 (or 1L116)	<p>Note: 1L116 (or 1L115) may be tripped (open-ended at LTZ) by over-load protection upon loss of 1L115 (or 1L116) when VI load is above 2000MW</p> <p>The estimated overload is calculated as:</p> <ul style="list-style-type: none"> • 1L116 DMR + 0.38 * 1L115 DMR - 1L116_Rating or, • 1L115 DMR + 0.38 * 1L115 DMR - 1L115_Rating 																												

End of Table 1.1.2

Table 1.1.3 Pre-Outage Restrictions – (DMR T1 or T2) OOS with VIT PST in Service

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
2L129	<p>JOR Gen and VIT VAR RMR Requirements are the same as Table 1.1.2 - (5L29 or 5L31) OOS with VIT PST in Service.</p> <p>Note: 1L115 & 1L116 may be tripped (open-ended at JPT) by protection upon loss of 2L129 when VI load is above 2000MW. The estimated overload is calculated as:</p> <ul style="list-style-type: none"> • 1L115 DMR + 0.097 * 2L129 ARN - 1L115_Rating • 1L116 DMR + 0.097 * 2L129 ARN - 1L116_Rating <p>Note also that DMR T2 (or DMR T1) may be loaded beyond its continuous rating upon loss of 2L129 when VI load is above 2000MW. The estimated DMR T2 (or DMR T1) overload will be:</p> <ul style="list-style-type: none"> • DMR T2 + 1.06 * 2L129 ARN - DMR T2_Rating or, • DMR T1 + 1.06 * 2L129 ARN - DMR T1_Rating.
5L29 & 5L31, or 5L30 & 5L32, or 5L42 & 5L45, or DMR T1 with DMR T2 OOS, or DMR T2 with DMR T1 OOS	Same VI RMR as Table 1.1.1 for the contingency.
5L29 or 5L31, or 5L30 or 5L32	No restriction.
2L123 or 2L128	<p>If $0.5 * (1L115 + 1L116) DMR + 0.17 * 0.5 * (2L123 + 2L128) DMR > 1L116_Rating$ Then limit: $2L129 ARN + 0.31 * 0.5 * (2L123 + 2L128) DMR +$ $0.32 * 0.17 * 2 * 0.5 * (2L123 + 2L128) DMR -$ $0.32 * (1L115 + 1L116) JPT \leq 850$</p> <p>Else limit: $2L129 ARN + 0.31 * 0.5 * (2L123 + 2L128) DMR \leq 850$</p> <p>If the above condition violates, TSA-PM will alarm "VIT PST RUN BACK LIMIT VIOLATION: 2L123OR128 CTG", then the BCHCC Operator must reduce the transfer on 2L129 and the DMR-SAT 230 kV circuits until the conditions are met by:</p> <ul style="list-style-type: none"> • Adjusting the tap of VIT transformer phase shifter to reduce 2L129 flow, and/or • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas.
5L42	No restriction.
5L44	No restriction.
1L115 (or 1L116)	<p>Note: 1L116 (or 1L115) may be tripped (open-ended at LTZ) by over-load protection upon loss of 1L115 (or 1L116) when VI load is above 2000MW</p> <p>The estimated overload is calculated as:</p> <ul style="list-style-type: none"> • 1L116 DMR + 0.38 * 1L116 DMR - 1L116_Rating • 1L115 DMR + 0.38 * 1L115 DMR - 1L115_Rating

End of Table 1.1.3

Table 1.1.4 Pre-Outage Restrictions – (5L30 or 5L32) OOS with VIT PST in Service

CONTINGENCY	PRE-OUTAGE RESTRICTIONS																												
2L129	<p>VI Reliability Must Run (VI RMR) is required for voltage stability (required for JOR/2L129/2L123/2L128 contingencies, the most stringent one is 2L129 contingency).</p> <p>JOR Gen and VIT VAR RMR Requirements</p> <table border="1"> <tr> <td>If VI MW load,</td> <td>≥ 2040</td> <td>≥ 2099</td> <td>≥ 2131</td> <td>≥ 2176</td> <td>≥ 2199</td> <td>(2213~2219)</td> </tr> <tr> <td>Or C&SVI MW load,</td> <td>≥ 1357</td> <td>≥ 1396</td> <td>≥ 1417</td> <td>≥ 1447</td> <td>≥ 1462</td> <td>(1472~1476)</td> </tr> <tr> <td>then Jordan MW output must be:</td> <td>on line</td> <td>≥ 50</td> <td>≥ 100</td> <td>≥ 130</td> <td>≥ 150</td> <td>170</td> </tr> <tr> <td>and available VIT MVAR must be:</td> <td></td> <td>≥ 195</td> <td>≥ 245</td> <td>≥ 295</td> <td>= 345</td> <td></td> </tr> </table> <p>If the above condition violates, TSA-PM will alarm “VI RMR VIOLATION: JOR MW < XX VI VOLTAGE STABILITY”, “VI RMR VIOLATION: NEED MORE VIT VAR SUPPORT”, then BCHCC Operator shall take the following actions:</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output, and/or Checking status of 1L18, VIT SCs, VIT HFs <p>If VI load or C&SVI load exceeds the maximum limit in above table, TSA-PM will alarm “VI LOAD EXCEEDS MAXIMUM LIMITS”, then BCHCC Operator shall contact TDSO Operations Planning.</p> <p>Note: 1L115 & 1L116 may be tripped (open-ended at JPT) by protection upon loss of 2L129 when VI load is above 2000MW. The estimated overload is:</p> <ul style="list-style-type: none"> 1L115 DMR + 0.094 * 2L129 ARN - 1L115_Rating 1L116 DMR + 0.094 * 2L129 ARN - 1L116_Rating 	If VI MW load,	≥ 2040	≥ 2099	≥ 2131	≥ 2176	≥ 2199	(2213~2219)	Or C&SVI MW load,	≥ 1357	≥ 1396	≥ 1417	≥ 1447	≥ 1462	(1472~1476)	then Jordan MW output must be:	on line	≥ 50	≥ 100	≥ 130	≥ 150	170	and available VIT MVAR must be:		≥ 195	≥ 245	≥ 295	= 345	
If VI MW load,	≥ 2040	≥ 2099	≥ 2131	≥ 2176	≥ 2199	(2213~2219)																							
Or C&SVI MW load,	≥ 1357	≥ 1396	≥ 1417	≥ 1447	≥ 1462	(1472~1476)																							
then Jordan MW output must be:	on line	≥ 50	≥ 100	≥ 130	≥ 150	170																							
and available VIT MVAR must be:		≥ 195	≥ 245	≥ 295	= 345																								
5L29 & 5L31, or 5L42 & 5L45, or DMR T2 & T1, or 5L30 with 5L32 OOS, or 5L32 with 5L30 OOS	Same VI RMR as Table 1.1.1 for the contingency																												
5L29 or 5L31	No restriction.																												
2L123 or 2L128	<p>If $0.5 * (1L115 + 1L116) DMR + 0.17 * 0.5 * (2L123 + 2L128) DMR > 1L116_Rating$ Then limit: $2L129 ARN + 0.31 * 0.5 * (2L123 + 2L128) DMR +$ $0.35 * 0.17 * 2 * 0.5 * (2L123 + 2L128) DMR -$ $0.35 * (1L115 + 1L116) JPT \leq 850$</p> <p>Else limit: $2L129 ARN + 0.31 * 0.5 * (2L123 + 2L128) DMR \leq 850$</p> <p>If the above condition violates, TSA-PM will alarm “VIT PST RUN BACK LIMIT VIOLATION: 2L123OR128 CTG”, then the BCHCC Operator must reduce the transfer on 2L129 and the DMR-SAT 230 kV circuits until the conditions are met by:</p> <ul style="list-style-type: none"> Adjusting the tap of VIT transformer phase shifter to reduce 2L129 flow, and/or Bring JOR online if it is available and increase the output, and/or Bring more generation online in North and Central VI areas. 																												
DMR T2 or T1	No restriction.																												
5L45	No restriction.																												
5L42	No restriction.																												
5L44	No restriction.																												
1L115 (or 1L116)	<p>Note: 1L115 & 1L116 may be tripped (open-ended at JPT) by protection upon loss of 2L129 when VI load is above 2000MW. The estimated overload is:</p> <ul style="list-style-type: none"> 1L115 DMR + 0.39 * 2L129 ARN - 1L115_Rating 1L116 DMR + 0.39 * 2L129 ARN - 1L116_Rating 																												

End of Table 1.1.4

Table 1.1.5 Pre-Outage Restrictions – (2L123 or 2L128) OOS with VIT PST in Service

CONTINGENCY	PRE-OUTAGE RESTRICTIONS																												
2L129	<p>VI Reliability Must Run (VI RMR) is required for voltage stability (required for JOR/2L129/2L123/2L128 contingencies, the most stringent one is 2L129 contingency):</p> <p>JOR Gen and VIT VAR RMR Requirements</p> <table border="1"> <tr> <td>If VI MW load,</td> <td>≥ 1663</td> <td>≥ 1690</td> <td>≥ 1743</td> <td>≥ 1833</td> <td>≥ 1897</td> <td>(1953~1968)</td> </tr> <tr> <td>or C&SVI MW load,</td> <td>≥ 1106</td> <td>≥ 1124</td> <td>≥ 1159</td> <td>≥ 1219</td> <td>≥ 1262</td> <td>(1299~1309)</td> </tr> <tr> <td>then Jordan MW output must be:</td> <td>on line</td> <td>≥ 50</td> <td>≥ 100</td> <td>≥ 130</td> <td>≥ 150</td> <td>170</td> </tr> <tr> <td>and available VIT MVAR must be:</td> <td colspan="2">≥ 195</td> <td>≥ 245</td> <td>≥ 295</td> <td colspan="2">= 345</td> </tr> </table> <p>If the above condition violates, TSA-PM will alarm “VI RMR VIOLATION: JOR MW < XX VI VOLTAGE STABILITY” or “VI RMR VIOLATION: NEED MORE VIT VAR SUPPORT”, then BCHCC Operator shall take the following actions:</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Check status of 1L18, VIT SCs, VIT HF2 <p>If VI load or C&SVI load exceeds the maximum limits in above table, TSA-PM will alarm “VI LOAD EXCEEDS MAXIMUM LIMITS”; then BCHCC Operator shall contact TDSO Operations Planning.</p> <p>Note: 1L115 & 1L116 may be tripped (open-ended at JPT) by protection upon loss of 2L129 when VI load is above 2000MW. The estimated overload is:</p> <ul style="list-style-type: none"> • 1L115 DMR + 0.17 * 2L129 ARN - 1L115_Rating • 1L116 DMR + 0.17 * 2L129 ARN - 1L116_Rating <p>Only JOR and the remaining DMR-SAT 230 kV circuit are left to carry the area load South of DMR.</p>	If VI MW load,	≥ 1663	≥ 1690	≥ 1743	≥ 1833	≥ 1897	(1953~1968)	or C&SVI MW load,	≥ 1106	≥ 1124	≥ 1159	≥ 1219	≥ 1262	(1299~1309)	then Jordan MW output must be:	on line	≥ 50	≥ 100	≥ 130	≥ 150	170	and available VIT MVAR must be:	≥ 195		≥ 245	≥ 295	= 345	
If VI MW load,	≥ 1663	≥ 1690	≥ 1743	≥ 1833	≥ 1897	(1953~1968)																							
or C&SVI MW load,	≥ 1106	≥ 1124	≥ 1159	≥ 1219	≥ 1262	(1299~1309)																							
then Jordan MW output must be:	on line	≥ 50	≥ 100	≥ 130	≥ 150	170																							
and available VIT MVAR must be:	≥ 195		≥ 245	≥ 295	= 345																								
5L29 & 5L31, or 5L30 & 5L32, or 5L42 & 5L45, or DMR T1 & T2	Same VI RMR as Table 1.1.1 for the contingency																												
5L29 or 5L31	No restriction																												
5L30 or 5L32	No restriction																												
DMR T1 or T2	No restriction																												
2L128 (or 2L123)	Loss of the remaining DMR-SAT 230 kV line will invoke shedding VI load South of DMR. Refer to Table 2.2.																												
5L42	No restriction																												
5L44	No restriction																												
1L115 (or 1L116)	<p>Note: 1L115 & 1L116 may be tripped (open-ended at JPT) by protection upon loss of 2L129 when VI load is above 2000MW. The estimated overload is:</p> <ul style="list-style-type: none"> • 1L115 DMR + 0.44 * 2L129 ARN - 1L115_Rating • 1L116 DMR + 0.44 * 2L129 ARN - 1L116_Rating 																												
HWW T1 or T2	<p>Note: 1L115 & 1L116 may be tripped (open-ended at JPT) by protection upon loss of 2L129 when VI load is above 2000MW. The estimated overload is:</p> <ul style="list-style-type: none"> • 1L115 DMR + 0.22 * 2L129 ARN - 1L115_Rating • 1L116 DMR + 0.22 * 2L129 ARN - 1L116_Rating 																												

End of Table 1.1.5

Table 1.1.6 Pre-Outage Restrictions – Both Sections of 1L115 and 1L116 Opened between JPT and LTZ with VIT PST in Service

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
2L129	JOR Gen and VIT VAR RMR Requirements are the same as Table 1.1.1 – System Normal for the contingency
5L29 & 5L31, or 5L30 & 5L32, or 5L42 & 5L45, or DMR T1 & T2	Same VI RMR as Table 1.1.1 for the contingency
5L29 or 5L31, or 5L30 or 5L32	No restriction.
2L123 or 2L128	No restriction.
DMR T1 or T2	No restriction.
5L42	No restriction.
5L44	No restriction.
5L45	No restriction.

End of Table 1.1.6

Table 1.1.7 Pre-Outage Restrictions – (any segment of 1L115 or any segment of 1L116) OOS with VIT PST in Service

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
2L129	JOR Gen and VIT VAR RMR Requirements are the same as Table 1.1.1 – System Normal for the contingency Note: 1L116 (or 1L115) may be tripped (open-ended at LTZ by 1CB3 if 1L115 was OOS, or open-ended at LTZ by 1CB1 if 1L116 was OOS) by overload protection upon loss of 2L129 when VI load is above 2000MW. The estimated overload is: <ul style="list-style-type: none">• 1L115 DMR + 0.14 * 2L129 ARN - 1L115_Rating• 1L116 DMR + 0.14 * 2L129 ARN - 1L116_Rating
5L29 with 5L31 OOS, or 5L31 with 5L29 OOS, or 5L30 & 5L32, or 5L42 & 5L45, or DMR T1 & T2	Same VI RMR as Table 1.1.1 for the contingency
5L29 or 5L31, or 5L30 or 5L32	No restriction.
2L123 or 2L128	Note: 1L116 (or 1L115) may be tripped (open-ended at LTZ by 1CB3 if 1L115 was OOS, or open-ended at LTZ by 1CB1 if 1L116 was OOS) by overload protection upon loss of 2L123 (or 2L128). 1L115 LTZ designated the MW flow for PVL-LTZ section of 1L115 measured at LTZ. It is a signed quantity; negative implied going into LTZ. Same for 1L116 LTZ. The estimated overload is: <ul style="list-style-type: none">• 1L116 DMR + 0.24 * 2L123 DMR (or 2L128 DMR) - 1L116_Rating• 1L115 DMR + 0.24 * 2L123 DMR (or 2L128 DMR) - 1L115_Rating <ul style="list-style-type: none">• If 1L115 DMR (or 1L116 DMR if 1L115 was OOS) + 0.24 * 0.5 * (2L123 + 2L128) DMR > 1L115_Rating Then limit: 2L129 ARN + 0.34 * 0.5 * (2L123 + 2L128) DMR + 0.24 * 0.24 * 0.5 * (2L123 + 2L128) DMR - 0.24 * 1L115 LTZ (or 1L116 LTZ if 1L115 was OOS) < = 850 Else limit: 2L129 ARN + 0.34 * 0.5 * (2L123 + 2L128) DMR < = 850 If the above condition is violated, TSA-PM will alarm "VIOLATION_VIT PST RUN BACK LIMIT 2L123OR128 CTG", then the BCHCC Operator must reduce the transfer on the 2L123/2L128 and 1L115 (or 1L116) by: <ul style="list-style-type: none">• Bring JOR online if it is available and increase the output.
DMR T2 or T1	No restriction.
5L45	No restriction.
5L42	No restriction.
5L44	No restriction.
HWW T1 or T2	Note: 1L116 (or 1L115) may be tripped (open-ended at LTZ; open LTZ 1CB3 if 1L115 was OOS, open LTZ 1CB1 if 1L116 was OOS) by overload protection upon loss of HWW T1 (or HWW T2) when VI load is above 2000MW Possibility of overload: If 1L116 DMR (post-contingency) = 1L116 DMR + 0.19 * HWW T1 (or HWW T2) > 1L116_Rating If 1L115 DMR (post-contingency) = 1L115 DMR + 0.19 * HWW T1 (or HWW T2) > 1L115_Rating

End of Table 1.1.7

Table 1.1.8 Pre-Outage Restrictions – DMR SVC and VAR Master OOS with VIT PST in Service

CONTINGENCY	PRE-OUTAGE RESTRICTIONS																																		
2L129	VI Reliability Must Run (VI RMR) is required for voltage stability (required for JOR/2L129/2L123/2L128 contingencies, the most stringent one is 2L129 contingency): JOR Gen and VIT VAR RMR Requirements <table border="1"> <tr> <td>If VI MW load,</td> <td>≥ 1858</td> <td>≥ 1890</td> <td>≥ 1935</td> <td>≥ 2009</td> <td>≥ 2060</td> <td>(2093 ~2099)</td> </tr> <tr> <td>Or C&SVI MW load,</td> <td>≥ 1236</td> <td>≥ 1257</td> <td>≥ 1287</td> <td>≥ 1336</td> <td>≥ 1370</td> <td>(1392 ~1396)</td> </tr> <tr> <td>then Jordan MW output must be:</td> <td>on line</td> <td>≥ 50</td> <td>≥ 100</td> <td>≥ 130</td> <td>≥ 150</td> <td>170</td> </tr> <tr> <td>and available VIT MVAR must be:</td> <td></td> <td>≥ 195</td> <td>≥ 245</td> <td>≥ 295</td> <td></td> <td>= 345</td> </tr> </table> If the above condition violates, TSA-PM will alarm “VI RMR VIOLATION: JOR MW < XX VI VOLTAGE STABILITY”, or “VI RMR VIOLATION: NEED MORE VIT VAR SUPPORT”, then BCHCC Operator shall take the following actions: <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output, and/or Checking status of 1L18, VIT SCs, VIT HF2 If VI load or C&SVI load exceeds the maximum limit in above table, TSA-PM will alarm “VI LOAD EXCEEDS MAXIMUM LIMITS”, then BCHCC Operator shall contact TDSO Operations Planning.							If VI MW load,	≥ 1858	≥ 1890	≥ 1935	≥ 2009	≥ 2060	(2093 ~2099)	Or C&SVI MW load,	≥ 1236	≥ 1257	≥ 1287	≥ 1336	≥ 1370	(1392 ~1396)	then Jordan MW output must be:	on line	≥ 50	≥ 100	≥ 130	≥ 150	170	and available VIT MVAR must be:		≥ 195	≥ 245	≥ 295		= 345
If VI MW load,	≥ 1858	≥ 1890	≥ 1935	≥ 2009	≥ 2060	(2093 ~2099)																													
Or C&SVI MW load,	≥ 1236	≥ 1257	≥ 1287	≥ 1336	≥ 1370	(1392 ~1396)																													
then Jordan MW output must be:	on line	≥ 50	≥ 100	≥ 130	≥ 150	170																													
and available VIT MVAR must be:		≥ 195	≥ 245	≥ 295		= 345																													
Other contingencies	The same as System Normal in Table 1.1.1.																																		

End of Table 1.1.8

Table 1.1.9 Pre-Outage Restrictions – 2L126 (or 2L170, or one GTP Capacitor) OOS with VIT PST in Service

CONTINGENCY	PRE-OUTAGE RESTRICTIONS																																		
2L129	VI Reliability Must Run (VI RMR) is required for voltage stability (required for JOR/2L129/2L123/2L128 contingencies, the most stringent one is 2L129 contingency): JOR Gen and VIT VAR RMR Requirements <table border="1"> <tr> <td>If VI MW load,</td> <td>≥ 1953</td> <td>≥ 2008</td> <td>≥ 2066</td> <td>≥ 2153</td> <td>≥ 2208</td> <td>(2254~2257)</td> </tr> <tr> <td>Or C&SVI MW load,</td> <td>≥ 1299</td> <td>≥ 1335</td> <td>≥ 1374</td> <td>≥ 1432</td> <td>≥ 1468</td> <td>(1499~1501)</td> </tr> <tr> <td>then Jordan MW output must be:</td> <td>on line</td> <td>≥ 50</td> <td>≥ 100</td> <td>≥ 130</td> <td>≥ 150</td> <td>170</td> </tr> <tr> <td>and available VIT MVAR must be:</td> <td></td> <td>≥ 195</td> <td>≥ 245</td> <td>≥ 295</td> <td></td> <td>= 345</td> </tr> </table> If the above condition violates, TSA-PM will alarm “VI RMR VIOLATION: JOR MW < XX VI VOLTAGE STABILITY” or “VI RMR VIOLATION: NEED MORE VIT VAR SUPPORT”, then BCHCC Operator shall take the following actions: <ul style="list-style-type: none"> Bring JOR online if it is available and increase the output, and/or Check status of 1L18, VIT SCs, VIT HF2 If VI Load or C&SVI Load exceeds the maximum limit in above table, TSA-PM will alarm “VI LOAD EXCEEDS MAXIMUM LIMITS”; then BCHCC Operator shall contact TDSO Operations Planning.							If VI MW load,	≥ 1953	≥ 2008	≥ 2066	≥ 2153	≥ 2208	(2254~2257)	Or C&SVI MW load,	≥ 1299	≥ 1335	≥ 1374	≥ 1432	≥ 1468	(1499~1501)	then Jordan MW output must be:	on line	≥ 50	≥ 100	≥ 130	≥ 150	170	and available VIT MVAR must be:		≥ 195	≥ 245	≥ 295		= 345
If VI MW load,	≥ 1953	≥ 2008	≥ 2066	≥ 2153	≥ 2208	(2254~2257)																													
Or C&SVI MW load,	≥ 1299	≥ 1335	≥ 1374	≥ 1432	≥ 1468	(1499~1501)																													
then Jordan MW output must be:	on line	≥ 50	≥ 100	≥ 130	≥ 150	170																													
and available VIT MVAR must be:		≥ 195	≥ 245	≥ 295		= 345																													
Other contingencies	The same as System Normal in Table 1.1.1.																																		

End of Table 1.1.9

Table 1.1.10 Pre-Outage Restrictions – one of (2L142, 2L143, 2L145, 2L146 or 5L42) OOS with VIT PST in Service

CONTINGENCY	PRE-OUTAGE RESTRICTIONS						
2L129	JOR Gen and VIT VAR RMR Requirements are the same as Table 1.1.4 - (5L30 or 5L32) OOS with VIT PST in Service						
Other contingencies	The same as System Normal in Table 1.1.1.						

End of Table 1.1.10

Table 1.1.11 Pre-Outage Restrictions – one of any capacitor at (PVO, ESQ, CLD, HSY, SNY) OOS with VIT PST in Service

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
2L129	JOR Gen and VIT VAR RMR Requirements are the same as Table 1.1.4 - 5L30 OOS, for the contingency.
Other contingencies	The same as System Normal in Table 1.1.1

Note:

"one of any capacitor at (PVO, ESQ, CLD, HSY, SNY) OOS" means one of the following capacitors OOS:

Station	Capacitor designation	MVAR
HSY	12CX1	14.4
	12CX2	10.8
	12CX4	14.1
	ESQ	12CX1
ESQ	12CX11	21.6
	12CX12	12
	SNY	25CX1
SNY	25CX2	5.4
	PVO	25CX2
	1CX1, 1CX2	9.6
CLD	1CX3	2×51.5
	CLD	12
	25CX3,4	51.0

End of Table 1.1.11

Table 1.1.12 Pre-Outage Restrictions – 5L44, 5L45, 2L144, 1L12, DMR T4 or T5 OOS with VIT PST in Service

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
2L129	JOR Gen and VIT VAR RMR Requirements are the same as Table 1.1.1 - system normal, for the contingency.
Other contingencies	The same as System Normal in Table 1.1.1

End of Table 1.1.12

Table 1.1.13 Pre-Outage Restrictions – one of (1L10, 1L11 or 1L14) OOS with VIT PST in Service

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
2L129	JOR Gen and VIT VAR RMR Requirements are the same as Table 1.1.4 - 5L30 OOS, for the contingency.
Other contingencies	The same as System Normal in Table 1.1.1

End of Table 1.1.13

1.2 Pre-Outage Restrictions – without VIT PST

Table 1.2.1

Pre-Outage Restrictions – VI Supply System Normal without PST

Notes: VI Supply System Normal means that 5L29, 5L31, 5L30, 5L32, at least one of 5L44 and 5L45, all major equipment in VI shall be in service.

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
Without any contingency	<p>Limit: $2L129\ ARN \leq 609\ MW$</p> <p>If TSA-PM alarms “2L129 ARN CONTINUOUS RATING VIOLATION”, the BCHCC Operator must reduce the transfer below the limit by:</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output. Bringing more generation online in North and Central VI areas. <p>The effectiveness of the above means to reduce 2L129 flow are reflected in the coefficients of the following formula: $2L129\ ARN = K1*VI/load - K2*JOR\ Gen - K3*NVI\ GEN - K4*(5L51+5L52)/NG - K0$ Where: $K1 = 0.41$, $K2 = 0.62$, $K3 = 0.26$, $K4 = 0.04$, and $K0 = 122$</p>
2L129	<p>VI Reliability Must Run (VI RMR) requirements are the same as Table 1.1.1 - System Normal</p> <p>Note: 1L115 & 1L116 may be tripped (open-ended at JPT) by over-load protection upon loss of 2L129 when VI load is above 2000MW</p> <p>Possibility of overload:</p> <ul style="list-style-type: none"> If 1L115 DMR (post-contingency) = $1L115\ DMR + 0.10 * 2L129\ ARN > 1L115_Rating$ If 1L116 DMR (post-contingency) = $1L116\ DMR + 0.10 * 2L129\ ARN > 1L116_Rating$
5L29 & 5L31, or 5L30 & 5L32, or 5L42 & 5L45, or DMR T1 & T2	Same VI RMR as Table 1.1.1 for the contingency.
5L29, or 5L31	<p>Limit: $2L129\ ARN + 0.5 * 0.086 * (5L29+5L31)\ MSA \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 5L29OR31 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and 5L29 and 5L31 until the condition is met by :</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output, and/or Bringing more generation online in North and Central VI areas.
5L30, or 5L32	<p>Limit: $2L129\ ARN + 0.5 * 0.13 * (5L30+5L32)\ CKY \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 5L30OR32 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and 5L30 and 5L32 until the condition is met by :</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output, and/or Bringing more generation online in North and Central VI areas.
2L123 or 2L128	<p>Note that 1L115 & 1L116 may be tripped (<i>open-ended at JPT</i>) by over-load protection upon loss of 2L123 or 2L128.</p> <ul style="list-style-type: none"> If $0.5 * (1L115 + 1L116) DMR + 0.15 * 0.5 * (2L123 + 2L128) DMR > 1L116_Rating$ Then limit: $2L129\ ARN + 0.37 * 0.5 * (2L123 + 2L128)\ DMR +$ $0.38 * 0.15 * 2 * 0.5 * (2L123 + 2L128)\ DMR -$ $0.38 * (1L115 + 1L116) JPT \leq 2L129_0.5hr_Rating$ Else limit: $2L129\ ARN + 0.37 * 0.5 * (2L123 + 2L128)\ DMR \leq 2L129_0.5hr_Rating$ <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 2L123OR128 CTG ”, then the BCHCC Operator must reduce the transfer on the 2L123/2L128 and 1L115/1L116 by :</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output.
DMR T1 or T2	<p>Limit: $2L129\ ARN + 0.5 * 0.17 * (DMR\ T1 + T2)\ MW \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: DMR T1ORT2 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and DMR transformers until the condition is met by :</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output, and/or Bringing more generation online in North and Central VI areas.
5L42	<p>Limit: $2L129\ ARN + 0.13 * 5L42\ KLY \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2 HOUR RATING VIOLATION: 5L42 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and/or 5L42 until the condition is met by :</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output, and/or Bringing more generation online in North and Central VI areas.
5L44	<p>Limit: $2L129\ ARN + 0.2 * (5L44\ ING + 2L53\ MAN + 2L27\ ING) \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129ARN 1/2HOUR RATING VIOLATION: 5L44 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and/or 5L44 until the condition is met by :</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output, and/or Bringing more generation online in North and Central VI areas.

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
1L115 (or 1L116)	<p>Note: 1L116 (or 1L115) may be tripped (open-ended at LTZ) by over-load protection upon loss of 1L115 (or 1L116) when VI load is above 2000MW</p> <p>Possibility of overload:</p> <p>If 1L116 DMR (post-contingency) = 1L116 DMR + 0.37 * 1L115 DMR > 1L116_Rating</p> <p>If 1L115 DMR (post-contingency) = 1L115 DMR + 0.37 * 1L116 DMR > 1L115_Rating</p>

End of Table 1.2.1

Table 1.2.2 Pre-Outage Restrictions – 5L29 or 5L31 OOS without VIT PST

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
Without any contingency	<p>Limit: $2L129 \text{ ARN} \leq 609 \text{ MW}$</p> <p>If TSA-PM alarms “$2L129 \text{ ARN}$ CONTINUOUS RATING VIOLATION”, the BCHCC Operator must reduce the transfer below the limit by:</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output, and/or Bringing more generation online in North and Central VI areas. <p>The effectiveness of the above means to reduce $2L129$ flow are reflected in the coefficients of the following formula: $2L129 \text{ ARN} = K1 * \text{VI load} - K2 * \text{JOR GEN} - K3 * \text{NVI GEN} - K4 * (5L51 + 5L52) \text{ ING} - K0$ Where: $K1 = 0.46$, $K2 = 0.65$, $K3 = 0.295$, $K4 = 0.036$ and $K0 = 186$</p>
2L129	<p>VI Reliability Must Run (VI RMR) requirements are the same as Table 1.1.2 - 5L29 or 5L31 OOS</p> <p>Note: 1L115 & 1L116 may be tripped (open-ended at JPT) by over-load protection upon loss of 2L129 when VI load is above 2000 MW</p> <p>Possibility of overload:</p> <ul style="list-style-type: none"> If $1L115 \text{ DMR}$ (post-contingency) = $1L115 \text{ DMR} + 0.12 * 2L129 \text{ ARN} > 1L115_Rating$ If $1L116 \text{ DMR}$ (post-contingency) = $1L116 \text{ DMR} + 0.12 * 2L129 \text{ ARN} > 1L116_Rating$ <p>Note: 5L31 (or 5L29) may be loaded beyond its continuous rating upon loss of 2L129 when VI load is above 2000MW</p> <p>For estimating 5L31 (or 5L29) post-contingency flow:</p> <ul style="list-style-type: none"> 5L31 MSA (post-contingency) = $5L31 + 1.07 * 2L129 \text{ ARN}$ 5L29 MSA (post-contingency) = $5L29 + 1.07 * 2L129 \text{ ARN}$
5L29 with 5L31 OOS, or 5L31 with 5L29 OOS, or 5L30 & 5L32, or 5L42 & 5L45, or DMR T1 & T2	Same VI RMR as Table 1.2.1 for the contingency.
5L30, or 5L32	<p>Limit: $2L129 \text{ ARN} + 0.5 * 0.12 * (5L30 + 5L32) \text{ CKY} \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “$2L129 \text{ ARN}$ 1/2HOUR RATING VIOLATION: 5L30OR32 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and 5L30 and 5L32 until the condition is met by :</p> <ul style="list-style-type: none"> Bring JOR online if it is available and increase the output, and/or Bring more generation online in North and Central VI areas.
2L123 or 2L128	<p>Note that 1L115 & 1L116 may be tripped (<i>open-ended at JPT</i>) by over-load protection upon loss of 2L123 or 2L128.</p> <ul style="list-style-type: none"> If $0.5 * (1L115 + 1L116) \text{ DMR} + 0.15 * 0.5 * (2L123 + 2L128) \text{ DMR} > 1L116_Rating$ Then limit: $2L129 \text{ ARN} + 0.36 * 0.5 * (2L123 + 2L128) \text{ DMR} +$ $0.38 * 0.15 * 2 * 0.5 * (2L123 + 2L128) \text{ DMR} -$ $0.38 * (1L115 + 1L116) \text{ JPT} \leq 2L129_0.5hr_Rating$ Else limit: $2L129 \text{ ARN} + 0.36 * 0.5 * (2L123 + 2L128) \text{ DMR} \leq 2L129_0.5hr_Rating$ <p>If the above condition violates, TSA-PM will alarm “$2L129 \text{ ARN}$ 1/2HOUR RATING VIOLATION: 2L123OR128 CTG”, then the BCHCC Operator must reduce the transfer on the 2L123/2L128 and 1L115/1L116 by :</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output.
DMR T1 or T2	Same as Table 1.2.1 for the contingency
5L42	Same as Table 1.2.1
5L44	Same as Table 1.2.1
1L115 (or 1L116)	<p>Note: 1L116 (or 1L115) may be tripped (open-ended at LTZ) by over-load protection upon loss of 1L115 (or 1L116) when VI load is above 2000MW</p> <p>Possibility of overload:</p> <ul style="list-style-type: none"> If $1L116 \text{ DMR}$ (post-contingency) = $1L116 \text{ DMR} + 0.37 * 1L115 \text{ DMR} > 1L116_Rating$ If $1L115 \text{ DMR}$ (post-contingency) = $1L115 \text{ DMR} + 0.37 * 1L116 \text{ DMR} > 1L115_Rating$

End of Table 1.2.2

Table 1.2.3 Pre-Outage Restrictions – DMR T1 or T2 OOS without VIT PST

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
Without any contingency	<p>Limit: $2L129\ ARN \leq 609\ MW$</p> <p>If TSA-PM alarms “2L129 ARN CONTINUOUS RATING VIOLATION”, the BCHCC Operator must reduce the transfer below the limit by:</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas. <p>The effectiveness of the above means to reduce 2L129 flow are reflected in the coefficients of the following formula:</p> $2L129\ ARN = K1*Vload - K2*JOR\ Gen - K3*NVI\ GEN - K4*(5L51+5L52)\ ING - K0$ <p>where $K1 = 0.49$, $K2 = 0.68$, $K3 = 0.28$, $K4 = 0.026$, and $K0 = 214$</p>
2L129	<p>VI Reliability Must Run (VI RMR) requirements are the same as Table 1.1.3 - DMR T1 or T2 OOS</p> <p>Note: 1L115 & 1L116 may be tripped (open-ended at JPT) by over-load protection upon loss of 2L129 when VI load is above 2000MW</p> <p>Possibility of overload:</p> <ul style="list-style-type: none"> If 1L115 DMR (post-contingency) = 1L115 DMR + 0.098 * 2L129 ARN > 1L115_Rating If 1L116 DMR (post-contingency) = 1L116 DMR + 0.098 * 2L129 ARN > 1L116_Rating <p>Note also that DMR T2 (or DMR T1) may be loaded beyond its continuous rating upon loss of 2L129 when VI load is above 2000MW</p> <p>For estimating DMR T2 (or DMR T1) post-contingency flow:</p> $\text{DMR T2 (post-contingency)} = \text{DMR T2} + 1.05 * 2L129\ ARN$ $\text{DMR T1 (post-contingency)} = \text{DMR T1} + 1.05 * 2L129\ ARN$
5L29 & 5L31, or 5L30 & 5L32, or 5L42 & 5L45, or DMR T1 with DMR T2 OOS, or DMR T2 with DMR T1 OOS	Same VI RMR as Table 1.2.1 for the contingency.
5L29, or 5L31	<p>Limit: $2L129\ ARN + 0.5 * 0.088 * (5L29+5L31)\ MSA \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 5L29OR31 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and 5L29 and 5L31 until the condition is met by</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas.
5L30, or 5L32	<p>Limit: $2L129\ ARN + 0.5 * 0.12 * (5L30+5L32)\ CKY \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 5L30OR32 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and 5L30 and 5L32 until the condition is met by</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas.
2L123 or 2L128	<p>Note that 1L115 & 1L116 may be tripped (open-ended at JPT) by over-load protection upon loss of 2L123 or 2L128.</p> <ul style="list-style-type: none"> • If $0.5 * (1L115 + 1L116) DMR + 0.16 * 0.5 * (2L123 + 2L128) DMR > 1L116_Rating$ Then limit: $2L129\ ARN + 0.34 * 0.5 * (2L123 + 2L128)\ DMR +$ $0.36 * 0.16 * 2 * 0.5 * (2L123 + 2L128)\ DMR -$ $0.36 * (1L115 + 1L116) JPT \leq 2L129_0.5hr_Rating$ Else limit: $2L129\ ARN + 0.34 * 0.5 * (2L123 + 2L128)\ DMR \leq 2L129_0.5hr_Rating$ <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 2L123OR128 CTG”, then the BCHCC Operator must reduce the transfer on the 2L123/2L128 and 1L115/1L116 by :</p> <ul style="list-style-type: none"> • Bringing JOR online if it is available and increasing the output.
5L42	<p>Limit: $2L129\ ARN + 0.13 * 5L42\ KLY \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 5L42 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and/or 5L42 until the condition is met by :</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas.
5L44	Same as Table 1.2.1

End of Table 1.2.3

Table 1.2.4 Pre-Outage Restrictions – 5L30 or 5L32 OOS without VIT PST

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
Without any contingency	<p>Limit: $2L129 \text{ ARN} \leq 609 \text{ MW}$</p> <p>If TSA-PM alarms “2L129 ARN CONTINUOUS RATING VIOLATION”, the BCHCC Operator must reduce the transfer below the limit by:</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output, and/or Bringing more generation online in North and Central VI areas. <p>The effectiveness of the above means to reduce 2L129 flow are reflected in the co-efficients of the following formula: $2L129 \text{ ARN} = K1 * \text{VI load} - K2 * \text{JOR Gen} - K3 * \text{NVI GEN} - K4 * (5L51 + 5L52) \text{ ING} - K0$ Where: $K1 = 0.48$, $K2 = 0.66$, $K3 = 0.29$, $K4 = 0.03$, $K0 = 222$</p>
2L129	<p>VI Reliability Must Run (VI RMR) requirements are the same as Table 1.1.4 – 5L30 or 5L32 OOS</p> <p>Note: 1L115 & 1L116 may be tripped (open-ended at JPT) by over-load protection upon loss of 2L129 when VI load is above 2000MW</p> <p>Possibility of overload:</p> <ul style="list-style-type: none"> If $1L115 \text{ DMR} (\text{post-contingency}) = 1L115 \text{ DMR} + 0.098 * 2L129 \text{ ARN} > 1L115 \text{ Rating}$ If $1L116 \text{ DMR} (\text{post-contingency}) = 1L116 \text{ DMR} + 0.098 * 2L129 \text{ ARN} > 1L116 \text{ Rating}$
5L29 & 5L31, or 5L42 & 5L45, or DMR T1 & T2 5L30 with 5L32 OOS 5L32 with 5L30 OOS	Same VI RMR as Table 1.2.1 for the contingency.
5L29 or 5L31	<p>Limit: $2L129 \text{ ARN} + 0.5 * 0.097 * (5L29 + 5L31) \text{ MSA} \leq 2L129 \text{ _0.5hr_Rating}$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 5L29OR31 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and 5L29 and 5L31 until the condition is met by :</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output, and/or Bringing more generation online in North and Central VI areas.
2L123 or 2L128	<p>Note that 1L115 & 1L116 may be tripped (<i>open-ended at JPT</i>) by over-load protection upon loss of 2L123 or 2L128.</p> <ul style="list-style-type: none"> If $0.5 * (1L115 + 1L116) \text{ DMR} + 0.16 * 0.5 * (2L123 + 2L128) \text{ DMR} > 1L116 \text{ Rating}$ Then limit: $2L129 \text{ ARN} + 0.35 * 0.5 * (2L123 + 2L128) \text{ DMR} +$ $0.37 * 0.16 * 2 * 0.5 * (2L123 + 2L128) \text{ DMR} -$ $0.37 * (1L115 + 1L116) \text{ JPT} \leq 2L129 \text{ _0.5hr_Rating}$ Else limit: $2L129 \text{ ARN} + 0.35 * 0.5 * (2L123 + 2L128) \text{ DMR} \leq 2L129 \text{ _0.5hr_Rating}$ <p>If the above condition violates, TSA-PM will alarm “2L129 1/2HOUR RATING VIOLATION: 2L123OR128 CTG ”, then the BCHCC Operator must reduce the transfer on the 2L123/2L128 and 1L115/1L116 by :</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output.
DMR T1 or T2	<p>Limit: $2L129 \text{ ARN} + 0.5 * 0.16 * (\text{DMR T1} + \text{T2}) \text{ MW} \leq 2L129 \text{ _0.5hr_Rating}$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: DMR T1ORT2 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and DMR transformers until the condition is met by :</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output, and/or Bringing more generation online in North and Central VI areas.
5L42	<p>Limit: $2L129 \text{ ARN} + 0.13 * 5L42 \text{ KLY} \leq 2L129 \text{ _0.5hr_Rating}$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 5L42 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and/or 5L42 until the condition is met by :</p> <ul style="list-style-type: none"> Bringing JOR online if it is available and increasing the output, and/or Bringing more generation online in North and Central VI areas.
5L44	Same as Table 1.2.1.
1L115 (or 1L116)	<p>Note: 1L116 (or 1L115) may be tripped (open-ended at LTZ) by over-load protection upon loss of 1L115 (or 1L116) when VI load is above 2000MW</p> <p>Possibility of overload:</p> <ul style="list-style-type: none"> If $1L116 \text{ DMR} (\text{post-contingency}) = 1L116 \text{ DMR} + 0.38 * 1L115 \text{ DMR} > 1L116 \text{ Rating}$ If $1L115 \text{ DMR} (\text{post-contingency}) = 1L115 \text{ DMR} + 0.38 * 1L116 \text{ DMR} > 1L115 \text{ Rating}$

End of Table 1.2.4

Table 1.2.5 Pre-Outage Restrictions – 2L123 or 2L128 OOS without VIT PST

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
Without any contingency	<p>Limit: $2L129 \text{ ARN} \leq 609 \text{ MW}$</p> <p>If TSA-PM alarms “2L129 ARN CONTINUOUS RATING VIOLATION”, the BCHCC Operator must reduce the transfer below the limit by:</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas. <p>The effectiveness of the above means to reduce 2L129 flow are reflected in the coefficients of the following formula:</p> <p>If both ends of 1L115 & 1L116 are connected, then $2L129 \text{ ARN} = K1 * \text{VI Load} - K2 * \text{JOR Gen} - K3 * \text{NVI Gen} - K4 * (5L51 + 5L52) \text{ ING} - K0$ Where $K1 = 0.47$, $K2 = 0.67$, $K3 = 0.21$, $K4 = 0.04$, $K0 = 212$</p> <p>If 1L115 and 1L116 between LTZ and JPT are open, then $2L129 \text{ ARN} = K1 * \text{VI Load} - K2 * \text{JOR Gen} - K3 * \text{NVI Gen} - K4 * (5L51 + 5L52) \text{ ING} - K0$ Where $K1 = 0.53$, $K2 = 0.72$, $K3 = 0.15$, $K4 = 0.04$, $K0 = 212$</p>
2L129	<p>VI Reliability Must Run (VI RMR) requirements are the same as Table 1.1.5 – 2L123 or 2L128 OOS</p> <p>** Note: Avoid scheduling 2L123 or 2L128 outage for periods when VI load equal or exceed 1800 MW as loss of 2L129 would overload the remaining DMR-SAT 230 kV line (2L129 contingency would likely cause 1L115/1L116 O/L; open-ending 1L115 & 1L116 at JPT by O/L protection would dump the pre-contingency 1L115 & 1L116 flows from LTZ to JPT onto the remaining DMR-SAT 230 kV line.) There may not be enough resources to alleviate the O/L and there is no load dropping scheme similar to that for loss of the parallel DMR-SAT 230 kV line with 2L123 or 2L128 already opened.</p> <p>Note: 1L115 & 1L116 may be tripped (open-ended at JPT) by over-load protection upon loss of 2L129 when VI load is above 2000MW</p> <p>Possibility of overload:</p> <p>If 1L115 DMR (post-contingency) = $1L115 \text{ DMR} + 0.18 * 2L129 \text{ ARN} > 1L115_Rating$ If 1L116 DMR (post-contingency) = $1L116 \text{ DMR} + 0.18 * 2L129 \text{ ARN} > 1L116_Rating$</p> <p>Only JOR/the remaining DMR-SAT 230 kV circuit left to carry the area load South of DMR.</p>
5L29 & 5L31, or 5L30 & 5L32, or 5L42 & 5L45, or DMR T1 & T2	Same as System Normal Table 1.2.1
5L29 or 5L31	<p>Limit: $2L129 \text{ ARN} + 0.5 * 0.077 * (5L29 + 5L31) \text{ MSA} \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 5L29OR31 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and 5L29/31 until the condition is met by</p> <ul style="list-style-type: none"> • Bringing JOR online if it is available and increasing the output, and/or • Bringing more generation online in North and Central VI areas.
5L30 or 5L32	<p>Limit: $2L129 \text{ ARN} + 0.5 * 0.095 * (5L30 + 5L32) \text{ CKY} \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 5L30OR32 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and 5L30/32 until the condition is met by</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas.
2L128 (or 2L123)	Loss of the remaining DMR-SAT 230 kV line will invoke shedding VI load South of DMR. Refer to Table 2.2.
DMR T1 or T2	<p>Limit: $2L129 \text{ ARN} + 0.5 * 0.15 * (\text{DMR T1} + \text{T2}) \text{ MW} \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: DMR T1ORT2 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and DMR transformers until the condition is met by :</p> <ul style="list-style-type: none"> • Bringing JOR online if it is available and increasing the output, and/or • Bringing more generation online in North and Central VI areas.
5L42	<p>Limit: $2L129 \text{ ARN} + 0.12 * 5L42 \text{ KLY} \leq 2L129_0.5hr_Rating$</p> <p>If 1L115 and 1L116 between LTZ and JPT are open, then $\text{Limit: } 2L129 \text{ ARN} + 0.098 * 5L42 \text{ KLY} \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 5L42 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and 5L42 until the conditions are met by</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas.

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
5L44	Same as Table 1.2.1
1L115 (or 1L116)	<p>Note: 1L116 (or 1L115) may be tripped (open-ended at LTZ) by over-load protection upon loss of 1L115 (or 1L116) when VI load is above 2000MW</p> <p>Possibility of overload:</p> <p>If 1L116 DMR (post-contingency) = 1L116 DMR + 0.43 * 1L115 DMR > 1L116_Rating If 1L115 DMR (post-contingency) = 1L115 DMR + 0.43 * 1L116 DMR > 1L115_Rating</p>
HWW T1 or T2	<p>Note: 1L116 & 1L115 may be tripped (open-ended at JPT) by over-load protection upon loss of HWW T1 (or HWW T2) when VI load is above 2000MW</p> <p>Possibility of overload:</p> <p>If 1L115 DMR (post-contingency) = 1L115 DMR + 0.22 * HWW T1 (or HWW T2) > 1L115_Rating If 1L116 DMR (post-contingency) = 1L116 DMR + 0.22 * HWW T1 (or HWW T2) > 1L116_Rating</p>

End of Table 1.2.5

Table 1.2.6 Pre-Outage Restrictions – Both Sections of 1L115 and 1L116 Opened between JPT and LTZ without VIT PST

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
Without any contingency	<p>Limit: $2L129 \text{ ARN} \leq 609 \text{ MW}$</p> <p>If TSA-PM alarms "2L129 ARN CONTINUOUS RATING VIOLATION", the BCHCC Operator must reduce the transfer below the limit by:</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas. <p>The effectiveness of the above means to reduce 2L129 flow are reflected in the coefficients of the following formula: $2L129 \text{ ARN} = K1 * \text{VI Load} - K2 * \text{JOR GEN} - K3 * \text{NVI GEN} - K4 * (5L51 + 5L52) \text{ ING} - K0$ where $K1 = 0.46$, $K2 = 0.64$, $K3 = 0.2$, $K4 = 0.026$, and $K0 = 213$</p>
2L129	<p>JOR Gen and VIT VAR RMR Requirements are the same as Table 1.1.1-System Normal for the contingency Limit:</p> <ul style="list-style-type: none"> • $2L123 \text{ DMR} + 0.53 * 2L129 \text{ ARN} \leq 2L123_0.5\text{hr_Rating}$ • $2L128 \text{ DMR} + 0.53 * 2L129 \text{ ARN} \leq 2L128_0.5\text{hr_Rating}$ <p>If the limit requirement violates, TSA-PM will alarm "2L123 1/2HR RATING VIOLATION: 2L129 CTG" or "2L128 1/2HR RATING VIOLATION: 2L129 CTG", then the BCHCC Operator must reduce the transfer on the 2L129 and 2L128 if 2L129 is OOS, or 2L128 if 2L129 is OOS by:</p> <ul style="list-style-type: none"> • Bringing JOR online if it is available and increasing the output <p>After loss of 2L129 and if TSA-PM alarms "2L123 RATING VIOLATION" or "2L128 RATING VIOLATION", the BCHCC Operator shall take the same actions as described above to reduce the flow on 2L123 or 2L128 from DMR to SAT within its continuous rating in half an hour.</p>
5L29 & 5L31, or 5L30 & 5L32, or 5L42 & 5L45, or DMR T1 & T2	Same VI RMR as Table 1.2.1 for the contingency
5L29 or 5L31	<p>Limit: $2L129 \text{ ARN} + 0.5 * 0.084 * (5L29 + 5L31) \text{ MSA} \leq 2L129_0.5\text{hr_Rating}$</p> <p>If the above condition violates, TSA-PM will alarm "2L129 ARN 1/HOUR RATING VIOLATION: 5L29OR31 CTG", then the BCHCC Operator must reduce the transfer on the 2L129 and 5L29 and 5L31 until the condition is met by:</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas.
5L30 or 5L32	<p>Limit: $2L129 \text{ ARN} + 0.5 * 0.12 * (5L30 + 5L32) \text{ CKY} \leq 2L129_0.5\text{hr_Rating}$</p> <p>If the above condition violates, TSA-PM will alarm "2L129 ARN 1/HOUR RATING VIOLATION: 5L30OR32 CTG", then the BCHCC Operator must reduce the transfer on the 2L129 and 5L30 and 5L32 until the condition is met by:</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas.
2L123 or 2L128	<p>Limit: $2L129 \text{ ARN} + 0.5 * 0.45 * (2L123 + 2L128) \text{ DMR} \leq 2L129_0.5\text{hr_Rating}$</p> <p>If the above condition violates, TSA-PM will alarm "2L129 ARN 1/HOUR RATING VIOLATION: 2L123OR128 CTG", then the BCHCC Operator must reduce the transfer on 2L123/2L128 by :</p> <ul style="list-style-type: none"> • Bringing JOR online if it is available and increasing the output, and /or
DMR T1 or T2	<p>Limit: $2L129 \text{ ARN} + 0.5 * 0.17 * (\text{DMR T1} + \text{T2}) \text{ MW} \leq 2L129_0.5\text{hr_Rating}$</p> <p>If the above condition violates, TSA-PM will alarm "2L129 ARN 1/HOUR RATING VIOLATION: DMR T1ORT2 CTG", then the BCHCC Operator must reduce the transfer on the 2L129 and DMR transformers until the condition is met by :</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas.
5L42	<p>Limit: $2L129 \text{ ARN} + 0.13 * 5L42 \text{ KLY} \leq 2L129_0.5\text{hr_Rating}$</p> <p>If the above condition violates, TSA-PM will alarm "2L129 ARN 1/HOUR RATING VIOLATION: 5L42 CTG", then the BCHCC Operator must reduce the transfer on the 2L129 and/or 5L42 until the condition is met by :</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas.
5L44	Same as Table 1.2.1

End of Table 1.2.6

Table 1.2.7 Pre-Outage Restrictions – (any segment of 1L115 or any segment of 1L116) OOS without VIT PST

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
Without any contingency	<p>Limit: $2L129\ ARN \leq 609\ MW$</p> <p>If TSA-PM alarms “2L129 ARN CONTINUOUS RATING VIOLATION”, the BCHCC Operator must reduce the transfer below the limit by:</p> <ul style="list-style-type: none"> • Adjusting the tap of the VIT phase shifter transformer, and /or • Bringing JOR online if it is available and increasing the output, and/or • Bringing more generation online in North and Central VI areas.
2L129	<p>JOR Gen and VIT VAR RMR Requirements are the same as Table 1.1.1 – System Normal for the contingency</p> <p>Note: 1L116 (or 1L115) may be tripped(open-ended at LTZ; open LTZ 1CB3 if 1L115 was OOS, open LTZ 1CB1 if 1L116 was OOS) by overload protection upon loss of 2L129 when VI load is above 2000MW</p> <p>Possibility of overload:</p> <p>If 1L116 DMR (post-contingency) = $1L116\ DMR + 0.14 * 2L129\ ARN > 1L116_Rating$ If 1L115 DMR (post-contingency) = $1L115\ DMR + 0.14 * 2L129\ ARN > 1L115_Rating$</p>
5L29 with 5L31 OOS, or 5L31 with 5L29 OOS, or 5L30 & 5L32, or 5L42 & 5L45, or DMR T1 & T2	Same VI RMR as Table 1.2.1 for the contingency.
5L29, or 5L31	<p>Limit: $2L129\ ARN + 0.5 * 0.086 * (5L29+5L31)\ MSA \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 5L29OR31 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and 5L29 and 5L31 until the condition is met by :</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas. • Monitor the loading of the parallel 500 kV line
5L30, or 5L32	<p>Limit: $2L129\ ARN + 0.5 * 0.12 * (5L30+5L32)\ CKY \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 5L30OR32 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and 5L30 and 5L32 until the condition is met by :</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas.
2L123 or 2L128	<p>Note that 1L115 (or 1L116) may be tripped (open-ended at LTZ; open LTZ 1CB3 if 1L115 was OOS, open LTZ 1CB1 if 1L116 was OOS) by overload protection upon loss of 2L123 or 2L128. 1L115 LTZ designated the MW flow for PVL-LTZ section of 1L115 measured at LTZ. It is a signed quantity; negative implied going into LTZ. Same for 1L116 LTZ.</p> <ul style="list-style-type: none"> • If 1L115 DMR (or 1L116 DMR if 1L115 was OOS) + $0.21 * 0.5 * (2L123 + 2L128)\ DMR > 1L115_Rating$ Then limit: $2L129\ ARN + 0.40 * 0.5 * (2L123 + 2L128)\ DMR +$ $0.28 * 0.21 * 0.5 * (2L123 + 2L128)\ DMR -$ $0.28 * 1L115\ LTZ\ (or\ 1L116\ LTZ\ if\ 1L115\ was\ OOS) \leq 2L129_0.5hr_Rating$ Else limit: $2L129\ ARN + 0.40 * 0.5 * (2L123 + 2L128)\ DMR \leq 2L129_0.5hr_Rating$ <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 2L123OR128 CTG ”, then the BCHCC Operator must reduce the transfer on the 2L123/2L128 and 1L115 (or 1L116) by :</p> <ul style="list-style-type: none"> • Bringing JOR online if it is available and increasing the output.
DMR T2 or T1	<p>Limit: $2L129\ ARN + 0.5 * 0.17 * (DMR\ T1 + T2)\ MW \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: DMR T1ORT2 CTG”, then the BCHCC Operator must reduce the transfer on the 2L129 and DMR transformers until the condition is met by :</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas.
5L45	No restriction.
5L42	<p>Limit: $2L129\ ARN + 0.13 * 5L42\ KLY \leq 2L129_0.5hr_Rating$</p> <p>If the above condition violates, TSA-PM will alarm “2L129 ARN 1/2HOUR RATING VIOLATION: 5L42 CTG ”, then the BCHCC Operator must reduce the transfer on the 2L129 and/or 5L42 until the condition is met by :</p> <ul style="list-style-type: none"> • Bring JOR online if it is available and increase the output, and/or • Bring more generation online in North and Central VI areas.
5L44	Same as Table 1.2.1
HWW T1 or T2	<p>Note: 1L115 (or 1L116) may be tripped (open-ended at LTZ; open LTZ 1CB3 if 1L115 was OOS, open LTZ 1CB1 if 1L116 was OOS) by overload protection upon loss of HWW T1 (or HWW T2) when VI load is above 2000MW</p> <p>Possibility of overload</p> <p>If 1L115 DMR (post-contingency) = $1L115\ DMR + 0.19 * HWW\ T1\ (or\ HWW\ T2) > 1L115_Rating$ If 1L116 DMR (post-contingency) = $1L116\ DMR + 0.19 * HWW\ T1\ (or\ HWW\ T2) > 1L116_Rating$</p>

Table 1.2.8 Pre-Outage Restrictions – DMR SVC and VAR Master OOS without VIT PST

The same as Table 1.1.8

Table 1.2.9 Pre-Outage Restrictions – 2L126 (or 2L170, or one GTP Capacitor) OOS without VIT PST

The same as Table 1.1.9

Table 1.2.10 Pre-Outage Restrictions – one of (2L142, 2L143, 2L145, 2L146 or 5L42) OOS without VIT PST

The same as Table 1.1.10

Table 1.2.11 Pre-Outage Restrictions –one of any capacitor at (PVO, ESQ, CLD, HSY, SNY) OOS^[Note] without VIT PST

The RMR requirements and the Note are the same as Table 1.1.11

Table 1.2.12 Pre-Outage Restrictions – one of (5L44, 5L45, 2L144, 1L12, DMR T4 or T5) OOS without VIT PST

The same as Table 1.1.12

Table 1.2.13 Pre-Outage Restrictions – one of (1L10, 1L11 or 1L14) OOS without VIT PST

The same as Table 1.1.13

Table 1.2.14 Pre-Outage Restrictions– 2L129 OOS without VIT PST

CONTINGENCY	PRE-OUTAGE RESTRICTIONS
Without any contingency	JOR Gen and VIT VAR RMR Requirements are the same Table 1.1.5 - 2L123 or 2L128 OOS
5L29 or 5L31	<p>Limit</p> <ul style="list-style-type: none"> • $(5L29+5L31) \text{ MSA} \leq 1450 \text{ MW}$ <p>If TSA-PM alarms “5L29 (5L31) Emergency Rating VIOLATION”, the BCHCC Operator must reduce the transfer below the limit by Increasing VI generation.</p>
1L115 (or 1L116)	<p>Note: 1L116 (or 1L115) may be tripped (open-ended at LTZ) by overload protection upon loss of 1L115 (or 1L116) when VI load is above 2000MW</p> <p>Possibility of overload:</p> <ul style="list-style-type: none"> If 1L116 DMR (post-contingency) = 1L116 DMR + 0.39 * 1L115 DMR > 1L116_Rating If 1L115 DMR (post-contingency) = 1L115 DMR + 0.39 * 1L116 DMR > 1L115_Rating

End of Table 1.2.14

ATTACHMENT 2 - Load Shedding and Generation Shedding Requirements - with or without 2L129 in Service

Notes for all the tables in Attachment 2:

Definitions:

$$\begin{aligned} AA &= (5L29 + 5L31) MSA + 2L129 ARN - 1150 \text{ MW} \\ BB &= (5L29 + 5L31) MSA + 2L129 ARN - 600 \text{ MW} \\ \text{If } AA < 0, \text{ then } AA = 0 \end{aligned}$$

Note 1: AA is for determining transfer exceedance for calculating generation shedding requirement to prevent transient voltage dip at the VIT bus.

Note 2: BB is for determining transfer exceedance for calculating load shedding requirement to prevent thermal overload on 2L129.

Note 3: "Loss of Northern Path of LM – VI" means the contingencies

- 5L29 and 5L31, or 5L29 with 5L31 OOS, or 5L31 with 5L29 OOS,
OR
 - 5L30 and 5L32, or 5L30 with 5L32 OOS, or 5L32 with 5L30 OOS,
OR
 - 5L42 and 5L45, or 5L42 with 5L45 OOS, or 5L45 with 5L42 OOS,
OR
- DMR T1 and T2, or DMR T1 with DMR T2 OOS, or DMR T2 with DMR T1 OOS.

Table 2.1 Load Shedding Requirements for the 500 kV Contingencies Associated with VI Supply – with 2L129

Notes for all the contingencies in this Table 2.1:

Note 1: Up to 5 smaller blocks of loads should be shed iteratively, starting at 2 seconds after contingency, with appropriate time delay of 10 seconds, with each load block of about 150 MW (120MW~180MW) and the remaining load for the last block. All shedable load blocks shall be armed.

Note 2: Load shedding is supervised by the 2L129 current measured at VIT, the RAS will not initiate load shedding unless the line current exceeds 1672 A for summer season and 1810 A for winter season, and the RAS will continue shedding load until the current drops below 1506 A.

Note 3: Do not shed all loads in one zone, the following rule could be used as reference: 40%~70% of total load shed is at SVI, 10%~40% at each of CVI and NVI.

Note 4: If the available load shedding is not enough, an alarm shall sound.

Note 5: Tripping of 2L129 by its overload protection is used as a backup for VI RAS.

Note 6: Each of the contingencies in the following table will send a signal to VIT to block the PST tap changer until manually reset by BCHCC Operator.

Note 7: The required iterative load shedding amount (BB – AA) is used for under load shed checking only.

CONTINGENCY	Fast Load shedding amount (MW) (within 15 Cycles)	Iterative Load shedding amount with time delay (MW)	Locations of Load Shedding
Loss of northern path of LM -VI	2L129 in Service: AA 2L129 OOS: Existing VI U/F and U/V load shedding schemes and initiate TECMP if VI load is greater than 1861 MW.	2L129 in Service: BB – AA 2L129 OOS: Existing VI U/F and U/V load shedding schemes and initiate TECMP if VI load is greater than 1861 MW.	2L129 in Service: All existing loads listed in Table 3.2 of Attachment 3 2L129 OOS: Existing VI U/F and U/V load shedding schemes.

Table 2.2 Load Shedding Requirements for Loss of Two of 2L123, 2L128 and 2L129

Notes for all the system conditions in Table 2.2:

Note 1: If load shedding is triggered, up to 3 or 4 smaller blocks of loads should be shed iteratively, starting at 1 second, with appropriate time delay 10 seconds, each consisting of almost 150 MW load (120MW~180MW) and the remaining load for the last block. All shedable load blocks shall be armed.

Note 2: Load shedding for loss of 2L123 and 2L128 is supervised by the 2L129 current measured at VIT, the RAS will not initiate load shedding unless the line current exceeds 1672 A for summer season and 1810 A for winter season, and the RAS will continue shedding load until the current drops below 1506 A.

Note 3: Load shedding for loss of 2L128 and 2L129 is supervised by the 2L123 current measured at DMR. During summer season, the RAS will not initiate load shedding unless the line current exceed 1637 A, and the RAS will continue shedding load until the current drops below 1555 A. During winter season, the RAS will not initiate load shedding unless the line current exceed 2034 A, and the RAS will continue shedding load until the current drops below 1932 A.

Note 4: Load shedding for loss of 2L123 and 2L129 is supervised by the 2L128 current measured at DMR. During summer season, the RAS will not initiate load shedding unless the line current exceed 2012 A, and the RAS will continue shedding load until the current drops below 1858 A. During winter season, the RAS will not initiate load shedding unless the line current exceed 2369 A, and the RAS will continue shedding load until the current drops below 2249 A.

Note 5: If the available load shedding is not enough, an alarm shall sound.

Note 6: Tripping of 2L129 by its overload protection is used as a backup for load shedding for loss of 2L123 and 2L128.

Note 7: Loss of both 2L123 and 2L128 including the single contingency with the parallel line O.O.S. will send a signal to block the PST tap changer until the OL signal disappears.

Note 8: The required iterative load shedding amount is used for under load shed checking only.

System Condition	Fast Load shedding amount (MW) (within 15 Cycles)	Iterative Load shedding amount with time delay (MW) (Note 8)	Locations of Load Shedding
System normal, or 5L29 OOS, or 5L31 OOS, or 5L30 OOS, or 5L32 OOS, or DMR T1 OOS, or DMR T2 OOS	None	LS for loss of 2L123 and 2L128 = $1.05 * 1.42 * [(2L129 ARN - 550) + 0.7 * (2L123+2L128) DMR]$	Loads in CVI and SVI listed in Table 3.2 of Attachment 3 excludes QLC, PVL, LTZ.

2L123 OOS	None	<p>LS for loss of 2L128 = $1.05 * 1.42 * [(2L129 \text{ ARN} - 550) + 0.7 * 2L128 \text{ DMR}]$</p> <p>If $1L115 \text{ DMR} + 0.17 * 2L129 \text{ ARN} > 1L115 \text{ Rating}$ OR $1L116 \text{ DMR} + 0.17 * 2L129 \text{ ARN} > 1L116 \text{ Rating}$, then, $\text{LS for loss of } 2L129 = 2L128 \text{ DMR} + 1.07 * [2L129 \text{ ARN} - (1L115 + 1L116) \text{ JPT}] - 2L128 \text{ _0.5hr_Rating}$</p> <p>Else, $\text{LS for loss of } 2L129 = 2L128 \text{ DMR} + 0.78 * 2L129 \text{ ARN} - 2L128 \text{ _0.5hr_Rating}$</p>	Loads in CVI and SVI listed in Table 3.2 of Attachment 3 excludes QLC, PVL, LTZ.
2L128 OOS	None	<p>LS for loss of 2L123 = $1.05 * 1.42 * [(2L129 \text{ ARN} - 550) + 0.7 * 2L123 \text{ DMR}]$</p> <p>If $1L115 \text{ DMR} + 0.17 * 2L129 \text{ ARN} > 1L115 \text{ Rating}$ OR $1L116 \text{ DMR} + 0.17 * 2L129 \text{ ARN} > 1L116 \text{ Rating}$, then, $\text{LS for loss of } 2L129 = 2L123 \text{ DMR} + 1.07 * [2L129 \text{ ARN} - (1L115 + 1L116) \text{ JPT}] - 2L123 \text{ _0.5hr_Rating}$</p> <p>Else, $\text{LS for loss of } 2L129 = 2L123 \text{ DMR} + 0.78 * 2L129 \text{ ARN} - 2L123 \text{ _0.5hr_Rating}$</p>	Loads in CVI and SVI listed in Table 3.2 of Attachment 3 excludes QLC, PVL, LTZ.
2L129 OOS	None	<p>If $1L115 \text{ DMR} + 0.19 * 0.5 * (2L123+2L128) \text{ DMR} > 1L115 \text{ Rating}$ OR $1L116 \text{ DMR} + 0.19 * 0.5 * (2L123+2L128) \text{ DMR} > 1L116 \text{ Rating}$, then, $\text{LS for loss of } 2L128 = 2L123 \text{ DMR} + 1.04 * [2L128 \text{ DMR} - (1L115 + 1L116) \text{ JPT}] - 2L123 \text{ _0.5hr_Rating}$ $\text{LS for loss of } 2L123 = 2L128 \text{ DMR} + 1.04 * [2L123 \text{ DMR} - (1L115 + 1L116) \text{ JPT}] - 2L128 \text{ _0.5hr_Rating}$</p> <p>Else, $\text{LS for loss of } 2L128 = 2L123 \text{ DMR} + 0.73 * 2L128 \text{ DMR} - 2L123 \text{ _0.5hr_Rating}$ $\text{LS for loss of } 2L123 = 2L128 \text{ DMR} + 0.73 * 2L123 \text{ DMR} - 2L128 \text{ _0.5hr_Rating}$</p>	Loads in CVI and SVI listed in Table 3.2 of Attachment 3 excludes QLC, PVL, LTZ.
Both Sections between JPT and LTZ on 1L115 and 1L116 OOS	None	LS for loss of 2L123 and 2L128 = $(2L123 + 2L128) \text{ DMR} + 2L129 \text{ ARN} - 600$	Loads in CVI and SVI listed in Table 3.2 of Attachment 3 excludes QLC, PVL, LTZ.

End of Table 2.2

Table 2.3 Generation Shedding Requirements – with or without 2L129

In Table 2.3 formulas, 2000 MW refers to historical limitations that BPA accepts for impacts of transfer swings on their system. 3150 MW refers to the WECC Path 3 rating (normal maximum for path operation).

CONTINGENCY	GENERATION SHEDDING REQUIREMENTS
Loss of Northern Path of LM - VI	<p>All system conditions except for 5L51 O.O.S., or 5L52 O.O.S.</p> <p>Shed at MCA/REV/GMS/PCN the greater of:</p> <ul style="list-style-type: none"> • Y if $(BC \text{ to US}) + Y > 2000 \text{ MW}$, or • $(BC \text{ to US}) + Z - 3150 \text{ MW}$ <p>5L51 O.O.S.</p> <p>Shed at MCA/REV/GMS/PCN the greater of:</p> <ul style="list-style-type: none"> • Y if $(BC \text{ to US}) + Y > 2000 \text{ MW}$, or • $(BC \text{ to US}) + Z - 5L52_{30Minute_MW_Rating_EX}$ <p>5L52 O.O.S.</p> <p>Shed at MCA/REV/GMS/PCN the greater of:</p> <ul style="list-style-type: none"> • Y if $(BC \text{ to US}) + Y > 2000 \text{ MW}$, or • $(BC \text{ to US}) + Z - 5L51_{30Minute_MW_Rating_EX}$ <p>Where:</p> <p>Y = AA if 2L129 is in service, or Y = $(5L29 + 5L31) \text{ MSA}$ if 2L129 is OOS Z = BB if 2L129 is in service, or Z = $(5L29 + 5L31) \text{ MSA}$ if 2L129 is OOS</p> <p>If generation shedding is required, a minimum of the following generator units shall remain on-line post-shedding:</p> <ul style="list-style-type: none"> • 2 MCA Units, AND • 2 REV units, AND • At GMS/PCN: <ul style="list-style-type: none"> • 4 equivalent GMS units. Two PCN units can be treated as one equivalent GMS unit. (Same as the requirement in Section 5.3.5 in SOO 7T-13) <p>Please refer to SOO 7T-18 Attachment 1 for 5L51_{30Minute_MW_Rating_EX} and 5L52_{30Minute_MW_Rating_EX} respectively.</p>

End of Table 2.3

ATTACHMENT 3 – Line Ratings and RAS Load Shedding Candidates

Table 3.1 Half Hour Emergency Rating of 2L129

Ambient Temperature at Ingledow (°C)	Half Hour Emergency Rating (A)	Half Hour Emergency Rating (MW) (calculated by: 1.732 * Rating in KA * 236 kV * 0.99 pf)
-20	1921	777.4
-10	1885	762.8
0	1848	747.8
10	1810	732.4
20	1754	709.8
30	1672	676.6
40	1669	675.4

Table 3.2 The VI RAS Load Shedding Candidates^{Note1}

Substation Load Blocks <small>Note 5</small>	Load Shed Actions ^{Note 4}	MW Load (Summer)	MW Load (Winter)	Area
CFT-A	CFT 6 Grinders (Trip CBS)	80	80	CVI
KTG-A	25 kV feeders: KTG 25CB111-115, 121-123)	29.5	75.4	SVI
ESQ-A	12 kV feeders: ESQ 12CB7, 10, 21, 40, 51-58, 72	38.9	79.0	SVI
GOW-A&C	25 kV feeders (50 series): GOW 25CB1, 2, 10	48.2	82.1	SVI
KTG-B	Shed KTG 60 kV (SNY Load): KTG 60CB1, 2, 3, 4	25.7	71.4	SVI
GTP-A	25 kV feeders (40 series): GTP 25CB11, 13	20.7	56.5	SVI
GTP-B	25 kV feeders (50, 60 series): GTP 25CB12, 14, 21, 22	46	79.1	SVI
HSY-A	12 kV feeders (60, 300, 400 series & 12kV Capacitors): HSY 12CB4, 32, 31, 38, 33, 36	46.1	80.6	SVI
HSY-B&C	12 and 25 kV feeders (50,70,80, 100, 200 series): HSY 12CB4, 37, 34, 35, 25CB1, 2, 10	70.4	133.4	SVI
PAL-B	25 kV feeders (all): PAL 25CB11, 12	40.8	59.9	CVI
PVO-B	PVO capacitors: PVO 1CB25, 26, 27	-	-	CVI
PVO-A	25 kV feeders except 25F51 (hospital) and including LCW Station: PVO 25CB52-57, 60CB3	42.5	61.6	CVI
NFD	All feeders except 25F54 (hospital): NFD 25CB50-53, 55-56, 60-66	58.9	94.6	CVI
CLD	25 kV feeders: CLD 25CB51-58, 61-63, 71-78, 81-83, 23, 24	77.3	138.0	SVI
SNY ^{Note2}	25 kV Feeders excluding SNY 25F54 & 65 (BC Ferries, airport): SNY 25CB22, 53, 55, 62-64, 66	22.5	62.5	SVI
KSH	25 kV Feeders: KSH 25CB2, 3	35.4	58.3	CVI
SHA	25 kV Feeders : SHA 25CB1, 2	23.9	48.1	CVI
QLC	25 kV Feeders excluding QLC 25F52 (medical clinic): QLC 25CB51, 53, 61, 62	21.2	42.6	CVI
LTZ	25 kV Feeders: LTZ 25CB111-114, 121-124	43.9	66.2	CVI
CMX	25kV Feeders excluding 25F31, 25F32 and 25F36: CMX 25CB33, 34, 35, 37, 51, 52	42.5	80.1	NVI
LDY	25 kV Feeders excluding LDY25F53 & 65 (medical clinic, BC Ferries): LDY 25CB51, 52, 55, 63, 64	29.3	52.4	CVI
HWD	25 kV Feeders excluding HWD 25F51 (Duke Point Ferry), HWD 25F38 (health clinic on Gabriola Island), and HWD 25F36 (Nanaimo Airport): HWD 25CB31-35, 37, 52	32.6	54.5	CVI
	Total Eligible Load ^{Note3}	853.8	1493.8	

Note 1: Based on 2021 Vancouver Island Load Forecast F22 Winter/Summer Ref Values Uncompensated Station Peak with DSM.

Note 2: SNY Block pro-rated as 7/8 of station forecast load.

Note 3: Total Eligible Load excludes SNY as it is previously counted under KTG-B block


Note 4: Refer to 2T-34 Appendix 2 "RAS General Description" Section 5.14 "Action Outputs" table for source information.

Note 5: station blocks ordered as displayed in EMS 7T-41 VI Load Shed RAS display.

Figure 3.3 EMS RAS Display

The figure below is an example of the layout for the 7T-41 Load Shed RAS display. This is for information only. The display capture does not prescribe settings and should not be used for operating purposes.

Note: PAL-MA load block is not used (load removed).



ATTACHMENT 4 – Vancouver Load Supply Capability

Attachment 4 is a high level reference for load supply capability. The tables here can be viewed as a simplified version of Attachment 5. It contains fewer study scenarios, and does not consider load ratios (i.e. load distribution on the Island). See Section 3.7 of the main body for applicability and use of this attachment.


Notes for all the charts in Attachment 4:

- Definitions
 - “VI load” = VI AC transfers + VI generation
 - “VI Load” captures the AC source injection dependencies that impact VAR support.
 - “C&SVI Load” = 2L129 ARN + (2L123 + 2L128) DMR – (1L115 + 1L116) JPT + JOR MW
 - “C&SVI Load” captures the AC source Injection dependencies that impact VAR support
 - Load Ratio = (C&SVI Load)/(VI load)
 - “VIT VAR” = total VIT VAR supporting capability available or on-line, includes
 - VIT Synchronous Condensers, total 250 MVAR, including SC2 50 MVAR, SC3 100 MVAR, SC4 100 MVAR
 - VIT HF2 total 94.7 MVAR, including 5HF2/7HF2/11HF2/13HF2 with 21.6/12.0/15.4/11.1 MVAR and HP2 34.6 MVAR
 - The maximum VIT Var supporting capability is 344.7 MVAR
- The priority sequence to serve Vancouver Island load are assumed as follows:
 - Central & North VI generation (C&N VI Gen)
 - Jordan generation
- If 2L129 contingency results in 1L115 & 1L116 tripped open at JPT by its O/L protection, and in turn O/L VIT T5 & T6, the BCHCC Operator may need to manually shed some load in Central and South VI area.
- For all the tables in Attachment 4, the half-hour emergency rating of 231 MVA at 0°C ambient temperature is used for VIT T5 or T6.
- For all the tables in Attachment 4, the continuous rating of 185 MVA at 0°C ambient temperature is used for 1L115 or 1L116.
- The charts below were developed solely from voltage stability perspective. The applied contingency is 2L129, which is the most impacting contingency. It is applicable to both scenarios of VIT PST in or out of service.
- In the tables, the result are calculated from the BenchMark case, where “Load Ratio” = 66.5%. Therefore, a modification factor f is used for different “Load Ratio”. Where

$$f = 0.665 / (\text{Load Ratio}),$$


That means if the “Load Ratio” > 0.665, then the VI load supply capability will be reduced.

A4.1 System Normal, or one of (1L12, 2L144, 5L44, 5L45, DMR T4 or T5, VIT T5 or T9) OOS




Note: The highlighted numbers in the table are used in Attachment 1.


A4.2 2L123 or 2L128 OOS




A4.3 DMR SVC and VARMaster OOS (With 6 5RXs on line)




A4.4 One of (5L29, 5L31, DMR T1, DMR T2) OOS



A4.5 One of (2L126, 2L170, GTP Capacitor) OOS



A4.6 One of (1L10,1L11,1L14,2L142,2L143,2L145,2L146,5L30,5L32,5L42) OOS or
one of (PVO, ESQ, CLD, HSY, SNY) Capacitor OOS



Note: See [Note 1] in Attachment 1.1 Table 1.1.11 for “one of any cap of (PVO, ESQ, CLD, HSY, SNY)” designations

ATTACHMENT 5 – Vancouver Island Load Supply Capability (Alternate)


This attachment can be used as reference for VI load supply. See Section 3.7 for applicability.

This attachment has been developed for implementation with an Artificial Intelligence model (Artificial Neural Network algorithm). The Attachment contains the full VI load supply capability results, which cover more scenarios than in Attachment 4. Attachment 5 can be considered as a more comprehensive version of Attachment 4.


Notes for all the charts in Attachment 5:

- Definitions
 - “VI load” = VI AC transfers + VI generation
 - “VI Load” captures the AC source injection dependencies that impact VAR support.
 - “C&SVI Load” = 2L129 ARN + (2L123 + 2L128) DMR – (1L115 + 1L116) JPT + JOR MW
 - “C&SVI Load” captures the AC source Injection dependencies that impact VAR support.
 - Load Ratio = (C&SVI Load)/(VI load)
 - “VIT VAR” = total VIT VAR supporting capability available or on-line, includes
 - VIT Synchronous Condensers, total 250 MVAR, including SC2 50 MVAR, SC3 100 MVAR, SC4 100 MVAR
 - VIT HF2 total 94.7 MVAR: including 5HF2/7HF2/11HF2/13HF2 with 21.6/12.0/15.4/11.1 MVAR and HP2 34.6 MVAR
 - The maximum VIT Var supporting capability is 344.7 MVAR
- The priority sequence to serve Vancouver Island load are assumed as follows:
 - Central & North VI generation (C&N VI Gen)
 - Jordan generation
- If 2L129 contingency results in 1L115 & 1L116 tripped open at JPT by its O/L protection, and in turn O/L VIT T5 & T6, the BCHCC Operator may need to manually shed some load in Central and South VI area.
- For all the tables in Attachment 5, the half-hour emergency rating of 231 MVA at 0°C ambient temperature is used for VIT T5 or T6.
- For all the tables in Attachment 5, the continuous rating of 185 MVA at 0°C ambient temperature is used for 1L115 or 1L116.
- The charts below were developed solely from voltage stability perspective. The applied contingency is 2L129, which is the most impacting contingency.


A5.1 System Normal




A5.2 1L10 OOS




A5.3 1L11 OOS




OOS:	1L11						
Load Ratio:	55.0%						
VIT VAR	Jordan Gen						
195	2238	2253	2266	2278	2285	2289	2293
245	2251	2264	2276	2287	2293	2297	2301
295	2263	2274	2282	2292	2298	2303	2307
345	2272	2280	2289	2299	2305	2309	2313




Load Ratio:	60.0%						
VIT VAR	Jordan Gen						
195	2192	2226	2255	2274	2282	2285	2287
245	2221	2245	2270	2287	2294	2297	2298
295	2234	2258	2281	2297	2303	2305	2307
345	2251	2273	2290	2303	2308	2311	2313



Load Ratio:	65.0%						
VIT VAR	Jordan Gen						
195	2044	2104	2172	2217	2233	2240	2243
245	2091	2151	2212	2252	2265	2270	2271
295	2132	2191	2235	2266	2278	2283	2286
345	2174	2211	2253	2281	2292	2297	2300




Load Ratio:	66.6%						
VIT VAR	Jordan Gen						
195	1998	2059	2126	2171	2187	2193	2196
245	2045	2105	2171	2216	2232	2238	2241
295	2088	2147	2206	2246	2261	2267	2270
345	2129	2187	2230	2263	2277	2284	2289




Load Ratio:	70.0%						
VIT VAR	Jordan Gen						
195	1905	1963	2026	2068	2083	2088	2091
245	1950	2007	2071	2113	2128	2134	2136
295	1990	2047	2112	2155	2169	2175	2177
345	2030	2087	2152	2194	2209	2214	2216


A5.4 1L12 OOS




OOS:	1L12						
Load Ratio:	55.0%						
VIT VAR	off	0	50	100	130	150	170
195	2245	2255	2266	2277	2283	2286	2290
245	2256	2268	2276	2285	2291	2295	2299
295	2269	2275	2282	2291	2296	2300	2304
345	2275	2281	2289	2298	2303	2307	2311




Load Ratio:	60.0%						
VIT VAR	off	0	50	100	130	150	170
195	2216	2233	2256	2273	2279	2283	2285
245	2236	2252	2271	2285	2291	2294	2297
295	2249	2267	2282	2294	2300	2303	2306
345	2264	2281	2291	2301	2306	2309	2312



Load Ratio:	65.0%						
VIT VAR	off	0	50	100	130	150	170
195	2085	2138	2184	2221	2238	2247	2255
245	2132	2186	2222	2250	2263	2270	2275
295	2175	2210	2242	2267	2278	2284	2289
345	2205	2231	2260	2283	2292	2297	2301




Load Ratio:	66.6%						
VIT VAR	off	0	50	100	130	150	170
195	2039	2094	2139	2175	2192	2201	2208
245	2088	2142	2187	2223	2241	2250	2258
295	2130	2185	2220	2249	2263	2271	2278
345	2173	2209	2241	2267	2280	2288	2295




Load Ratio:	70.0%						
VIT VAR	off	0	50	100	130	150	170
195	1944	1998	2043	2078	2094	2103	2109
245	1990	2045	2089	2124	2140	2149	2156
295	2032	2087	2131	2166	2183	2193	2202
345	2075	2128	2175	2211	2228	2237	2244


A5.5 1L14 OOS




A5.6 2L123 or 2L128 OOS




A5.7 2L126 or 2L170 OOS




A5.8 2L142 OOS




A5.9 2L143 OOS




OOS:	2L143					
Load Ratio:	55.0%					
VIT VAR	Jordan Gen					
195	off	0	50	100	130	150
245	2251	2264	2274	2284	2290	2298
295	2263	2272	2281	2291	2297	2304
345	2272	2279	2288	2297	2303	2307
	170					
	2290					




Load Ratio:	60.0%					
VIT VAR	Jordan Gen					
195	off	0	50	100	130	150
245	2225	2245	2268	2285	2292	2295
295	2239	2263	2281	2294	2301	2304
345	2256	2275	2290	2302	2307	2310
	170					
	2312					



Load Ratio:	65.0%					
VIT VAR	Jordan Gen					
195	off	0	50	100	130	150
245	2117	2164	2215	2250	2263	2269
295	2150	2199	2238	2267	2278	2284
345	2194	2218	2256	2283	2293	2298
	170					
	2248					




Load Ratio:	66.6%					
VIT VAR	Jordan Gen					
195	off	0	50	100	130	150
245	2062	2117	2178	2220	2236	2244
295	2106	2162	2213	2249	2264	2270
345	2149	2198	2236	2266	2279	2287
	170					
	2274					




Load Ratio:	70.0%					
VIT VAR	Jordan Gen					
195	off	0	50	100	130	150
245	1966	2020	2079	2119	2134	2140
295	2008	2062	2122	2162	2177	2183
345	2051	2104	2163	2204	2219	2225
	170					
	2228					


A5.10 2L144 OOS




A5.11 2L145 OOS




A5.12 2L146 OOS




A5.13 5L29 or 5L31 OOS




A5.14 5L30 or 5L32 OOS




A5.15 5L42 OOS




OOS:	5L42						
Load Ratio:	55.0%						
VIT VAR	Jordan Gen						
195	2169	2175	2185	2196	2202	2207	2211
245	2179	2184	2193	2203	2209	2213	2217
295	2181	2187	2196	2205	2211	2215	2220
345	2189	2190	2199	2209	2215	2219	2223




Load Ratio:	60.0%						
VIT VAR	Jordan Gen						
195	2150	2162	2181	2196	2203	2206	2209
245	2161	2172	2189	2203	2209	2213	2216
295	2166	2176	2193	2206	2212	2215	2218
345	2174	2181	2196	2209	2215	2219	2222



Load Ratio:	65.0%						
VIT VAR	Jordan Gen						
195	2087	2116	2149	2175	2187	2194	2200
245	2116	2134	2164	2188	2199	2204	2209
295	2126	2144	2172	2194	2205	2211	2216
345	2140	2159	2182	2201	2210	2216	2220




Load Ratio:	66.6%						
VIT VAR	Jordan Gen						
195	2040	2099	2131	2159	2174	2183	2192
245	2090	2119	2150	2176	2189	2197	2204
295	2111	2130	2161	2186	2199	2206	2213
345	2126	2144	2172	2195	2207	2213	2219




Load Ratio:	70.0%						
VIT VAR	Jordan Gen						
195	1944	1999	2057	2097	2112	2118	2122
245	1991	2046	2102	2141	2156	2163	2167
295	2033	2088	2127	2157	2171	2178	2184
345	2077	2109	2143	2170	2184	2192	2198


A5.16 5L44 OOS




A5.17 5L45 OOS




OOS:	5L45						
Load Ratio:	55.0%						
VIT VAR	Jordan Gen						
195	2229	2232	2253	2268	2275	2279	2282
245	2233	2239	2260	2276	2283	2287	2291
295	2239	2243	2265	2281	2289	2293	2296
345	2241	2250	2271	2287	2295	2299	2302




Load Ratio:	60.0%						
VIT VAR	Jordan Gen						
195	2182	2196	2234	2261	2273	2279	2283
245	2197	2210	2248	2274	2285	2290	2293
295	2204	2218	2255	2281	2291	2296	2298
345	2219	2231	2265	2288	2297	2301	2303



Load Ratio:	65.0%						
VIT VAR	Jordan Gen						
195	2086	2139	2178	2212	2230	2241	2252
245	2133	2162	2198	2231	2249	2261	2272
295	2150	2173	2210	2243	2260	2271	2281
345	2168	2189	2225	2257	2274	2285	2296




Load Ratio:	66.6%						
VIT VAR	Jordan Gen						
195	2039	2098	2153	2193	2211	2220	2227
245	2089	2139	2179	2214	2232	2243	2253
295	2130	2154	2194	2227	2245	2255	2264
345	2149	2174	2211	2244	2261	2272	2281




Load Ratio:	70.0%						
VIT VAR	Jordan Gen						
195	1944	1999	2057	2097	2112	2118	2122
245	1991	2045	2104	2144	2160	2166	2169
295	2033	2087	2146	2186	2201	2207	2211
345	2077	2126	2169	2204	2220	2230	2238


A5.18 VIT T5 OOS




OOS:	VIT5					
Load Ratio:	55.0%					
VIT VAR	Jordan Gen					
195	2242	2255	2268	2279	2285	2289
295	2266	2274	2283	2293	2299	2303
0	0	0	0	0	0	0
0	0	0	0	0	0	0




Load Ratio:	60.0%					
VIT VAR	Jordan Gen					
195	2213	2234	2259	2277	2284	2288
295	2246	2267	2284	2297	2303	2307
0	0	0	0	0	0	0
0	0	0	0	0	0	0



Load Ratio:	65.0%					
VIT VAR	Jordan Gen					
195	2079	2135	2194	2235	2251	2259
295	2169	2207	2246	2273	2284	2289
0	0	0	0	0	0	0
0	0	0	0	0	0	0




Load Ratio:	66.6%					
VIT VAR	Jordan Gen					
195	2033	2091	2150	2191	2208	2216
295	2124	2179	2223	2256	2270	2277
0	0	0	0	0	0	0
0	0	0	0	0	0	0




Load Ratio:	70.0%					
VIT VAR	Jordan Gen					
195	1938	1993	2051	2091	2107	2113
295	2026	2080	2139	2180	2195	2201
0	0	0	0	0	0	0
0	0	0	0	0	0	0


A5.19 VIT T9 or T10 OOS




A5.20 DMR T1 or T2 OOS




A5.21 DMR T4 or T7 OOS




A5.22 DMR T5 or T6 OOS




A5.23 HSY CX OOS




A5.24 ESQ CX OOS




A5.25 SNY CX OOS




A5.26 GTP CX OOS




A5.27 CLD CX OOS




A5.28 PVO CX OOS




OOS:	PVOCX						
Load Ratio:	55.0%						
VIT VAR	Jordan Gen						
195	2230	2244	2257	2269	2276	2280	2285
245	2244	2257	2269	2280	2286	2289	2293
295	2256	2268	2278	2287	2293	2297	2301
345	2268	2274	2284	2293	2299	2303	2307




Load Ratio:	60.0%						
VIT VAR	Jordan Gen						
195	2182	2218	2245	2265	2273	2277	2279
245	2213	2235	2261	2279	2286	2289	2291
295	2229	2252	2274	2289	2296	2299	2301
345	2247	2267	2285	2298	2304	2307	2309



Load Ratio:	65.0%						
VIT VAR	Jordan Gen						
195	2033	2091	2150	2192	2209	2217	2221
245	2084	2140	2198	2238	2253	2260	2264
295	2128	2184	2227	2257	2270	2276	2280
345	2174	2209	2247	2274	2286	2291	2294




Load Ratio:	66.6%						
VIT VAR	Jordan Gen						
195	1990	2042	2105	2148	2164	2171	2174
245	2039	2095	2155	2196	2212	2220	2224
295	2084	2139	2197	2237	2253	2260	2264
345	2137	2183	2225	2257	2270	2278	2283




Load Ratio:	70.0%						
VIT VAR	Jordan Gen						
195	1897	1951	2010	2048	2062	2068	2070
245	1944	1998	2057	2096	2111	2116	2119
295	1987	2041	2100	2140	2155	2161	2164
345	2031	2085	2144	2183	2198	2205	2208


A5.29 SVC OOS with DMR 5-5RX on line




OOS:	DMR SVC OOS with 5 RX on						
Load Ratio:	55.0%						
VIT VAR	Jordan Gen						
195	2046	2059	2087	2111	2124	2132	2140
245	2066	2077	2104	2128	2141	2149	2156
295	2080	2093	2118	2140	2152	2160	2167
345	2095	2107	2130	2152	2164	2171	2178




Load Ratio:	60.0%						
VIT VAR	Jordan Gen						
195	1996	2025	2062	2094	2109	2118	2127
245	2028	2055	2088	2117	2132	2141	2150
295	2054	2076	2108	2136	2150	2159	2168
345	2076	2097	2127	2153	2167	2176	2185



Load Ratio:	65.0%						
VIT VAR	Jordan Gen						
195	1920	1952	1999	2037	2055	2065	2074
245	1951	1985	2030	2065	2082	2091	2099
295	1980	2017	2059	2092	2106	2114	2120
345	2011	2044	2084	2115	2129	2137	2143



Load Ratio:	66.6%						
VIT VAR	Jordan Gen						
195	1895	1928	1974	2014	2034	2046	2057
245	1927	1959	2008	2047	2065	2076	2084
295	1955	1987	2038	2076	2092	2101	2107
345	1985	2020	2060	2097	2118	2131	2144



Load Ratio:	70.0%						
VIT VAR	Jordan Gen						
195	1839	1869	1917	1958	1978	1990	2000
245	1866	1900	1948	1988	2009	2021	2032
295	1894	1928	1977	2017	2037	2050	2060
345	1924	1958	2009	2048	2067	2077	2085

A5.30 SVC OOS with 6-5RX online

