

**Integrated Resource Plan**

---

---

**Chapter 6**

**Resource Planning Analysis**

---

---

**Table of Contents**

---

6.1	Introduction .....	6-1
6.2	Natural Gas-Fired Generation.....	6-4
6.2.1	Introduction .....	6-4
6.2.2	Applying the 93 per cent <i>CEA</i> Objective to Resource Planning.....	6-6
6.2.3	Resource Planning with Gas-Fired Generation.....	6-8
6.2.4	Non-Clean Headroom with the 93 per cent Clean Objective.....	6-9
6.2.5	Permitting Gas-Fired Generation .....	6-11
6.2.6	Cost of Gas-Fired Generation Compared to Clean Resources.....	6-12
6.2.6.1	Environmental and Economic Development Considerations.....	6-14
6.2.7	Optimal Use of the 7 per cent Non-Clean Headroom.....	6-14
6.2.7.1	Using Gas as a Transmission Alternative .....	6-14
6.2.7.2	Using Gas as a Capacity and Contingency Resource .....	6-19
6.2.8	Conclusions .....	6-21
6.3	Demand-Side Measures .....	6-22
6.3.1	Introduction .....	6-22
6.3.2	Resource Need: DSM Options and Load Resource Balance.....	6-22
6.3.3	Financial Factors: Cost of DSM Options .....	6-25
6.3.4	Portfolio Analysis .....	6-25
6.3.4.1	Option 2/DSM Target with and without Site C .....	6-26
6.3.4.2	DSM Option 3 .....	6-27
6.3.4.3	DSM Option 1 .....	6-28
6.3.5	Deliverability Risks.....	6-28
6.3.6	Environmental and Economic Development Benefits .....	6-29
6.3.7	Conclusions .....	6-29
6.4	Site C .....	6-29
6.4.1	Introduction .....	6-29
6.4.2	Unit Cost Comparison.....	6-31
6.4.3	Portfolio Analysis using System Optimizer – Base Case .....	6-37
6.4.4	Portfolio Analysis using System Optimizer - Sensitivities.....	6-39
6.4.4.1	Cost of Capital Differential .....	6-39
6.4.4.2	Market Prices.....	6-40
6.4.4.3	Site C Cost of Capital .....	6-41

---

	6.4.4.4	Wind Integration Cost .....	6-42
	6.4.4.5	Large and Small Gaps .....	6-42
6.4.5		Other Technical Benefits.....	6-45
	6.4.5.1	Dispatchability .....	6-45
	6.4.5.2	Wind Integration Limit.....	6-46
6.4.6		Environmental Attributes.....	6-48
6.4.7		Economic Development Attributes .....	6-51
6.4.8		Conclusions .....	6-52
6.5		LNG and the North Coast.....	6-53
	6.5.1	Introduction .....	6-53
	6.5.2	Additional Resource Requirement to Serve LNG and Other Loads .....	6-54
	6.5.3	North Coast Transmission Planning Considerations.....	6-56
	6.5.4	Supply Options.....	6-58
	6.5.5	Evaluation of North Coast Supply Options.....	6-61
	6.5.6	Conclusions .....	6-66
6.6		Fort Nelson Supply and Electrification of the Horn River Basin .....	6-67
	6.6.1	Introduction .....	6-67
	6.6.2	Load Scenarios.....	6-68
	6.6.3	Alternative Supply Strategies.....	6-69
	6.6.4	Fort Nelson/HRB Analysis .....	6-70
	6.6.4.1	Economic Analysis.....	6-71
	6.6.4.2	GHG Emission Production Analysis.....	6-73
	6.6.4.3	CEA 93 per cent Clean or Renewable Energy Objective.....	6-79
	6.6.4.4	Supplying Only Fort Nelson .....	6-80
	6.6.4.5	Risk Analysis .....	6-82
	6.6.5	Conclusions .....	6-84
6.7		General Electrification.....	6-84
	6.7.1	Introduction .....	6-84
	6.7.2	WECC Electrification Scenarios.....	6-86
	6.7.3	Electrification Potential Review.....	6-89
	6.7.4	Analysis to Identify System Requirements.....	6-89
	6.7.5	Conclusions .....	6-91
6.8		Transmission.....	6-92
	6.8.1	Introduction .....	6-92
	6.8.2	Transmission Analysis: Mid Gap.....	6-95
	6.8.3	Transmission Analysis: Mid Gap with Expected LNG .....	6-98
	6.8.4	Transmission Large Gap Analysis .....	6-98

---

	6.8.4.1	Large Gap Scenario.....	6-99
	6.8.4.2	Higher than Expected LNG Load.....	6-100
6.8.5		Generation Cluster Analysis.....	6-101
	6.8.5.1	Cluster Identification.....	6-102
	6.8.5.2	Portfolio Cost Analysis.....	6-104
	6.8.5.3	Simple Cost Analysis for Clusters.....	6-105
	6.8.5.4	Transmission for Clusters.....	6-108
6.8.6		Conclusions.....	6-109
6.9		Capacity and Contingency Analysis.....	6-111
	6.9.1	Introduction.....	6-111
	6.9.2	Capacity Resource Options.....	6-112
	6.9.3	Capacity Planning – Mid Gap.....	6-117
	6.9.3.1	Mid Gap without LNG.....	6-118
	6.9.3.2	Mid Gap with LNG.....	6-120
6.9.4		Contingency Planning.....	6-121
	6.9.4.1	Uncertainties.....	6-122
	6.9.4.2	Load Forecast Uncertainty and DSM Deliverability Risk.....	6-124
	6.9.4.3	Effective Load Carrying Capability of Intermittent Resources.....	6-125
	6.9.4.4	Large Gap.....	6-126
6.9.5		Conclusions.....	6-128

## List of Figures

---

Figure 6-1	Available Headroom for Non-Clean Firm Energy.....	6-10
Figure 6-2	Available Headroom for Non-Clean Capacity (based on 18 per cent and 90 per cent capacity factor).....	6-11
Figure 6-3	Energy Gap after DSM Options 1 to 3 (Mid Gap).....	6-24
Figure 6-4	Capacity Gap after DSM Options 1 to 3 (Mid Gap).....	6-24
Figure 6-5	Modelling Assumptions.....	6-26
Figure 6-6	Base Modelling Assumptions Used for the Site C Portfolio Analysis.....	6-38
Figure 6-7	Energy Load Resource Balance for Large, Mid and Small Gap.....	6-43
Figure 6-8	Capacity Load Resource Balance for Large, Mid and Small Gap.....	6-44

---

Figure 6-9	Modelled Installed Wind Capacity under the Clean Generation, Mid Gap, without LNG Scenario and no Site C .....	6-48
Figure 6-10	System Energy Surplus/Deficit after BRP Implementation under Different LNG Load Scenarios .....	6-55
Figure 6-11	System Capacity Surplus/Deficit after BRP Implementation under Different LNG Load Scenarios .....	6-56
Figure 6-12	North Coast Load Scenarios and the Capability of the Transmission Connection to the Integrated System.....	6-59
Figure 6-13	Fort Nelson Peak Load Scenarios and Existing Supply Capacity.....	6-81
Figure 6-14	Electrification Scenarios.....	6-88
Figure 6-15	Cluster Analysis Nodes.....	6-103
Figure 6-16	Comparison of Weighted Average Annualized Cost for the Bundle Versus Cluster Approach .....	6-106
Figure 6-17	Capacity Requirements under Mid Gap .....	6-118
Figure 6-18	Load and DSM uncertainty Bands .....	6-125
Figure 6-19	Large Gap Capacity Requirements.....	6-128

**List of Tables**

---

Table 6-1	Adjusted UECs of CCGT for Various Market Scenarios, Site C and IPPs.....	6-12
Table 6-2	Cost of Capacity Options .....	6-14
Table 6-3	Potential Required Transmission to Load Centres and Associated Costs .....	6-16
Table 6-4	Mid Savings Levels for DSM Options and per cent of Load Growth .....	6-23
Table 6-5	Comparison of Adjusted UECs .....	6-32
Table 6-6	Block Details and UEC Calculations for Clean Generation Portfolio.....	6-34
Table 6-7	Block Details and UEC Calculations for Clean + Thermal Generation Portfolio (Revelstoke Unit 6 and 6 SCGTs).....	6-35
Table 6-8	Block Details and UEC Calculations for Clean + Thermal Generation Portfolio (Revelstoke Unit 6, GMS and 4 SCGTs).....	6-36
Table 6-9	Benefit of Site C .....	6-39
Table 6-10	Sensitivity of Site C Benefit to Market Prices .....	6-41
Table 6-11	Sensitivity of Site C Benefit to Capital Cost Increase.....	6-42
Table 6-12	Sensitivity of Site C Benefit to Gap Condition .....	6-44

---

Table 6-13	Sensitivity of Site C Benefit to LNG Scenario .....	6-45
Table 6-14	Environmental Attributes for the Site C, Clean Generation and Clean + Thermal Generation Portfolios.....	6-49
Table 6-15	Economic Development Attributes for the Site C, Clean Generation and Clean + Thermal Generation Portfolios .....	6-51
Table 6-16	Comparison of Alternative Supply Options to meet needs prior to Site C in-service.....	6-63
Table 6-17	Comparison of Alternative Options to meet long-term System Needs due to High LNG .....	6-65
Table 6-18	Summary of Fort Nelson/HRB Electricity Supply Strategies .....	6-70
Table 6-19	BC Hydro's Total Cost to Serve Fort Nelson and HRB (PV \$2013 million).....	6-73
Table 6-20	Overall Fort Nelson (FN)/HRB GHG production (PV of MT) .....	6-75
Table 6-21	CO <sub>2</sub> Produced by BC Hydro Facilities in Fort Nelson/HRB (PV of MT).....	6-76
Table 6-22	Incremental Cost (\$/tonne) to Upgrade Gas-Fired Generation Strategies to a System Clean Energy Strategy .....	6-78
Table 6-23	Comparison of Alternatives Against CEA 93 per cent Clean or Renewable Objective (percentage of BC Hydro System Clean Electricity, Average 2020 to 2030).....	6-80
Table 6-24	BC Hydro's Total Costs (PV, \$ million, without CO <sub>2</sub> Costs) .....	6-82
Table 6-25	BC Hydro Stranded Asset Risk Matrix .....	6-83
Table 6-26	Electrification Load Scenario Summary .....	6-90
Table 6-27	UEC Cost Comparison for Bundle Approach versus Cluster Approach for a 230 kV Line .....	6-107
Table 6-28	UEC Cost Comparison for Bundle Approach versus Cluster Approach for a 500 kV Line .....	6-107
Table 6-29	Total Cost Comparison for Bundle Approach versus Cluster Approach for a 230 kV Line .....	6-108
Table 6-30	Total Cost Comparison for Bundle Approach versus Cluster Approach for a 500 kV Line .....	6-108
Table 6-31	Inventory of Capacity Resource Options.....	6-117
Table 6-32	Capacity Need Uncertainties.....	6-123

---

## 6.1 Introduction

This chapter presents the resource planning analysis conducted utilizing the analytical framework described in Chapter 4 to inform the long-term planning actions that should be pursued to fill the Load-Resource Balance (**LRB**) gaps. As described in section 2.4.2, the LRBs and need for new resources have been analyzed at a number of stages. Chapter 4 addresses the manner in which BC Hydro prudently manages near-term costs while maintaining an adequate, cost-effective longer term supply. The LRB gap analyzed in the portfolios in this chapter reflects the cost management approach summarized in Table 4-18 and Table 4-19 and the LRBs shown in Figure 4-3 and Figure 4-4.

The analysis presented in this chapter is grouped into three categories:

- **LRB Mid Gap Before Expected LNG** - As described in Chapter 4, the mid gap is based on BC Hydro's mid-2012 Load Forecast. The Recommended Actions to fill the mid gap prior to LNG lead to the Base Resource Plan (**BRP**) are described in section 8.2.
- **LRB Mid Gap with Expected LNG** - Based on discussions with the B.C. Government and LNG proponents, the Expected LNG load is 3,000 GWh/year (360 MW) as early as F2020. To inform its plans, BC Hydro has considered both the Expected LNG load as well as a range of 800 GWh/year to 6,600 GWh/year as described in Chapter 2. Future demand from the LNG industry warrants specific analysis given that the size of these loads, potentially concentrated within a transmission constrained region, can have a significant impact on resource plans. Recommended Actions to enable BC Hydro to supply these large loads when LNG proponents enter into energy supply contracts with BC Hydro and make their final investment decisions are presented in section 8.3.

- 
- 1 • Contingency Conditions - CRPs address how BC Hydro would supply larger  
2 LRB gaps due to significant planning uncertainties such as load growth being  
3 greater than expected (e.g., higher load forecast) and/or planned resources  
4 under delivering, and in particular lower levels of energy and capacity savings  
5 from DSM given the extent of planned reliance on DSM. Recommended  
6 Actions to prepare for contingency conditions are presented in section 8.4.  
7 BC Hydro also considers planning uncertainties that would result in smaller  
8 LRB gaps, and flexibility and off-ramps that should be maintained for each  
9 resource.

10 The remainder of this chapter is structured as follows. Section [6.2](#) to section [6.4](#)  
11 discuss the generation resource mix to serve load growth prior to Expected LNG as  
12 follows:

- 13 • **Natural Gas-Fired Generation (section [6.2](#)):** Natural gas-fired generation is a  
14 cost-effective resource option that emits GHGs and is limited by the *Clean*  
15 *Energy Act (CEA)* 93 per cent clean or renewable energy objective. This  
16 section explores how the 7 per cent non-clean or renewable headroom (which  
17 excludes LNG loads per the British Columbia's Energy Objectives Regulation  
18 described in section 1.2.4) can best be used to meet forecasted needs.
- 19 • **DSM (section [6.3](#)):** Given the *CEA* 93 per cent clean or renewable target and  
20 the target to reduce BC Hydro's expected increase in demand for electricity by  
21 F2021 by at least 66 per cent, DSM, Site C and clean or renewable IPP  
22 acquisitions are the major options available to meet long-term resource  
23 requirements. In this section, the relative cost-effectiveness of DSM is  
24 compared to clean or renewable IPPs and Site C and the implications of having  
25 Site C in the plan are considered. The analysis shows that the current long-term  
26 DSM target as well as Site C are cost-effective.
- 27 • **Site C (section [6.4](#)):** The continued role of Site C as a cost-effective resource  
28 is tested including sensitivities to major input assumptions.



---

1 Section [6.5](#), considers the additional resource requirements to serve Expected LNG  
2 and the North Coast region:

- 3 • **LNG and the North Coast (section [6.5](#)):** This section begins with a discussion  
4 of the additional resource requirements to serve potential LNG load in  
5 BC Hydro's service area. The majority of the LNG load is expected to be  
6 concentrated in the North Coast region. The supply strategies and transmission  
7 planning considerations specific to this region are also addressed in this  
8 section.

9 The remaining sections, section [6.6](#) to section [6.9](#), discuss other potential new  
10 loads, transmission resources and contingency conditions:

- 11 • **Other Incremental Load Scenarios:** Potential large new loads could emerge  
12 in the Fort Nelson/Horn River Basin (**HRB**) area (section [6.6](#)) and from general  
13 electrification (section [6.7](#)). In section [6.6](#) and section [6.7](#), the planning  
14 environment and load potential from each of these areas are discussed along  
15 with supply strategies and resource requirements.
- 16 • **Transmission (section [6.8](#)):** This section identifies the transmission  
17 requirements to support resource requirements under mid gap, LNG scenarios  
18 and contingency conditions
- 19 • **Capacity and Contingency Analysis (section [6.9](#)):** This section begins by  
20 identifying the remaining need for capacity for the mid gap LRB. Next, a range  
21 of planning uncertainties is described and contingency conditions considered.  
22 The strategy to address these uncertainties leading to the development of the  
23 two CRPs is then discussed.

24 The analytical results shown in the following sections include key findings from  
25 technical, financial, environmental and economic development attributes. Detailed  
26 results from the IRP analysis, including portfolio composition, results and Present

1 Value (**PV**) cost differences, as well as environmental and economic development  
 2 attributes, are provided in Appendix 6A grouped by the same IRP topics/questions.

3 **6.2 Natural Gas-Fired Generation**

4 **6.2.1 Introduction**

5 The use of natural gas-fired generation is governed by the following energy  
 6 objectives as set out by the *CEA* and subsequent regulations:

- 7 • To generate at least 93 per cent of the electricity in B.C., from clean or  
 8 renewable resources, other than electricity to serve demand from facilities that  
 9 liquefy natural gas for export by ship
- 10 • To reduce B.C. GHG emissions pursuant to the legislated *Greenhouse Gas*  
 11 *Reduction Targets Act (GGRTA)*, GHG reduction targets are discussed in  
 12 section 5.4.2.2
- 13 • To encourage energy efficiency and clean or renewable electricity through:
  - 14 ▶ Development of innovative technology in B.C.
  - 15 ▶ Use of waste heat, biomass or biogas
  - 16 ▶ Use and development of clean or renewable resources in First Nations and  
 17 rural development.

18 Natural gas-fired generation is not a clean or renewable resource as defined by the  
 19 *CEA*. Section 1 of the *CEA* provides that “clean or renewable resource means  
 20 biomass, biogas, geothermal heat, hydro, solar, ocean, wind or any other prescribed  
 21 resource”. The Clean or Renewable Resource Regulation<sup>1</sup> provides that biogenic  
 22 waste, waste heat and waste hydrogen are clean or renewable resources. To meet  
 23 the *CEA* objectives, BC Hydro evaluated natural gas-fired generation within the

<sup>1</sup> B.C. Reg. 291/2010.

1 remaining headroom of 7 per cent for non-clean or renewable resources<sup>2</sup> for serving  
2 non-LNG loads, and has only contemplated exceeding this headroom in the  
3 Fort Nelson/Horn River Basin load scenarios where there are limited supply options.

4 As discussed in section 5.4.2.2, Policy Action No. 18 of the 2007 BC Energy Plan  
5 provides that new natural gas-fired generation is to have net zero GHG emissions.  
6 Natural gas-fired generation is also subject to the carbon tax; however, the B.C.  
7 Government has indicated in the Climate Action Plan that it is will not charge the  
8 carbon tax when natural gas-fired generation is required to acquire and retire  
9 offsets.<sup>3</sup> Natural gas-fired generation may be exempted from the carbon tax under  
10 section 84 of the *Carbon Tax Act*, which states that the Lieutenant Governor in  
11 Council (**LGIC**) may make regulations providing for exemptions from the payment of  
12 tax, or for refunds of all or part of the tax paid, with respect to a fuel or combustible  
13 that is the source for GHG emissions that are subject to the requirements of  
14 *Environmental Management Act (EMA)*. Such a regulation has not been issued to  
15 date by the LGIC. GHG offset cost assumptions are set out in section 5.4.3.3 and  
16 are used in the portfolio modelling analysis in this chapter. BC Hydro assumes that  
17 natural gas-fired generation would incur the maximum of either the B.C. carbon tax  
18 of \$30 per tonne of CO<sub>2</sub>e emissions or the GHG prices shown for B.C. in Table 5-3.

19 Gas-fired generation can be a significant source of dependable capacity and firm  
20 energy. The dispatchable and dependable nature of gas-fired generation can enable  
21 the integration of intermittent and non dispatchable renewable resources such as

---

<sup>2</sup> Although all non-clean or renewable resource options can use the 7 per cent non-clean headroom, the discussion here focuses on natural gas-fired resource options. Gas is the default non-clean generation option for most utilities because it is a proven technology, is available in significant amounts, is the most efficient, and has the least GHG emissions and criteria air contaminants compared to other non-clean options. Other non-clean options such as diesel will continue to be generation options where no other options are available/feasible (e.g., in some NIAs) but their usage/energy volume will be negligible

<sup>3</sup> The Climate Action Plan states at page 15: "To avoid unfairness and what might effectively be double taxation, the carbon tax and complimentary measures such as the 'cap and trade' system will be integrated as these other measures are designed and implemented".

1 wind and run-of-river hydro.<sup>4</sup> The cost of gas-fired generation is competitive given  
2 the current price of natural gas and the longer-term outlook for natural gas prices  
3 and GHG offset costs in most of the market scenarios analysed in the IRP. Unlike  
4 many other resource options, gas has siting flexibility that may allow it to be sited in  
5 locations that yield greater value (e.g., near load centres or in transmission  
6 constrained areas), with the significant constraint being the air emission permitting  
7 requirements and related social licensing issues. Its relatively short construction lead  
8 time, once permitting is secured, also makes it a good candidate as a contingency  
9 resource.

10 Natural gas-fired generation also has drawbacks. The cost of gas-fired generation is  
11 uncertain due to the historically volatile cost of natural gas and liquid GHG offsets  
12 markets. There are also permitting and development risks in B.C.

13 The key IRP questions for this resource option are:

- 14 • What is the optimal use of the 7 per cent non-clean or renewable headroom?
  - 15 ► Where should the allowable natural gas-fired generation be sited?
  - 16 ► When should the 7 per cent non-clean or renewable headroom be used?
- 17 • What natural gas-fired generation is needed to serve LNG loads? (This  
18 question is addressed in section [6.5](#))

## 19 **6.2.2 Applying the 93 per cent CEA Objective to Resource Planning**

20 BC Hydro interprets the CEA 93 per cent clean or renewable objective, which uses  
21 the phrasing “to *generate* electricity at least 93 per cent of the electricity” [emphasis  
22 added], as applying to the actual output of generation facilities as opposed to the  
23 planned reliance on the facilities.<sup>5</sup> BC Hydro must plan its system such that the

---

<sup>4</sup> For example, natural gas-fired generation can be turned off when generation from non-dispatchable run-of-river hydro is high when load is light such as during the freshet. Gas turbines can also provide firming for wind integration.

<sup>5</sup> Specifically, it is the ratio between clean electricity and the total electricity generated within the Province.

---

1 objective can be met when operating its facilities. BC Hydro reviewed several  
2 possible interpretations of the 93 per cent clean or renewable objective, their  
3 applications to the IRP and their consistency with the *CEA* as follows:

4 (a) **Meet the objective on average:** Enabling BC Hydro's generation to be at least  
5 93 per cent clean or renewable while meeting all of BC Hydro's load obligations  
6 (net of DSM and net of LNG loads) from B.C. resources and be able to do so  
7 under average water conditions (i.e., being able to meet the objective by  
8 averaging the clean generation percentage over a period of time, but not  
9 necessarily meeting the 93 per cent clean or renewable objective in every  
10 year). In this approach, BC Hydro would develop resource plans where energy  
11 contribution under average water conditions of Heritage hydroelectric facilities  
12 combined with the firm energy contribution from clean or renewable IPP  
13 resources would be at least 93 per cent of load requirements.

14 (b) **Meet the objective every year:** Taking a similar approach to (a) but for critical  
15 water conditions (i.e., being able to meet the objective in every year even under  
16 low water conditions when more reliance on thermal resources may be  
17 required).

18 (c) **Meet the objective (on average or every year) by relying on import of**  
19 **market energy:** Enabling BC Hydro's actual generation output to be at least  
20 93 per cent clean or renewable without consideration of whether all of  
21 BC Hydro's load obligations can be met from B.C. resources. In practice, this  
22 would allow BC Hydro to rely on significant amounts of natural gas-fired  
23 generation, with the intention to displace natural gas-fired generation with  
24 market energy import to meet load during operations. The minimized generation  
25 from natural gas-fired facilities in B.C. to meet load allows BC Hydro's  
26 generation to be at least 93 per cent clean or renewable even though a  
27 significant portion of the BC Hydro system load would be met by market  
28 imports.

1 BC Hydro ruled out approach (c) since this would defeat the intent of the *CEA* in  
2 setting out the electricity self-sufficiency requirement and the 93 per cent clean or  
3 renewable objective. As discussed in the 2008 LTAP, BC Hydro has been planning  
4 according to approach (b), based on the 90 per cent clean generation policy  
5 objective in the 2007 BC Energy Plan. By comparison, approach (a) would provide  
6 greater flexibility to use natural gas-fired generation. BC Hydro proposes to use  
7 approach (a) since it is consistent with the recent move to average water planning  
8 and it is a cost-effective action that meets the intent of the *CEA* energy objectives. In  
9 planning energy to average water conditions, BC Hydro is able to manage its  
10 resources and avoid being oversupplied in a low priced market.

### 11 **6.2.3 Resource Planning with Gas-Fired Generation**

12 BC Hydro relies on natural gas-fired generation for both dependable capacity and  
13 firm energy. The energy reliance is based upon how frequently these facilities are  
14 expected to operate, with the minimum being 18 per cent of full time over the course  
15 of a year (i.e., 18 per cent capacity factor). The 18 per cent capacity factor  
16 assumption was established in the 2008 LTAP to reflect that natural gas-fired  
17 generation, even if built purely for capacity purposes, would need to be capable of  
18 running at least at 18 per cent of the time to reliably provide dependable capacity.

19 Whether to increase the 18 per cent capacity factor minimum energy reliance  
20 depends upon the expected utilization of a particular plant with the sum of all  
21 gas-fired units' expected operations remaining within the available 7 per cent  
22 non-clean headroom. As described in section 3.4.1.9, there are two main categories  
23 of gas-fired turbines that inform this reliance:

- 24 • Combined Cycle Gas Turbines (**CCGTs**) are typically built where there is a  
25 need for both dependable capacity and an expectation of high utilization  
26 (typically used for base load energy type plants). CCGTs are a highly efficient  
27 technology, have a relatively high capital cost and are economic when they  
28 operate at a high capacity factor. In the analysis, a firm energy contribution

1 based on a 90 per cent capacity factor and a minimum must run requirement  
2 based on 70 per cent capacity factor has been used for CCGTs.

- 3 • Simple Cycle Gas Turbines (**SCGTs**) are typically built for dependable capacity  
4 (for use as peakers),<sup>6</sup> have lower capital cost than CCGTs, faster ramp rates  
5 and allow frequent starts/stops, but are significantly less efficient than CCGTs.  
6 SCGTs are readily dispatched off in favour of surplus energy or low cost market  
7 purchases. While SCGTs are typically not operated for many hours, the  
8 combination of SCGTs/surplus system energy/low cost markets have economic  
9 benefits while ensuring adequate dependable capacity is available to meet  
10 peak load requirements and adequate firm energy is available should a very dry  
11 water year or tight market conditions be experienced. In the analysis, an  
12 18 per cent capacity factor has been used in determining the firm energy  
13 contribution and the minimum must run requirement for SCGTs.

#### 14 **6.2.4 Non-Clean Headroom with the 93 per cent Clean Objective**

15 As stated in section [6.2.2](#), BC Hydro plans such that the average water output of  
16 Heritage hydroelectric facilities combined with the firm capability of clean or  
17 renewable IPP resources would serve at least 93 per cent of the load net of DSM.  
18 BC Hydro has four existing natural gas-fired generation facilities in its system<sup>7</sup> that  
19 take up part of the 7 per cent headroom available. They are:

- 20 • Fort Nelson Generating Station (**FNG**) – BC Hydro facility
- 21 • Prince Rupert Generating Station – BC Hydro facility
- 22 • Island Generation Plant – EPA

---


<sup>6</sup> Peakers (or peaking plants) are power generation plants that typically only run at times of peak demand.

<sup>7</sup> As described in section 2.3.2.1 and as required by subsections 3(5) and 6(2)9b) of the *CEA*, BC Hydro does not plan on any energy contribution from Burrard and hence Burrard does not have any impact on the 93 per cent clean or renewable objective from a planning perspective. BC Hydro also operates several diesel generators in NIAs. Their energy contribution is relatively minor and has no material impact on the 93 per cent clean or renewable objective.

1 • McMahon Cogeneration Plant - EPA

2 These existing facilities provide approximately 3,500 GWh/year of non-clean or  
 3 renewable firm energy contribution. BC Hydro plans to continue relying on the  
 4 energy from these facilities within the planning horizon. (BC Hydro’s plan to exercise  
 5 an option to extend the McMahon Cogeneration Plant Electricity Purchase  
 6 Agreement (**EPA**) is discussed in section 8.2.4.2). The remaining non-clean or  
 7 renewable energy headroom available for new natural gas-fired generation during  
 8 the planning horizon based on the mid gap (Option 2/DSM target, no LNG load)  
 9 scenario, as shown in [Figure 6-1](#). [Figure 6-2](#), shows the corresponding capacity,  
 10 assuming capacity factors of 18 per cent and 90 per cent that are typical of SCGTs  
 11 and CCGTs respectively.


12 **Figure 6-1 Available Headroom for Non-Clean Firm**  
 13 **Energy**





1  
2  
3

**Figure 6-2 Available Headroom for Non-Clean Capacity (based on 18 per cent and 90 per cent capacity factor)**



4 **6.2.5 Permitting Gas-Fired Generation**

5 New natural gas-fired generation greater than or equal to 50 MW requires an  
 6 Environmental Assessment Certificate (**EAC**) pursuant to *B.C. Environment*  
 7 *Assessment Act (BCEAA)* and an air emission permit under the *Environmental*  
 8 *Management Act (EMA)*. Securing an EAC and/or air emission permit for natural gas  
 9 generation could be a lengthy process and have an uncertain outcome in some  
 10 regions of the Province. For example, Metro Vancouver has responsibility for issuing  
 11 air emission permits for Lower Mainland facilities,<sup>8</sup> and has taken the public position  
 12 that it would not welcome natural gas generation within the Lower Fraser Valley

<sup>8</sup> Per section 31 of *EMA*.

1 airshed.<sup>9</sup> In addition, the Province, in its news release<sup>10</sup> concerning Direction No. 2<sup>11</sup>  
 2 to the BCUC, cited concerns with Burrard air emissions in the Lower Fraser Valley  
 3 airshed as a reason for the Directive.

4 **6.2.6 Cost of Gas-Fired Generation Compared to Clean Resources**

5 Gas-fired generation is generally lower in cost compared to clean or renewable  
 6 resources, in particular under the most likely market scenario (i.e., Market  
 7 Scenario 1). [Table 6-1](#) compares the costs of natural gas-fired generation under the  
 8 range of market scenarios described in Chapter 5 to the cost of Site C and the  
 9 weighted average cost of IPP clean or renewable energy equivalent to the firm  
 10 energy available from Site C (i.e., 5,100 GWh/year).

11 **Table 6-1 Adjusted UECs<sup>12</sup> of CCGT for Various**  
 12 **Market Scenarios, Site C and IPPs**

Market Scenarios	Market Scenario Likelihood (%)	50 MW CCGT (\$/MWh)	250 MW CCGT (\$/MWh)	500 MW CCGT (\$/MWh)	Site C	IPPs
Scenario 1 <sup>13</sup>	60	85.96	60.51	56.90	83	125
Scenario 2 <sup>14</sup>	20	71.33	45.99	42.33		
Scenario 3 <sup>15</sup>	15	101.86	76.29	72.76		
Scenario 4 <sup>16</sup>	4	94.64	68.87	65.29		
Scenario 5 <sup>17</sup>	1	138.97	111.02	107.49		

<sup>9</sup> For example, D.Bell, Metro Vancouver, letter to Washington State Energy Site Evaluation Council, “Re: Draft Notice of Construction/Prevention of Significant Deterioration Permit and Supplementary Draft Fact Sheet for Sumas Energy 2 Generating Facility”, September 28, 2000.

<sup>10</sup> B.C. Ministry of Energy, Mines and Petroleum Resources, “News Release: Province Advances Commitment to Clean, Renewable Energy”, October 28, 2009, page 1.

<sup>11</sup> B.C. Reg. 254/2009, repealed by B.C. Reg. 318/2010 and replaced by sections 3(5), 6(2)(d) and 13 of CEA and the Burrard Thermal Electricity Regulation, B.C. Reg. 319/2010.

<sup>12</sup> All cost values presented (UECs, UCCs, capital costs) are expressed in 2013\$. The nominal cost of a generation or transmission asset will be higher when it comes into service and will depend on the length of time from now up to the in-service date of the asset as well as the escalation in costs that occur in the interim. For example, an asset that costs \$1 million in 2013 would cost \$1.22 million in 10 years’ time due to the impact of general inflation alone.

<sup>13</sup> Medium Electricity, Medium regional GHG (Carbon tax for B.C.), Medium Gas.

<sup>14</sup> Low Electricity, Low regional GHG (Carbon tax for B.C.), Low Gas.

<sup>15</sup> High Electricity, High regional GHG (Carbon tax for B.C.), High Gas.

<sup>16</sup> Medium Electricity, Medium regional/national GHG, Medium Gas.

<sup>17</sup> High Electricity, High regional/national GHG, High Gas.

---

1 The unit energy costs (**UECs**) for CCGTs and IPP resources have been adjusted,  
2 and include a 5 per cent soft cost adder to reflect the fact that there would likely be  
3 mitigation, First Nation consultation, public engagement and regulatory review costs,  
4 thus making them comparable to Site C as the cost estimate for Site C includes  
5 these soft costs (see section 3.4.3 for a discussion of the adjusted UECs). The  
6 details of the IPP resources making up the 5,100 GWh/year block are provided in  
7 section [6.4.2](#). A 90 per cent capacity factor is assumed for the cost shown for  
8 CCGTs. The table also illustrates that the comparative energy benefit is maximized  
9 when the energy is generated by more efficient larger sized gas-fired units.

10 Gas-fired generation is also a low cost source of capacity. A comparison of the UCC  
11 for a SCGT and other supply side capacity options is provided in [Table 6-2](#). Note  
12 that the unit capacity costs (**UCCs**) in [Table 6-2](#) represent only fixed costs at the  
13 point of interconnection and do not include fuel and variable OMA, nor a credit for  
14 firm energy contribution to the system. The numbers for pumped storage costs also  
15 do not reflect the fact that pumped storage facilities are net users of energy. The  
16 cost of firm energy resources required to offset the system energy loss is estimated  
17 to be around \$84 million<sup>18</sup> per year based on a 1,000 MW pumped storage facility  
18 operating at an 18 per cent capacity factor. The UCC of a pumped storage facility  
19 would increase by \$84/kW-year if this cost is taken into account. Detailed discussion  
20 of capacity options are provided in section 3.4.2.

---

<sup>18</sup> Based on an IPP firm energy cost of \$125/MWh as shown in Table 6-1.

1 **Table 6-2 Cost<sup>19</sup> of Capacity Options**

Capacity Resource	UCC (\$kW-year)
GMS Units 1-5 Capacity Increase	35
Revelstoke Unit 6	50
SCGT	$\geq 84$ <sup>20</sup>
Pumped Storage – Mica	100
Pumped Storage - Other	$\geq 118$ <sup>21</sup>

2 **6.2.6.1 Environmental and Economic Development Considerations**

3 The use of gas-fired resources to displace clean or renewable energy, transmission,  
 4 or clean or renewable capacity resources will have an effect on the environmental  
 5 and economic development attributes being tracked for a portfolio. A comparison of  
 6 the attributes between a portfolio that uses the 7 per cent non-clean or renewable  
 7 headroom and a portfolio using only clean or renewable resources is shown in  
 8 section [6.4.6](#).

9 **6.2.7 Optimal Use of the 7 per cent Non-Clean Headroom**

10 The optimal use and siting of gas-fired generation can provide significant economic  
 11 benefits over and above the cost benefits identified in the previous section. The key  
 12 questions are “where” and “when” gas capacity should be used to yield the most  
 13 benefits.

14 **6.2.7.1 Using Gas as a Transmission Alternative**

15 Siting natural gas-fired generation in remote areas (e.g., areas currently connected  
 16 to the system with a long radial transmission line or areas currently non-integrated)

---

<sup>19</sup> All cost values presented (UECs, UCCs, capital costs) are expressed in \$F2013. The nominal cost of a generation or transmission asset will be higher when it comes into service and will depend on the length of time from now up to the in-service date of the asset as well as the escalation in costs that occur in the interim. For example, an asset that costs \$1 million in 2013 would cost \$1.22 million in 10 years’ time due to the impact of general inflation alone.

<sup>20</sup> The UCC shown is for a SCGT located at Kelly Lake which is in close proximity to transmission and a major gas pipeline. SCGTs located elsewhere are likely to have higher fixed costs in terms of firm gas tolls and transmission interconnection costs.

<sup>21</sup> The UCC shown is for the lowest cost Pumped Storage site identified in studies on potential pumped storage sites in B.C. A Pumped Storage project located at another site would have a higher UCC.

---

1 could avoid or defer costly transmission or enable BC Hydro to serve load that it may  
2 otherwise not be able to serve because of long lead times for transmission. In  
3 addition, natural gas-fired generation located in a load centre can provide additional  
4 benefits in the form of increased transmission maintenance flexibility and increased  
5 transmission stability as described in section [6.5.3](#).

6 Factors that need to be considered in evaluating the use of natural gas-fired  
7 generation at a particular location include the number and size of units required and  
8 whether the units are required to be base loaded. In general, it is economic to build  
9 larger, more efficient units as illustrated by the data in [Table 6-1](#) . It is also preferable  
10 to build gas-fired generation at a location which allows peaking units to be built since  
11 they take up significantly smaller gas headroom. This enables greater amounts of  
12 dependable gas-fired generation capacity at different locations in BC Hydro's service  
13 area providing transmission benefits at each location.

14 BC Hydro identified a few locations where siting natural gas-fired generation could  
15 yield benefits related to avoidance or deferral of transmission, aid transmission  
16 stability and facilitate maintenance. [Table 6-3](#) provides a list of these locations, the  
17 potential transmission options to these regions and their capital costs. The capital  
18 costs are indicative of the order of magnitude of the investments required. The  
19 following subsections describe each of these regions and their planning issues in  
20 more detail.

1  
2

**Table 6-3 Potential Required Transmission to Load Centres and Associated Costs<sup>22</sup>**

Region	Potential Transmission Requirement	\$ Billion
North Coast	500 kV transmission line from WSN to SKA	1.1
Fort Nelson/HRB	500 kV North East Transmission Line	1.1
Lower Mainland/ Vancouver Island	500 kV Interior to Lower Mainland Transmission line (5L46)	0.7
South Peace Region	South Peace area transmission reinforcements	0.3

3 *North Coast*

4 As discussed in section [6.5](#), the electricity demand in the North Coast region may  
 5 increase significantly, primarily due to the development of several LNG facilities and  
 6 new mines. The region is currently interconnected to the rest of the BC Hydro  
 7 system by a radial 500 kV transmission line (consisting of three cascading 500 kV  
 8 circuits). This line, even after non-wire upgrades, may not be capable of transferring  
 9 sufficient electricity from the integrated system to serve all of the potential new  
 10 loads. A new 500 kV transmission line requires eight to 10 years of development  
 11 time and would have high capital costs and permitting risks. In comparison to  
 12 building a new transmission line and adding more generating capacity units at other  
 13 locations on the integrated system, natural gas-fired generation in the form of  
 14 SCGTs in the North Coast could be a cost-effective option to meet the potential  
 15 increased regional loads in a timely manner (SCGTs would have about a five-year  
 16 lead time which could be reduced somewhat through advanced planning and  
 17 expedited approvals; refer to section 8.3.1 in this regard). The SCGTs operating as  
 18 peaking units can enhance the transmission reliability of the existing radial  
 19 transmission system and provide dependable capacity to supply expected load  
 20 increases in the region.

---

<sup>22</sup> Costs shown in the table are capital costs including interest during construction in \$F2013 with -50 per cent to +100 per cent accuracy. All cost values presented (UECs, UCCs, capital costs) are expressed in \$F2013. The nominal cost of a generation or transmission asset will be higher when it comes into service and will depend on the length of time from now up to the in-service date of the asset as well as the escalation in costs that occur in the interim. For example, an asset that costs \$1 million in 2013 would cost \$1.22 million in 10 years' time due to the impact of general inflation alone.

---

1 Although the use of natural gas-fired generation to serve LNG load is not limited by  
2 the 7 per cent non-clean or renewable headroom, the unique characteristics of this  
3 region illustrates the potential benefits of siting natural gas-fired generation as a  
4 transmission alternative.

#### 5 *Fort Nelson/HRB*

6 As described in Chapter 2, the Fort Nelson region is a non-integrated area (**NIA**)  
7 currently served by local natural gas-fired generation. The nearby HRB is a region  
8 with significant natural gas production potential. A portion of the gas extraction  
9 process could be electrified leading to significant growth of the electrical load in the  
10 area. Gas-fired generation offers a potentially cost-effective alternative to  
11 B.C.-based transmission or Alberta-based transmission alternatives but may use  
12 part or all of the 7 per cent non-clean or renewable headroom. The relative  
13 cost-effectiveness of various supply strategies and available gas head room are  
14 dependent on market scenario and the load scenarios for the Fort Nelson/HRB  
15 region. The results of BC Hydro's analysis for the Fort Nelson/HRB region are  
16 summarized in section [6.6](#).

#### 17 *Lower Mainland/Vancouver Island*

18 The Lower Mainland/Vancouver Island region accounts for approximately  
19 70 per cent of BC Hydro system load. Only around 25 per cent<sup>23</sup> of the peak Lower  
20 Mainland/Vancouver Island load can be met by resources within the region, meaning  
21 most of its capacity requirement is met via transmission. Future sources of capacity  
22 in the Lower Mainland/Vancouver Island region other than natural gas-fired  
23 generation, such as pumped storage facilities, have significant uncertainties in terms  
24 of development and operations. As discussed in section [6.8.4.1](#), if pumped storage  
25 facilities in the Lower Mainland/Vancouver Island are not available, an additional line  
26 from the Interior to Lower Mainland after 5L83 may be required by F2029 under a

---

<sup>23</sup> Excluding Burrard capacity.

---

1 large gap condition. This next line can be avoided or delayed by siting gas-fired  
2 generation in Lower Mainland/Vancouver Island region. However, siting gas-fired  
3 generation in the Lower Mainland would be very challenging from a permitting  
4 perspective as discussed in section [6.2.5](#).

5 *South Peace Region*

6 Section 2.5 identified substantial growth potential in the South Peace region as the  
7 natural gas industry develops unconventional gas reserves in the Montney gas  
8 basin. The high load growth expectation has triggered the need for transmission  
9 upgrades and additions in this area.

10 In April 2013, the BCUC granted a CPCN for BC Hydro's Dawson Creek to  
11 Chetwynd Area Transmission Project (**DCAT**), which is designed to address  
12 electricity supply constraints in the Dawson Creek and Groundbirch areas within the  
13 South Peace region. While DCAT will increase both N-0 and N-1 regional load  
14 serving capabilities, BC Hydro's load forecast indicates additional supply will be  
15 needed.

16 The use of gas-fired generation as an alternative to network transmission upgrades  
17 (DCAT plus future transmission additions) were assessed as part of the DCAT  
18 CPCN application process. The assessment concluded the transmission alternatives  
19 were generally more cost-effective and reliable than the comparable natural  
20 gas-fired generation alternatives. There were a number of factors that contributed to  
21 this conclusion including:

- 22 • Using gas-fired generation would require the installation of relatively small units  
23 (50 MW to 75 MW) to have redundancy such that an acceptable level of  
24 reliability can be achieved. Such redundancy is required to allow for both  
25 planned outages (maintenance) and unplanned outages (breakdowns) of  
26 generating units;



- 
- 1 • The use of small gas-fired units, even if configured as CCGTs, has cost  
2 inefficiencies relative to larger unit sizes because of higher unit capital costs,  
3 and higher operating costs associated with the additional maintenance required  
4 for multiple unit configurations. There are also operational inefficiencies for the  
5 smaller CCGT units since they generally have lower thermal efficiencies (higher  
6 heat rates) compared to the larger units;
  - 7 • There are further inefficiencies (e.g., operation at partial unit loadings and  
8 uneconomic dispatch) associated with the need for "reliability must run"  
9 operation of the local units to ensure an acceptable level of reliability is  
10 maintained.

11 This IRP does not provide an updated analysis for the South Peace region that  
12 compares future transmission additions to local natural gas-fired generation. Such  
13 analysis will be included in any future CPCN application for area reinforcements  
14 needed to meet the supply gap identified in section 2.5.5. However, given the  
15 drawbacks identified above, as well as broader system considerations associated  
16 with optimal use of the 7 per cent gas head room, further reinforcement of the South  
17 Peace region transmission system is expected to be the preferred supply option.

#### 18 **6.2.7.2 Using Gas as a Capacity and Contingency Resource**

19 Most of the low cost hydro capacity options that were available to BC Hydro have  
20 now been developed to meet load growth. Revelstoke Unit 5 is now operational  
21 while Mica Units 5 and 6 are currently under construction. Revelstoke Unit 6,  
22 GMS Units 1-5 Capacity Increase and Site C are the only remaining large scale  
23 hydro-electric capacity options available to BC Hydro. Site C is in the BRP to meet  
24 capacity need under the mid gap condition (see section [6.4](#) and section [6.9](#) for more  
25 details, and section 8.2.6). However, it is also a large project with regulatory  
26 uncertainty. Revelstoke Unit 6 (488 MW) and GMS Units 1-5 capacity increase (up  
27 to 220 MW) together are not sufficient to replace Site C's 1,100 MW of dependable  
28 capacity in the event of a delay in the Site C earliest in-service date (**ISD**) of F2024.

---

1 Furthermore, as identified in section [6.9](#), the contingency conditions considered by  
2 BC Hydro for planning purposes could require BC Hydro to use up all of its large  
3 scale hydro-electric options.

4 Capacity options other than natural gas-fired generation and the ones listed above  
5 have significant development and operational uncertainties. Pumped storage has  
6 been identified as a sizeable source of clean or renewable capacity in B.C. with an  
7 estimated lead time of eight to 10 years. However, pumped storage has not yet been  
8 permitted or developed in B.C., and thus significant uncertainties exist around the  
9 permitting process and development timelines. Furthermore, as shown in [Table 6-2](#),  
10 pumped storage hydro is significantly more expensive than gas-fired SCGTs. DSM  
11 capacity options are limited in potential and have implementation and operational  
12 uncertainties as discussed in section 3.7 and section 6.9.

13 Gas-fired generation has a relatively short construction lead time once permitting is  
14 secured. Siting flexibility also exists, provided gas supply is available and required  
15 permitting can be secured. Hence, given the lack of other capacity alternatives that  
16 can act as contingency resources, there is added value for reserving natural  
17 gas-fired generation for contingency situations. Developing peakers that provide  
18 dependable capacity instead of base loaded gas-fired units would maximize the  
19 dependable capacity that is available for contingency purposes. [Figure 6-2](#) shows  
20 that the available capacity increases from about 100 MW to 600 MW by around  
21 F2024, if the gas-fired generation is built for capacity (i.e., SCGT) rather than energy  
22 (i.e., CCGT).

23 BC Hydro has compared a portfolio that uses the 7 per cent non-clean or renewable  
24 headroom for capacity in combination with clean or renewable IPP resources instead  
25 of Site C to a portfolio that uses the 7 per cent non-clean or renewable headroom  
26 when an energy or capacity gap re-emerges after Site C. The mid load forecast  
27 without LNG was used in this analysis. Gas-fired units were assumed to be in the  
28 Kelly Lake region in close proximity to a major natural gas pipeline. The results of

---

1 the portfolio analysis are shown in section [6.4](#). The analysis shows that the latter  
2 portfolio of building Site C, and utilizing the 7 per cent non-clean or renewable  
3 headroom in subsequent years is more cost-effective. The option value of being able  
4 to reserve gas-fired generation as a contingency resource in the face of future  
5 uncertainties is an added benefit that is not captured in this analysis.

### 6 **6.2.8 Conclusions**

7 Planning to meet the *CEA* 93 per cent clean or renewable objective under average  
8 water conditions is consistent with the objectives of the *CEA*.

9 Natural gas-fired energy has a cost advantage over other resources given current  
10 gas prices as well as under most Market Scenarios. However, using gas-fired  
11 generation primarily for capacity, while potentially siting it as a transmission  
12 alternative (to benefit from transmission deferral/avoidance) and reserving it as a  
13 contingency resource, allows BC Hydro to optimize the use of the 7 per cent  
14 non-clean or renewable headroom.

15 In considering the siting of gas-fired generation, BC Hydro identified several other  
16 regions in addition to the Kelly Lake area which is in close proximity to major load  
17 centre and a major gas pipeline. The siting of gas-fired generation in these other  
18 regions may yield significant transmission deferral benefits. They include the North  
19 Coast, Fort Nelson/HRB, and the Lower Mainland/Vancouver Island regions. The  
20 South Peace region is an area where the need to build small, redundant gas units as  
21 well as the need to operate gas-fired units is expected to result in transmission being  
22 the preferred supply option. Gas-fired generation has a relatively short construction  
23 lead time. However, permitting can be challenging especially in locations such as the  
24 Lower Mainland. Lengthy permitting requirements can potentially preclude the use of  
25 gas-fired generation as a contingency resource or as an alternative to transmission.  
26 BC Hydro should explore the gas-fired supply options to reduce potential delays to  
27 siting gas and preserve the value that is offered by gas-fired generation.

1 The conclusions on this gas-fired generation section support Recommended Actions  
2 No. 10 and No. 16 described in Chapter 8.

### 3 **6.3 Demand-Side Measures**

#### 4 **6.3.1 Introduction**

5 The remaining energy resource options for BC Hydro to meet long-term needs are  
6 DSM, Site C and clean or renewable IPPs. BC Hydro analyzes DSM first to meet the  
7 CEA objective of reducing at least 66 per cent of load growth by 2020 (i.e., F2021)  
8 using DSM and because, as shown in Chapter 3, it is a low cost resource option with  
9 low environmental footprint. Section 4.2.5.2 established the preferred means of  
10 achieving savings through short-term adjustments to DSM Option 1 and  
11 Option 2/DSM Target<sup>24</sup>. The analysis in this chapter compares the adjusted DSM  
12 Options 1 and 2, and DSM Option 3 described in section 3.3.1, to each other, and to  
13 supply-side resources such as Site C and clean or renewable IPPs to determine the  
14 most cost-effective resource mix and answer the following questions:

- 15 • Should the long term DSM target established in the 2008 LTAP be adjusted?
- 16 • Should BC Hydro continue to advance Site C for its earliest ISD of F2024?

17 The analysis jointly considers the continued cost-effectiveness of Site C and the  
18 appropriate DSM reliance to minimize short-term costs while continuing to provide  
19 cost-effective long term savings. The cost-effectiveness of Site C is further tested in  
20 section [6.4](#). The conclusions on the DSM target and Site C's continued role will  
21 determine whether there is any need for clean or renewable IPP resources.

#### 22 **6.3.2 Resource Need: DSM Options and Load Resource Balance**

23 The three DSM options analyzed differ based upon increasing program activities in  
24 moving from Option 1 to Option2/DSM Target to Option 3. As described in  
25 Chapter 4, low (about P10), mid and high (about P90) levels of savings were

---

<sup>24</sup> Note that short term adjustments are already reflected in these options as shown in Chapter 3

1 assessed for Option 2/DSM Target to reflect the quantifiable uncertainty of  
 2 forecasted DSM savings.

3 [Table 6-4](#) shows the mid savings level associated with these three DSM options for  
 4 F2021 and their ability to reduce the load growth per the CEA objective. [Table 6-4](#)  
 5 also shows the per cent of load growth numbers both with and without Expected  
 6 LNG; however, the analysis in this chapter reflects the need for resources prior to  
 7 including Expected LNG. The ability to supply Expected LNG loads is further  
 8 reviewed in section [6.5](#).


9 **Table 6-4 Mid Savings Levels for DSM Options**  
 10 **and per cent of Load Growth**

DSM Option	Mid Savings in F2021 (GWh/year)	% of Load Growth without Expected LNG	% of Load Growth with Expected LNG
Option 1	6,100	67	58
Option 2/DSM Target	7,800	78	69
Option 3	8,300	82	72

11 [Figure 6-3](#) and [Figure 6-4](#) show the remaining load resource gaps (mid-gap) after  
 12 implementation each of these DSM options in a no LNG scenario. These remaining  
 13 gap sizes would inform the need for supply side resources once a level of DSM is  
 14 selected.


1  
2

**Figure 6-3 Energy Gap after DSM Options 1 to 3 (Mid Gap)**



3  
4

**Figure 6-4 Capacity Gap after DSM Options 1 to 3 (Mid Gap)**



\* including planning reserve requirements

---

### 1 **6.3.3 Financial Factors: Cost of DSM Options**

2 As described in section 3.3.4.1, there are two primary cost-effectiveness tests for  
3 DSM: Total Resource Cost (**TRC**) and Utility Cost (**UC**). BC Hydro uses the Net TRC  
4 in the Chapter 6 analysis; however, the Net TRC reflective only of regional  
5 transmission and distribution capacity benefits for BC Hydro is included in the  
6 calculation of portfolio PVs. The UC is used in Chapter 4 and in section 8.2.1.

7 As described in section 3.3.3.1, all three DSM options have low average TRCs  
8 ranging from \$32/MWh to \$35/MWh. Among the three DSM tools (i.e., codes and  
9 standards, rates structure and programs), programs have the highest cost. It is  
10 important to recognize that while the average cost of each DSM option is low  
11 (compared to \$94/MWh<sup>25</sup> and above for supply side resources), each option is  
12 comprised of DSM programs with a wide range of costs. For example, DSM target  
13 programs have net TRC costs ranging from \$6/MWh to \$113/MWh (see  
14 section 8.2.1.1).

### 15 **6.3.4 Portfolio Analysis**

16 In this analysis, different portfolios of DSM options and supply side (Site C and clean  
17 or renewable IPPs) resources to fill LRB gaps are created, and the PVs of the costs  
18 of these portfolios are compared. This analysis is done using the base assumptions  
19 shown in [Figure 6-5](#)<sup>26</sup> unless otherwise noted.

---

<sup>25</sup> Site C cost adjusted to Lower Mainland but before netting off capacity benefits.

<sup>26</sup> For 30-year portfolio analysis, DSM savings were extended from the underlying 20-year DSM options using two methods: 1) reflecting the most current thinking where the last year of cumulative savings was held to be constant; and 2) savings continue to grow based on the rate of growth averaged over the last five years. Portfolios comparing DSM options used the “constant savings” assumption. For the rest of the analysis, the earlier “extrapolation” assumption was used.

1

**Figure 6-5 Modelling Assumptions**

<b>Modelling Map</b>				
<b>Uncertainties/Scenarios</b>				
Market Prices	Scenario 2 Low	Scenario 1 Mid	Scenario 3 High	
Load Forecast	Low	Mid	High	
DSM deliverability	Low	Mid	High	
LNG Load Scenarios	Prior to Expected LNG	800 GWh	3000 GWh	6600 GWh
<b>Resource choices</b>				
Usage of 7% non-clean	Yes	No		
Site C (all units in) timing	F2024	F2026	No Site C	
<b>Modelling Assumptions and Parameters</b>				
BCH/IPP Cost of Capital	5/7	5/6		
Pumped Storage as Option	Yes	No		
Site C Capital Cost	Base	Base plus 10%		
Wind Integration Cost	\$5/MWh	\$10/MWh	\$15/MWh	
	shows the modeling assumptions			

2 **6.3.4.1 Option 2/DSM Target with and without Site C**

3 The initial analysis tests whether Site C continues to be a cost-effective resource  
 4 given the current BC Hydro DSM target (Option 2). Option 2/DSM Target provides  
 5 sufficient energy leading up to Site C’s earliest ISD while allowing for a reduction in  
 6 near-term program expenditures.

7 The analysis shows that the portfolio with Site C has a PV benefit of \$630 million<sup>27</sup>  
 8 over a clean or renewable resource portfolio without Site C and a benefit of

<sup>27</sup> Note that the DSM savings of Option 2 used in the Site C analysis was extended from 20 years to 30 years using the “extrapolation” assumption as described in the footnote in section 6.3.4. That analysis resulted in a \$630 million benefits for Site C. If the “constant savings” assumption is used, Site C benefit is increased to \$750 million. Apart from the \$630million and \$150 million quoted in section 6.3.4.1, all other PV numbers or differences quoted in section 6.3 are based on portfolios with DSM savings extended using the “constant savings” assumption.



---

1 \$150 million over a portfolio that maximizes the use of the 7 per cent natural gas  
2 headroom, meaning Site C is a cost competitive resource after implementation of the  
3 Option 2/DSM Target. This primarily demonstrates that Site C continues to be more  
4 cost-effective than other clean or renewable supply side resources. The  
5 cost-effectiveness of Site C given the current Option 2/DSM Target is further  
6 analysed in section [6.4](#).

#### 7 **6.3.4.2 DSM Option 3**

8 The next analysis was to determine if DSM Option 3 would be a lower cost potential  
9 alternative to Site C. DSM Option 3 on its own would only defer the need for Site C's  
10 energy output for two years (from F2027 to F2029, without Expected LNG). To be an  
11 alternative to Site C, DSM Option 3 must be augmented with additional supply side  
12 resources to match Site C's energy and dependable capacity output. The most  
13 cost-effective alternative to Site C would include the use of natural gas-fired  
14 generation up to the 7 per cent non-clean headroom. The results show that the  
15 portfolio with Option 2/DSM Target and Site C has a PV cost benefit of \$320 million  
16 compared to the portfolio with Option 3, natural gas-fired generation within the  
17 7 per cent headroom, low cost Revelstoke Unit 6 and GMS Units 1-5 Capacity  
18 Increase capacity resources but without Site C.

19 A portfolio with Option 3 was also compared to a portfolio with Option 2/DSM Target,  
20 both with Site C and no natural gas-fired option. The comparison shows that given  
21 Site C, staying with Option 2/DSM Target would avoid costly surplus and has a  
22 \$260 million lower PV cost than DSM Option 3.

23 The ability to supply Expected LNG load given DSM Option 2/DSM Target and  
24 Site C without adding additional energy resources is discussed in section [6.5](#) and  
25 demonstrates that DSM Option 3 would not be cost-effective at this time even with  
26 Expected LNG.

---

### 1 **6.3.4.3 DSM Option 1**

2 The Option 2/DSM Target analysis concluded that a portfolio with Site C was more  
3 cost-effective than a portfolio without Site C. Given that Site C is a cost-effective  
4 resource and is continuing to be advanced, the next question is whether it would be  
5 more cost-effective to reduce the DSM target to Option 1, which meets the minimum  
6 66 per cent load reduction objective of the CEA.

7 The portfolio with Option 2/DSM Target has a \$90 million PV benefit compared to  
8 portfolio with Option 1. Both portfolios include Site C. These portfolios show that  
9 although Option 2/DSM Target results in more surplus, the incremental savings from  
10 Option 1 to Option 2/DSM Target is cost competitive against market prices, making  
11 the portfolio with Option 2/DSM Target lower cost.

12 Furthermore, reducing the DSM target is risky at this time. Site C is a large project  
13 and faces regulatory approval uncertainty. Therefore, reducing the DSM target  
14 before Site C's development is secured could create a greater need for more costly  
15 supply-side resources such as clean or renewable IPPs. In a scenario without  
16 Site C, the portfolio with Option 1 would be \$330 million more costly than portfolio  
17 with Option 2/DSM Target. In the Expected LNG scenario, the energy deficit before  
18 Site C would increase by 1,300 GWh/year to 2,700 GWh/year if the target for DSM is  
19 reduced to Option 1.

### 20 **6.3.5 Deliverability Risks**

21 The deliverability risk/uncertainties around DSM are discussed in section 4.3.4.2. An  
22 unexpected downward departure from the planned level of DSM savings is a  
23 reliability concern, particularly with respect to capacity. With Option 2/DSM Target,  
24 BC Hydro would be relying on DSM to deliver 1,400 MW of dependable capacity by  
25 F2021 (i.e., 86 per cent of incremental peak load growth from F2013). Based on the  
26 DSM uncertainty quantified by BC Hydro as described in section 4.3.4.2, there is a  
27 about 10 per cent probability that the DSM Plan will deliver about 300 MW less than  
28 the 1,400 MW DSM target by F2021.

1 DSM deliverability risk is further assessed in section [6.9](#) dealing with capacity and  
2 contingency plans.

### 3 **6.3.6 Environmental and Economic Development Benefits**

4 DSM avoids the environmental impacts associated with the construction of new  
5 generation facilities. Incremental DSM also provides economic development benefits  
6 through the creation and retention of jobs and increased GDP.

### 7 **6.3.7 Conclusions**

8 Option 2/DSM Target is the most cost-effective long-term target at this time. DSM  
9 Option 3 is not a cost-effective alternative to Site C or to the DSM target. Lowering  
10 the DSM target level to DSM Option 1 is not cost-effective. It is also too risky to  
11 pursue at this time given the approval uncertainty associated with Site C and  
12 potential LNG load.

13 Conclusions in this DSM section support Recommended Action 1, as described in  
14 section 8.2.

## 15 **6.4 Site C**

### 16 **6.4.1 Introduction**

17 Site C would provide approximately 1,100 MW of dependable capacity, and  
18 approximately 4,700 GWh and 5,100 GWh of firm energy and average energy per  
19 year, respectively. The earliest ISD for Site C would have the first unit in operation  
20 by December 2022 and all units in place by F2024. This would allow the full capacity  
21 of Site C to be relied upon during the peak load winter season of F2024.

22 The key question for Site C in the IRP is:

- 23 • Should BC Hydro continue to advance Site C for its earliest ISD?

---

1 To assess Site C's cost-effectiveness relative to other available resource options,  
2 portfolios including Site C<sup>28</sup> were compared against portfolios that did not include  
3 Site C. Two general categories of portfolio were analyzed:

- 4 • Clean Generation Portfolios: these portfolios use a combination of clean or  
5 renewable resources including wind, biomass and run-of-river hydro.  
6 Revelstoke Unit 6, GMS Units 1-5 Capacity Increase and lastly pumped storage  
7 capacity projects were added as needed to meet the capacity requirement of  
8 the portfolios. These portfolios reserve the 7 per cent non-clean headroom for  
9 contingency use as described in section [6.2](#).
- 10 • Clean + Thermal Generation Portfolios: the resource options in these portfolios  
11 are the same as the Clean Generation Portfolios with the exception that thermal  
12 generation (in the form of SCGTs) within the 7 per cent non-clean or renewable  
13 headroom is available as soon as it is needed to meet capacity requirements.  
14 These portfolios provide the most stringent cost competitiveness tests for Site C  
15 by advancing low cost natural gas-fired generation capacity.

16 The cost competitiveness of Site C is evaluated using two different methods of  
17 portfolio analysis:

- 18 1. The first method is a unit cost comparison whereby the cost of Site C is  
19 compared to the cost of similar sized blocks of energy and capacity provided by  
20 alternative resources. The block comparison compares Site C to its alternatives  
21 over their project lives and demonstrates the long term value of Site C.
- 22 2. The second method creates and evaluates portfolios using the linear  
23 optimization model (System Optimizer) that selects the optimal combinations of  
24 resources over a 30-year planning horizon under different assumptions and  
25 constraints. The analysis using System Optimizer is a more sophisticated

---

<sup>28</sup> The Site C cost used in the analysis does not include sunk costs.

1 approach and provides additional information not captured by the simple unit  
2 cost comparison, including:

- 3 ▶ Timing of resource additions and associated capital expenditures
- 4 ▶ Effects of resource additions to the overall system and the system load  
5 resource balance over the planning horizon
- 6 ▶ Expected operating costs and economic dispatches reflecting the manner in  
7 which the resources will be operated
- 8 ▶ Electricity market trade benefits depending on the flexibility of the overall  
9 portfolio

10 The portfolios analyzed in this section assume DSM at the Option 2/DSM Target  
11 savings level. The cost competitiveness of Site C compared to DSM Option 3 is  
12 analyzed in section [6.3](#).

13 The simple unit cost comparison is presented in section [6.4.2](#). Portfolio analysis  
14 using System Optimizer is presented in section [6.4.3](#) and section [6.4.4](#) for the base  
15 assumptions and sensitivity tests, respectively. Section [6.4.5](#) describes other  
16 technical benefits of Site C. Comparisons of the environmental and economic  
17 development attributes for portfolios with and without Site C are presented in  
18 section [6.4.6](#) and section [6.4.7](#), respectively. Conclusions are presented in  
19 section [6.4.8](#).

## 20 **6.4.2 Unit Cost Comparison**

21 The alternatives to Site C are composed of multiple available resources, as most  
22 alternatives are not capable of delivering comparable amounts of energy and  
23 dependable capacity on their own. To facilitate a unit cost comparison with Site C, a  
24 block of Clean Generation Portfolio and a block of Clean + Thermal Generation  
25 Portfolio both making up to Site C's 5,100 GWh/year of energy and 1,100 MW of  
26 dependable capacity are created and the adjusted UECs are compared. Two  
27 variations of the Clean + Thermal Generation Portfolio are considered. One variation

1 uses the entire 7 per cent non-clean headroom of six SCGTs around F2024 together  
 2 with Revelstoke Unit 6 to meet the 1,100 MW capacity requirement. The other  
 3 variation replaces two of the SCGTs with GMS Units 1-5 Capacity Increase. The  
 4 adjusted UEC costs for all four portfolios are listed in [Table 6-5](#), showing that Site C  
 5 is lower cost than the alternative portfolios.

6 **Table 6-5 Comparison of Adjusted UECs**

	Site C	Clean Generation Block	Clean + Thermal Generation Block (Revelstoke Unit 6 and 6 SCGTs)	Clean + Thermal Generation Block (Revelstoke Unit 6, GMS and 4 SCGTs)
\$/MWh	94 <sup>29</sup>	153	128	130

7 It should be noted that the adjusted UECs<sup>30</sup> for the Clean Generation and the Clean  
 8 + Thermal Generation blocks shown in [Table 6-5](#) differ from the adjusted UECs  
 9 described in Chapter 3. For comparison purposes, the cost of capacity resources  
 10 required to make clean or renewable IPP resources have Site C’s equivalent  
 11 capacity are included in the adjusted UECs shown in [Table 6-5](#). UECs in this chapter  
 12 add capacity costs for resource options that do not have dependable capacity, while  
 13 UECs in Chapter 3 reduce the cost of resource options which do deliver dependable  
 14 capacity by the cost of avoided capacity options. The net effect is roughly equivalent  
 15 for both analysis techniques. The adjusted UECs in Chapter 3 also have not  
 16 reflected network upgrade costs (estimated at \$6/MWh).

17 [Table 6-6](#), [Table 6-7](#) and [Table 6-8](#) show the resources, which make up the Clean  
 18 Generation and Clean + Thermal Generation portfolio blocks, and their associated  
 19 costs. These blocks predominately consist of wind resources to provide energy. In  
 20 the Clean Generation Portfolio block, Revelstoke Unit 6, GMS Units 1-5 Capacity

<sup>29</sup> This is Site C’s unit energy cost (excluding sunk cost) adjusted to Lower Mainland before taking into account a capacity credit. The corresponding cost after a capacity credit is \$83/MWh.

<sup>30</sup> Adjusted UEC is the appropriate measure to use when comparing resource options as it adjusts the generation resources to be a common firm energy product delivered to BC Hydro’s major load centre, the Lower Mainland. Adjusted UECs are calculated based on the firm energy provided by the resource options, and adjustments are made to reflect delivery costs to the Lower Mainland, wind integration costs (where applicable), capacity credit, soft costs and time of delivery of the energy.

---

1 Increase and pumped storage are added to the block to make the capacity  
2 equivalent to Site C. To account for the energy losses associated with pumped  
3 storage, this block requires 364 GWh/year of additional energy resources. In the  
4 Clean + Thermal Generation Portfolio blocks, SCGTs partly make up the capacity  
5 need comparable to Site C. As described in section [6.2](#), BC Hydro would plan on  
6 SCGTs to run about 18 per cent of the time if used as a capacity/peaking resource.  
7 As a result, SCGTs would contribute towards the 5,100 GWh/year of energy to be  
8 equivalent to Site C, and thus the need for clean or renewable energy such as wind  
9 would be reduced to 4,180 GWh/year and 4,490 GWh/year for the six SCGTs and  
10 the four SCGTs blocks, respectively.

1  
2

**Table 6-6 Block Details and UEC Calculations for Clean Generation Portfolio**

Clean Generation				
Project Name	Dependable Capacity (MW)	Annual Firm Energy (GWh)	Adjusted Unit Energy Cost (\$F2013/MWh)	Total Cost (\$F2013M)
<b>Energy Costs</b>				
<i>MSW2_LM</i>	25	211	90	19
<i>Wind_PC28</i>		591	121	71
<i>Wind_PC21</i>		371	123	46
<i>Wind_PC13</i>		541	123	67
<i>MSW1_VI</i>	12	101	123	13
<i>Wind_PC19</i>		441	124	55
<i>Wind_PC16</i>		377	126	48
<i>Wind_PC14</i>		527	127	67
<i>Wind_PC10</i>		1023	129	132
<i>Wind_PC15</i>		382	130	50
<i>Wind_PC20</i>		609	131	80
<i>Wind_VI12</i>		151	131	20
<i>Wind_VI14</i>		113	132	15
<i>REV6 Variable Costs (see note 1)</i>	n/a	26	12	0
<i>GMS Variable Costs (see note 2)</i>	n/a	0	0	0
<i>PS Variable Costs (see note 3)</i>	n/a	(364)	19	7
<i>Weighted Average excluding capacity resources</i>	n/a	n/a	<b>125</b>	n/a
<i>Weighted Average including capacity resources</i>	n/a	n/a	<b>135</b>	n/a
<i>Sub-total</i>	36	5100	n/a	688
<b>Capacity Costs</b>				
	Dependable Capacity (MW)	Annual Firm Energy (GWh)	Unit Capacity Cost (\$F2013/kW-year)	Total Cost (\$F2013M)
<i>REV6 Fixed Costs</i>	488	n/a	50	24
<i>GMS Fixed Costs</i>	220	n/a	35	8
<i>PS Fixed Costs</i>	500	n/a	124	62
<i>Sub-total</i>	1208	n/a	78	94
<b>Total</b>				
	1244	5100	<b>153</b>	<b>782</b>
Note:				
1. REV6 variable cost include variable OMA and water rentals.				
2. GMS variable cost include variable OMA and water rentals.				
3. Pumped Storage variable cost include variable OMA and water rentals. The cost of energy losses is included in the total cost of the clean resources that would be used to serve those losses.				
4. UECs include a soft cost adder of 5%, wind integration cost where applicable, adjustment for time of delivery, a regional transmission cost adder of \$6/MWh, and the cost of delivery to the lower mainland.				



1  
2  
3

**Table 6-7 Block Details and UEC Calculations for Clean + Thermal Generation Portfolio (Revelstoke Unit 6 and 6 SCGTs)**

Clean + Thermal Generation (No GMS, 6 SCGTs)				
Project Name	Dependable Capacity (MW)	Annual Firm/Effective Energy (GWh)	Adjusted Unit Energy Cost (\$F2013/MWh)	Total Cost (\$1000)
<b>Energy Costs</b>				
<i>MSW2_LM</i>	25	211	90	19
<i>Wind_PC28</i>		591	121	71
<i>Wind_PC21</i>		371	123	46
<i>Wind_PC13</i>		541	123	67
<i>MSW1_VI</i>	12	101	123	13
<i>Wind_PC19</i>		441	124	55
<i>Wind_PC16</i>		377	126	48
<i>Wind_PC14</i>		527	127	67
<i>Wind_PC15</i>		382	130	50
<i>Wind_PC20</i>		609	131	80
<i>REV6 Variable Costs (see note 1)</i>	n/a	26	12	0
<i>SCGT Variable Costs (see note 2)</i>	n/a	924	66	61
<i>Weighted Average excluding capacity resources</i>	n/a	n/a	<b>124</b>	n/a
<i>Weighted Average including capacity resources</i>	n/a	n/a	<b>113</b>	n/a
<i>Sub-total</i>	36	5101	n/a	575
<b>Capacity Costs</b>				
	Dependable Capacity (MW)	Annual Firm Energy (GWh)	Unit Capacity Cost (\$F2013/kW-year)	Total Cost (\$F2013M)
<i>REV6 Fixed Costs</i>	488	n/a	50	24
<i>SCGT Fixed Costs</i>	588	n/a	88	52
<i>Sub-total</i>	1076	n/a	71	76
<b>Total</b>				
	1112	5101	<b>128</b>	651
Note:				
1. REV6 variable cost include variable OMA and water rentals.				
2. SCGT variable costs include variable OMA, fuel cost and GHG cost.				
3. UECs include a soft cost adder of 5%, wind integration cost where applicable, adjustment for time of delivery, a regional transmission cost adder of \$6/MWh, and the cost of delivery to the lower mainland.				

1  
2  
3

**Table 6-8 Block Details and UEC Calculations for Clean + Thermal Generation Portfolio (Revelstoke Unit 6, GMS and 4 SCGTs)**

Clean + Thermal Generation (With GMS, 4 SCGTs)				
Project Name	Dependable Capacity (MW)	Annual Firm/Effective Energy (GWh)	Adjusted Unit Energy Cost (\$F2013/MWh)	Total Cost (\$1000)
<b>Energy Costs</b>				
<i>MSW2_LM</i>	25	211	90	19
<i>Wind_PC28</i>		591	121	71
<i>Wind_PC21</i>		371	123	46
<i>Wind_PC13</i>		541	123	67
<i>MSW1_VI</i>	12	101	123	13
<i>Wind_PC19</i>		441	124	55
<i>Wind_PC16</i>		377	126	48
<i>Wind_PC14</i>		527	127	67
<i>Wind_VI14</i>		113	132	15
<i>Wind_PC11</i>		473	133	63
<i>Wind_PC09</i>		713	133	95
<i>REV6 Variable Costs (see note 1)</i>	n/a	26	12	0
<i>GMS Variable Costs (see note 2)</i>	n/a	0	0	0
<i>SCGT Variable Costs (see note 3)</i>	n/a	616	66	41
<i>Weighted Average <u>excluding</u> capacity resources</i>	n/a	n/a	<b>125</b>	n/a
<i>Weighted Average <u>including</u> capacity resources</i>	n/a	n/a	<b>117</b>	n/a
<i>Sub-total</i>	36	5102	n/a	598
<b>Capacity Costs</b>				
	Dependable Capacity (MW)	Annual Firm Energy (GWh)	Unit Capacity Cost (\$F2013/kW-year)	Total Cost (\$F2013M)
<i>REV6 Fixed Costs</i>	488	n/a	50	24
<i>GMS Fixed Costs</i>	220	n/a	35	8
<i>SCGT Fixed Costs</i>	392	n/a	88	34
<i>Sub-total</i>	1100	n/a	60	66
<b>Total</b>				
	1136	5102	<b>130</b>	665
Note:				
1. REV6 variable cost include variable OMA and water rentals.				
2. GMS variable cost include variable OMA and water rentals.				
3. SCGT variable costs include variable OMA, fuel cost and GHG cost.				
4. UECs include a soft cost adder of 5%, wind integration cost where applicable, adjustment for time of delivery, a regional transmission cost adder of \$6/MWh, and the cost of delivery to the lower mainland.				

---

**1 6.4.3 Portfolio Analysis using System Optimizer – Base Case**

2 This analysis evaluates the cost competitiveness of Site C by comparing the PV cost  
3 of portfolios with and without Site C using the System Optimizer. Positive values  
4 indicate that the portfolio with Site C has lower costs than the alternative portfolio. All  
5 costs are in \$F2013. [Figure 6-6](#) shows the base assumptions/conditions used for the  
6 portfolios analyzed in this section. <sup>31</sup>

---

<sup>31</sup> For 30-year portfolio analysis, DSM savings were extended from the underlying 20-year DSM options using two methods: 1) reflecting the most current thinking where the last year of cumulative savings was held to be constant; and 2) savings continue to grow based on the rate of growth averaged over the last five years. Portfolios comparing DSM options used the “constant savings” assumption. For the rest of the analysis, the earlier “extrapolation” assumption was used. When creating portfolios to stress test the cost-effectiveness of Site C, the “extrapolation” assumption was used as it gives advantage to the alternatives of Site C by allowing them to be built later given higher level of DSM savings.

1  
2

**Figure 6-6 Base Modelling Assumptions Used for the Site C Portfolio Analysis**

<b>Modelling Map</b>				
<u>Uncertainties/Scenarios</u>				
Market Prices	Scenario 2 Low	Scenario 1 Mid	Scenario 3 High	
Load Forecast	Low	Mid	High	
DSM deliverability	Low	Mid	High	
LNG Load Scenarios	Prior to Expected LNG	800 GWh	3000 GWh	6600 GWh
<u>Resource choices</u>				
Usage of 7% non-clean	Yes	No		
DSM Options	DSM Option 1	DSM Target/ Option 2	DSM Option 3	
Site C (all units in) timing	F2024	F2026	No Site C	
<u>Modelling Assumptions and Parameters</u>				
BCH/IPP Cost of Capital	5/7	5/6		
Pumped Storage as Option	Yes	No		
Site C Capital Cost		Base	Base plus 10%	
Wind Integration Cost	\$5/MWh	\$10/MWh	\$15/MWh	
	shows the modeling assumptions			

3 [Table 6-9](#) shows the difference in the PV cost between the without Site C vs. Site C  
 4 portfolios. [Table 6-9](#) shows that Site C has a cost advantage at its earliest ISD,  
 5 saving approximately \$630 million and \$150 million in PV as compared to the Clean  
 6 Generation and Clean + Thermal Generation portfolios, respectively.

7 Site C’s cost advantage increases with a F2026 ISD. However, this does not take  
 8 into account any potential costs of project delay other than inflation, which additional  
 9 costs would reduce the PV cost differential for the Site C F2026 ISD.

1 **Table 6-9 Benefit of Site C**

Portfolio Type	Site C Timing	Difference in PV Cost (Portfolio without Site C minus with Site C) (\$F2013 million)
Clean Generation portfolio	F2024	630
	F2026	880
Clean + Thermal Generation portfolio	F2024	150
	F2026	390

2 It should be noted that the partial replacement of the dependable capacity provided  
 3 by Site C with SCGTs would use up all of the 7 per cent non-clean or renewable  
 4 headroom. As a result, BC Hydro’s ability to use natural gas-fired generation for  
 5 contingency resource planning purposes is forgone. This forgone value is not  
 6 captured in the portfolio analysis undertaken.

7 **6.4.4 Portfolio Analysis using System Optimizer - Sensitivities**

8 In addition to the base assumptions/conditions analyzed, the cost competitiveness of  
 9 Site C was tested for: 1) different BC Hydro/IPP cost of capital differential scenario;  
 10 2) market price scenario; 3) Site C capital cost scenario; and 4) wind integration cost  
 11 scenario. These four sensitivity analyses were based on a Site C ISD of F2024  
 12 (except for the capital cost sensitivity analysis, which also included an analysis  
 13 based on a Site C ISD of F2026). The performance of Site C in large gap and small  
 14 gap scenarios are also investigated.

15 **6.4.4.1 Cost of Capital Differential**

16 As described in section 3.2.2, the base assumption for cost of capital is 5 per cent  
 17 for BC Hydro and 7 per cent for clean or renewable IPPs. A sensitivity test was  
 18 performed assuming 6 per cent cost of capital for IPPs, effectively reducing the cost  
 19 of capital differential from 2 per cent to 1 per cent. In this sensitivity test, the Site C  
 20 portfolio maintains a cost advantage although the benefit of Site C portfolio is  
 21 reduced from \$630 million to \$420 million for the Clean Generation alternative

1 portfolio and from \$150 million to \$20 million for the Clean + Thermal alternative  
2 portfolio.

#### 3 **6.4.4.2 Market Prices**

4 Market Scenario 1 is the base assumption used in the Site C analysis so far. Among  
5 the five market scenarios described in Chapter 5, it has the highest likelihood  
6 (60 per cent). In this section, the cost competitiveness of Site C is tested in a high  
7 market (Scenario 3) and a low market (Scenario 2) price scenario.

8 The PV benefits of Site C over the Clean Generation and Clean + Thermal  
9 Generation portfolios are shown in [Table 6-10](#). In comparison to the base case, the  
10 benefits of Site C are larger in the high market (with a projected spot market forecast  
11 of about US\$43/MWh in F2024), and smaller in the low market scenario (with a  
12 projected spot market price of about \$24/MWh (USD) in F2024).<sup>32</sup> In the low market  
13 sensitivity case which only has a 20 per cent likelihood, Site C is still more cost  
14 competitive than the Clean Generation Portfolio without Site C but is marginally less  
15 cost competitive than the Clean + Thermal Generation Portfolio without Site C. In  
16 this latter case, lower gas prices favour the thermal alternative while the energy  
17 surplus that comes with Site C in its early years is now sold at a lower market price.

18 Note that BC Hydro has conservatively assigned no value to surplus capacity.  
19 Surplus capacity would have some value. In the recent John Hart Replacement  
20 Project CPCN proceeding, BC Hydro provided evidence that while the market value  
21 of capacity is uncertain because the current market in the WECC region is illiquid,  
22 BC Hydro estimated a range of market values of \$75/kW-year to about  
23 \$110/KW-year, based on recent Booneville Power Administration (**BPA**) tariffs,  
24 transaction and market analysis. BC Hydro further estimates that U.S. market  
25 access transmission constraints could reduce the market value of capacity to  
26 \$37/kW-year for the low end of the market range.

---

<sup>32</sup> No GHG regulation and natural gas prices at \$3 MMBTu continue for the entire forecast period.

1  
2

**Table 6-10 Sensitivity of Site C Benefit to Market Prices**

Difference in PV Cost (Portfolio without Site C minus with Site C) (\$F2013 million)	Market Scenario 3 <sup>33</sup> (15% likelihood)	Base Case: Market Scenario 1 <sup>34</sup> (60% likelihood)	Market Scenario 2 <sup>35</sup> (20% likelihood)
Clean Generation Portfolio	830	630	450
Clean + Thermal Generation Portfolio	470	150	(90)

3 **6.4.4.3 Site C Cost of Capital**

4 As outlined in section 3.2.2 and section 8.2.6, the Site C cost estimate is a AACE  
 5 Class 3 cost estimate, and includes an appropriate level of contingency to reflect  
 6 uncertainty in future conditions. To test the sensitivity of Site C to capital costs,  
 7 BC Hydro evaluated a set of portfolios with the Site C capital cost of \$7.9 billion plus  
 8 10 per cent, consistent with the capital cost sensitivities in generation project CPCN  
 9 applications with the BCUC. The costs of all other resources are held constant.

10 [Table 6-11](#) shows that with the plus 10 per cent capital cost sensitivity, Site C with  
 11 an ISD of F2026 remains more cost competitive than the Clean Generation Portfolio  
 12 and the Clean + Thermal Generation Portfolio both without Site C. For an ISD of  
 13 F2024, Site C is still more cost competitive than the Clean Generation Portfolio  
 14 without Site C but at a disadvantage to the Clean + Thermal Generation Portfolio  
 15 without Site C.

---

<sup>33</sup> High market prices.

<sup>34</sup> Mid market prices.

<sup>35</sup> Low market prices.

1  
2

**Table 6-11 Sensitivity of Site C Benefit to Capital Cost Increase**

Portfolio Type	Site C Timing	Difference in PV Cost (Portfolio without Site C minus with Site C) (\$F2013 million)
Clean Generation portfolio	F2024	360
	F2026	650
Clean + Thermal Generation portfolio	F2024	(120)
	F2026	170

3 **6.4.4.4 Wind Integration Cost**

4 As described in section 3.4.1.4 and section 4.3.4.5, the base assumption for wind  
 5 integration cost is \$10/MWh. For the purpose of testing the sensitivity of the cost  
 6 competitiveness of Site C, wind integration costs of \$5/MWh and \$15/MWh were  
 7 also modelled. The analysis shows that based on an ISD of F2024, the PV benefits  
 8 of Site C for the Clean Generation Portfolio would decrease from \$630 million to  
 9 \$530 million for a wind integration cost of \$5/MWh, and increase from \$620 million to  
 10 \$720 million for a wind integration cost of \$15/MWh.

11 **6.4.4.5 Large and Small Gaps**

12 In this analysis, the cost competitiveness of Site C under large gap and small gap  
 13 conditions, both assuming no LNG, are tested:

- 14 • Large gap conditions are defined as high load forecast (about P90) with low  
 15 level of DSM savings (DSM target at P10)
- 16 • Small gap conditions are defined as low load forecast (about P10) and low level  
 17 of DSM savings (DSM target at P10). As discussed in section 3.3.1, a reduced  
 18 load forecast impacts DSM economic potential.


19 Both conditions have a low probability of occurring (10 per cent each).

20 [Figure 6-7](#) and [Figure 6-8](#) shows the load-resource gap for both of these conditions  
 21 prior to adding Site C. [Table 6-12](#) summarizes the PV benefits for portfolios with




1 Site C over portfolios without Site C under these conditions. The PV benefits of  
 2 Site C increase with the size of the gap. Site C is at a cost disadvantage to  
 3 alternative portfolios in the small gap conditions; however, the small gap scenario  
 4 has almost no load growth after DSM for most of the 30-year planning horizon.

5 **Figure 6-7 Energy Load Resource Balance for**  
 6 **Large, Mid and Small Gap**



1  
2

**Figure 6-8 Capacity Load Resource Balance for Large, Mid and Small Gap**



3  
4

**Table 6-12 Sensitivity of Site C Benefit to Gap Condition**

Difference in PV Cost (Portfolio without Site C minus with Site C) (\$F2013 million)	Large-Gap (10% likelihood)	Base Case: Mid-Gap (80% likelihood)	Small-Gap (10% likelihood)
Clean Generation Portfolio	See Note 1	630	(1,040)
Clean + Thermal Generation Portfolio	2,260	150	(1,280)

5 Note

6 1: As discussed in section 6.9, the large gap scenario is considered as contingency conditions. As concluded in  
7 section 6.2, natural gas-fired generation within the 7 per cent non-clean headroom would be used for these  
8 conditions and therefore Clean-Only portfolios are not created for this gap. The benefits for Site C are  
9 expected to be higher in the Clean Only Portfolios than the Clean + Thermal Portfolios.

10 While LNG proponents have the choice of whether to self-serve or request service  
11 from BC Hydro, to the extent that LNG proponents take service, BC Hydro reviewed  
12 Expected LNG load in the context of Site C. [Table 6-13](#) shows that the benefits of  
13 the portfolio with Site C would increase when Expected LNG load is considered. This  
14 is because Expected LNG advances the need for: 1) new energy resources after

1 implementation of the DSM target and EPA renewals from F2027 to F2022; and  
 2 2) new capacity resources from F2021 to F2020.

3 **Table 6-13 Sensitivity of Site C Benefit to LNG**  
 4 **Scenario**

Portfolio Type	LNG Scenario	Difference in PV Cost (Portfolio without Site C minus with Site C) (\$F2013 million)
Clean Generation portfolio	No LNG	630
	Expected LNG level	1,850
Clean + Thermal Generation portfolio	No LNG	150
	Expected LNG level	1,260

5 **6.4.5 Other Technical Benefits**

6 Both the Clean Generation and Clean + Thermal Generation portfolios rely  
 7 significantly on intermittent clean or renewable resources for the energy contribution  
 8 (particularly in the portfolios without Site C). Many clean or renewable energy  
 9 resources – such as wind or run-of-river hydro – are intermittent as their generation  
 10 varies with natural factors, such as river flows or wind speeds. As a result,  
 11 intermittent resources cannot be economically dispatched in response to changes in  
 12 market prices. To integrate these clean or renewable resources into the BC Hydro  
 13 system and meet electricity demand, this variability must be backed up by  
 14 dispatchable capacity. As described in the following sub-sections and section [6.9](#),  
 15 the ability for the existing BC Hydro system to shape, firm and integrate such  
 16 resources is limited.

17 **6.4.5.1 Dispatchability**

18 Site C provides dispatchable<sup>36</sup> capacity, which means that Site C can be dispatched  
 19 to meet the load, and generate power when market pricing is high and stop  
 20 generation when pricing is low, providing additional value to BC Hydro’s ratepayers.

---

<sup>36</sup> A resource whose output can be adjusted to meet various conditions including fluctuating customer demand, weather changes, outages, market price changes and non-power considerations.

---

1 As a dispatchable resource, Site C supplies ancillary benefits to the electric system  
2 including shaping and firming capability to integrate clean or renewable intermittent  
3 resources. The value of shaping within a month is reflected in the System Optimizer  
4 modelling, but the benefits of firming and inter-month shaping is not captured.

#### 5 **6.4.5.2 Wind Integration Limit**

6 A preliminary analysis has been completed to determine the maximum amount of  
7 wind power that can be integrated into the current BC Hydro power system without  
8 impacting the reliability and security of the system. The analysis is based on the  
9 assumption that only dispatchable generation from automatic generation control  
10 (**AGC**) plants can be used to manage wind variability and ramps.

11 The analysis is based on actual hourly system operation data, including load,  
12 generation, maximum/minimum generation limits, outages and tie line schedules, for  
13 the period October 2007 to September 2008. Actual wind data is not used in this  
14 analysis, but instead the assumption is made that the intra hour wind power  
15 fluctuations may range from minimum to maximum output (worst case scenario) and  
16 that the dispatchable resources have to be able to respond to these fluctuations.

17 The analysis shows that the system is most constrained during the freshet period,  
18 when the available dispatchable AGC generation drops to approximately 3,000 MW.  
19 Therefore 3,000 MW has been adopted as the current wind integration limit. This  
20 preliminary analysis does not consider transmission constraints, market constraints  
21 for the surplus wind energy, or trade-offs with spilling and/or wind curtailment. Since  
22 the analysis is based on historical data, it also does not include a build-out of the  
23 BC Hydro system, which would include Mica Units 5 and 6, Revelstoke Units 5 and  
24 6, and Site C. BC Hydro will continue to refine the understanding of its wind  
25 integration limit and explore resources and methods (e.g., spilling/curtailment) that  
26 can enhance integration capability.


---

1 If Site C were not built, resource alternatives (mostly wind) would gradually utilize  
2 some of the remaining integration capability of the system and additional integration  
3 capability would eventually be required. [Figure 6-9](#) shows the increase in modeled  
4 installed capacity over time, from wind resources for the Clean Generation portfolio  
5 with a mid gap, no LNG scenario and no Site C. The increase in wind installed  
6 capacity would be advanced if the gap were larger. The estimated wind integration  
7 limit shown in the figure has the limitations as described in the previous paragraph  
8 and does not reflect any increase in integration capability that may come with the  
9 addition of pumped storage units to the portfolio.

10 On the other hand, a separate preliminary analysis shows that the addition of Site C  
11 could increase the wind integration limit by up to 900 MW. However, the overall  
12 effects on the wind integration limit given the recent and future planned capacity  
13 additions as well as the potential addition of LNG load have not been concluded.

1  
2  
3

**Figure 6-9 Modelled Installed Wind Capacity under the Clean Generation, Mid Gap, without LNG Scenario and no Site C**



4 **6.4.6 Environmental Attributes**

5 Portfolios with and without Site C were compared based on their environmental  
6 attributes. [Table 6-14](#) lists the environmental attributes for the Site C, the Clean  
7 Generation and both Clean + Thermal Generation portfolios used in the unit cost  
8 comparison presented in section [6.4.2](#).

9 The advanced level of project definition for Site C allows a high level of accuracy in  
10 determining its footprint. In contrast, portfolios without Site C are populated with  
11 “typical” projects with estimated footprints. As a result, the environmental attributes  
12 presented in this section compare defined attributes for Site C to representative  
13 estimates for clean or renewable IPPs. The actual difference in attributes between  
14 portfolios cannot be known with certainty. The portfolio values include the impacts of  
15 associated transmission requirements to the POI.

1  
2  
3

**Table 6-14 Environmental Attributes for the Site C, Clean Generation and Clean + Thermal Generation Portfolios**

Category	Indicator	Units	Classification	Clean Portfolio	Clean + Thermal (6 SCGT)	Clean + Thermal (4 SCGT)	Site C Portfolio
Land	Footprint	hectares	n/a	2,555	1,768	2,067	5,661
Freshwater	Affected Stream Length	kilometers	n/a	–	–	–	123
	Reservoir Aquatic Area	ha	n/a	–	–	–	9,310
Atmosphere	GHG emissions	tonnes/year , thousands	Carbon dioxide equivalent	217	657	511	–
	Air Contaminant Emissions	tonnes/year , thousands	Oxides of nitrogen	0.3	0.6	0.5	–
			Carbon monoxide	0.0	1.3	0.9	–

4 **Land and freshwater footprint:** [Table 6-14](#) shows that all four portfolios have land  
5 footprints, although Site C has a larger land footprint than portfolios without the  
6 project. Since the Clean Generation and the Clean +Thermal Generation portfolios  
7 contain a high percentage of onshore wind generation, the Site C portfolio also has a  
8 larger freshwater footprint than the portfolios that do not include Site C.

9 The land and freshwater footprint of Site C reservoir represents a conversion of  
10 habitat from terrestrial and river environments to a reservoir environment, and not a  
11 loss of productive environment. This may not be the case with other portfolios based  
12 on alternative resources. As a result, portfolios with Site C include the creation of a  
13 9,310 ha reservoir, while portfolios without Site C do not. It should be noted that  
14 pumped storage, an alternative capacity rich option and net energy consumer, is  
15 assumed to occur on existing water bodies with no reservoir footprints. This is likely  
16 a conservative assumption as no pumped storage project has been permitted in B.C.  
17 to date.

18 The differences in land and freshwater footprint are highly dependent on the mix of  
19 energy resources. The portfolios generally include a majority of wind energy. If these

1 portfolios had a higher proportion of run-of-river resources (as was the result of  
2 BC Hydro's recent calls for power), it is likely that the portfolios of alternatives would  
3 have a comparable or larger footprint than the Site C portfolio as wind and biomass  
4 resources generally have smaller footprints per unit energy delivered than either  
5 Site C or run-of-river hydro. It is also important to note that the land footprints in  
6 [Table 6-14](#) consist of the footprints for the primary generation site, transmission and  
7 road to the POI. For hydroelectric projects such as Site C and run-of-river resources,  
8 this footprint includes the fuel collection footprint (i.e., the water). For other available  
9 resource options such as natural gas-fired generation or biomass, the fuel collection  
10 footprint is not included in the land footprint.

11 **GHG Emissions:** The GHG emissions shown in [Table 6-14](#) represent planning-level  
12 estimates of GHG emissions during the operating phases of the projects. The Site C  
13 portfolio has lower operational GHG emissions than the portfolios not including  
14 Site C. The Clean Generation portfolio selects a municipal solid waste (**MSW**)  
15 resource option, which includes GHG emissions from fuel combustion. The Clean +  
16 Thermal Generation portfolio has the highest level of GHG emissions due to the  
17 combustion of natural gas.

18 **Local Air Emissions:** [Table 6-14](#) shows that the Site C portfolio has lower local air  
19 emissions than the portfolios not including Site C. The Clean Generation portfolio  
20 selects both wood based biomass and MSW resource options, which create local air  
21 emissions from fuel combustion. The Clean + Thermal Generation portfolio includes  
22 biomass resources as well as natural gas-fired generation and, as a result, has the  
23 highest level of local air emissions.

24 **Location of Portfolio Footprint:** The locations of the environmental attributes used  
25 in the analysis of alternatives were compared between portfolios. Site C is located  
26 solely in the Peace Region, whereas the alternative resources are located in a range  
27 of locations across the province. However, as shown in [Table 6-6](#), [Table 6-7](#) and  
28 [Table 6-8](#), the portfolio analysis identifies wind as the primary source of energy to



1 the system, with more than 90 per cent of wind resources located in the Peace  
 2 Region. As a result, more than 50 per cent of the land footprint in both the Clean and  
 3 the Clean + Thermal Generation portfolios would be located in the Peace Region,  
 4 with the balance in the Lower Mainland and on Vancouver Island.

5 **6.4.7 Economic Development Attributes**

6 Portfolios with and without Site C were compared based on their economic  
 7 development attributes, including jobs and GDP. [Table 6-15](#) lists the economic  
 8 development attributes for Site C and for the Clean Generation and Clean + Thermal  
 9 Generation portfolios, based on a Site C equivalent 5,100 GWh/year (1,100 MW)  
 10 block of power. The portfolio values include the impacts of associated transmission  
 11 requirements to the point of interconnection.

12 **Table 6-15 Economic Development Attributes for the**  
 13 **Site C, Clean Generation and Clean +**  
 14 **Thermal Generation Portfolios**

Indicator	Units	Classification	Clean Portfolio	Clean + Thermal (6 SCGT)	Clean + Thermal (4 SCGT)	Site C Portfolio
Construction period GDP	dollars, millions	Total	2,513	1,616	1,706	3,676
Construction period employment	jobs	Total	30,788	19,872	20,963	44,249
Operations period employment	jobs per year	Total	998	985	958	74

15 The Site C portfolio shows higher measures of economic development during  
 16 construction as compared to portfolios without Site C. Jobs and GDP related to  
 17 construction are higher for the Site C portfolio, due to the high job intensity during  
 18 the construction period. Jobs and GDP during operations are lower for the Site C  
 19 portfolio, as a result of the low operating costs for Site C. It should be noted that  
 20 these are high level estimates and that the exact differences between economic  
 21 development attributes are uncertain.

---

### 1 **6.4.8 Conclusions**

2 The IRP analysis demonstrates that, even in a no LNG load scenario, portfolios with  
3 Site C are more cost competitive than portfolios without Site C regardless of whether  
4 the 7 per cent natural gas-fired generation headroom is used or not. Although the  
5 analysis shows that Site C yields even more benefits when a later F2026 ISD was  
6 tested in a no LNG load scenario, given Site C's long lead time, uncertainties around  
7 DSM delivery as well as LNG load, it is prudent to continue with the current  
8 regulatory window and maintain Site C's earliest ISD of F2024.

9 A number of sensitivity cases were examined with a no LNG scenario. These  
10 include: 1) large gap (i.e., high load growth with low DSM savings level) and small  
11 gap (low load growth with low DSM savings level); 2) high and low market price  
12 scenarios; 3) a smaller cost of capital differential between BC Hydro projects (such  
13 as Site C, Revelstoke Unit 6, GMS Units 1-5 Capacity Increase) and IPP projects;  
14 4) higher capital costs for Site C; and 5) different wind integration costs. In general,  
15 these sensitivities result in a PV advantage for Site C as compared to viable  
16 alternatives in all but the small gap scenario. The small gap scenario is a low  
17 probability scenario (about P10) that would effectively see negligible load growth  
18 after DSM for the planning period examined (virtually no load growth until F2024;  
19 and about 4,000 GWh/year net growth from F2024 to F2033). When compared to  
20 the Clean + Thermal Generation Portfolio, Site C has a slight cost disadvantage in a  
21 low market price scenario (with a low likelihood of 20 per cent) and in a scenario  
22 where Site C's capital cost is increased by 10 per cent.

23 In addition to providing energy and capacity, Site C also provides ancillary benefits  
24 to the electric system including shaping and firming capability, and capability to  
25 integrate intermittent resources. Although generally the analysis shows greater  
26 environmental footprints with Site C than its alternative portfolios, the economic,  
27 ancillary and economic development benefits associated with Site C continue to  
28 support the recommendation to pursue this project. Site C also aligns with the *CEA*

---

1 93 per cent clean or renewable energy target and legislated *GGRTA* GHG reduction  
2 targets. As a result, BC Hydro believes that Site C provides the best combination of  
3 financial, technical, environmental and economic development attributes.

4 The development of Site C is subject to completing the environmental assessment  
5 certification, fulfilling the Crown's duty to consult and, if appropriate, accommodate  
6 First Nations which may be potentially affected by Site C, and a decision by the B.C.  
7 Government to proceed to full project construction.

8 Conclusions in this Site C section supports Recommended Action 6 as described in  
9 section 8.2.6.

## 10 **6.5 LNG and the North Coast**

### 11 **6.5.1 Introduction**

12 The key IRP question for BC Hydro regarding LNG and the North Coast is: What  
13 actions are needed and what supply options need to be maintained to ensure that  
14 BC Hydro is able to supply Expected LNG, additional LNG load above expected and  
15 other loads in the North Coast while considering the specific planning challenges of  
16 this region? This section focuses on the incremental generation and transmission  
17 resources needed to serve LNG load given the context of maintaining the current  
18 DSM target and advancing Site C being for ISD.

19 As described in Chapter 2, based on discussions with the B.C. Government and  
20 LNG proponents, the Expected LNG electrification load is 3,000 GWh/year  
21 (360 MW). However, this level of load is uncertain so a range of 800 GWh/year  
22 (100 MW) to 6,600 GWh/year (800 MW) is considered. The majority of the LNG  
23 loads are expected to be located on the North Coast and several projects could be  
24 online as early as F2020. In addition, there is potential for other non-LNG loads,  
25 primarily in the mining sector, that could also increase load in the region.

26 The North Coast area in northwestern B.C. is connected to the rest of the BC Hydro  
27 system via a 450 km long single radial 500 kV transmission line from Prince George

1 to Terrace. Beyond Terrace, the area is served by two 287 kV transmission lines -  
2 one that extends to Kitimat and another that extends to Prince Rupert. When the  
3 287 kV NTL project is completed in May 2014, service will be extended north to Bob  
4 Quinn and will interconnect the Forrest Kerr, McLymont, and Volcano hydroelectric  
5 projects, and several potential mines.


6 The North Coast region poses unique planning challenges for BC Hydro due to its  
7 remote location, large range of load potential and limited local clean or renewable  
8 capacity resources. Although the existing 500 kV transmission supply has  
9 maintained a high level of reliability, increasing loads will require a trade-off between  
10 adding local natural gas-fired generation versus the ability to reinforce the existing  
11 transmission system to the main grid. These challenges require a flexible supply  
12 strategy that can meet the range of increasing load levels in a timely and  
13 cost-effective manner.

#### 14 **6.5.2 Additional Resource Requirement to Serve LNG and Other Loads**

15 Supply requirements are initially assessed by reviewing the BRP LRBs with various  
16 LNG load levels (see [Figure 6-10](#) and [Figure 6-11](#)). For the 3,000 GWh/year  
17 Expected LNG level, there is a short-term firm energy gap before Site C's earliest  
18 ISD of about 1,500 GWh/year, and a short-term capacity gap before Site C's earliest  
19 ISD of F2024 of up to 600 MW. The higher amounts of LNG loads considered (up to  
20 6,600 GWh/year (800 MW)) would increase energy requirements before Site C's  
21 earliest ISD to 5,200 GWh/year and the need for dependable capacity resources to  
22 1,000 MW.


1  
2  
3

**Figure 6-10 System Energy Surplus/Deficit after BRP Implementation under Different LNG Load Scenarios**



1  
2  
3

**Figure 6-11 System Capacity Surplus/Deficit after BRP Implementation under Different LNG Load Scenarios**



4 In addition to system energy and capacity needs, there would also be requirements  
 5 to increase the capacity of the transmission tie between the North Coast and the  
 6 integrated system, or alternatively develop dependable generation capacity locally in  
 7 the North Coast. As described in section 2.5.1 and shown in Figure 2.10, the N-0,  
 8 non-firm transfer capability of the existing radial transmission system could be  
 9 exceeded under a number of LNG and mining load scenarios.

10 **6.5.3 North Coast Transmission Planning Considerations**

11 Managing the maintenance outages on the cascading 5L61, 62, and 63 circuits that  
 12 span from Prince George to Terrace is critical to maintaining reliable supply to the  
 13 North Coast. The maintenance outages using standard methods can last six to  
 14 seven days and are currently accomplished without interrupting the supply by:  
 15 scheduling the outages in the spring when customer loads are generally low;

---

1 coordinating with planned outages at industrial facilities; and utilizing local  
2 generation facilities including Prince Rupert GS, Falls River GS (hydroelectric) and  
3 relying upon contracted delivery from Rio Tinto Alcan's Kemano facility. The local  
4 load resource balance is tight even during spring load conditions, leaving little  
5 margin to continue this process with additional loads being added to the area.

6 Options to accommodate maintenance line outages with future LNG loads and  
7 increased mining activity include reduction of outage duration, additional  
8 coordination of outages with customers including LNG facilities, capital spending at  
9 existing BC Hydro facilities in the North Coast to ensure reliability, and the  
10 development of new local dependable capacity in the form of natural gas-fired  
11 generation. Run-of-river IPP facilities scheduled to come online within the next few  
12 years would also facilitate line maintenance, especially if carried out during the  
13 freshet season.

14 The radial transmission system is also prone to system disturbances such as line to  
15 ground faults, the sudden loss of a large load due to an outage at an industrial  
16 customer facility, or the loss of generation due to a forced outage of a local  
17 generator or the transmission line that interconnects the generator. Often in these  
18 cases, injection of instantaneous reactive power is required to maintain acceptable  
19 voltages and system stability. Reactive power support can be delivered by power  
20 electronics controlled devices or local generators. The reactive power contribution of  
21 the local generators is maximized when the units are operated in the synchronous  
22 condenser mode

23 The LNG loads would likely be in the Kitimat region or the Prince Rupert region of  
24 the North Coast. The 287 kV transmission line 2L99 interconnects Minette  
25 Substation (**MIN**) at Kitimat to SKA at Terrace which is the terminus of the 500 kV  
26 line from the integrated system. 2L99 is near end of life and would likely require  
27 upgrades or replacement regardless of LNG loads at Kitimat. Other regional  
28 upgrades, such as providing voltage support at MIN, may also be needed. Similarly,

1 some upgrades may be required on the 287 kV circuit 2L101 that interconnects  
2 Prince Rupert to Skeena. Regional transmission requirements have not been  
3 analyzed in the IRP and will be studied as part of LNG load interconnection studies.  
4 Consideration may be given to strategically siting natural gas-fired generation in  
5 these sub-regions of the North Coast in order to avoid or defer transmission  
6 upgrades, to enhance the reliability of supply, and to support the regional  
7 transmission system.

#### 8 **6.5.4 Supply Options**

9 The options available to supply future load growth in the North Coast are:

- 10 (a) Integrated System Supply: Strengthen the transmission connection between the  
11 North Coast and the rest of the integrated system to facilitate the transfer of  
12 capacity necessary to meet future load growth. Generation resources can be  
13 developed anywhere within the integrated system with this supply option;
- 14 (b) Local Supply: Develop capacity resources locally in the North Coast; and
- 15 (c) A combination of (a) and (b): Carrying out some cost-effective transmission  
16 upgrades along with the development of local capacity resources.

17 Options (a) and (b) are discussed below while the results of portfolio analysis used  
18 to determine the cost-effectiveness of the options are presented in section [6.5.5](#).

##### 19 (a) Integrated System Supply

20 An integrated system supply solution requires the transmission system to be  
21 capable of transferring adequate capacity to meet future North Coast loads.


22 [Figure 6-12](#) compares the transfer capability of the existing 500 kV transmission  
23 line from Prince George to Terrace against potential North Coast load  
24 combinations. It shows that the capacity of the existing line would provide  
25 adequate capacity only in a mid load forecast without any LNG. Any other  
26 combination of loads where LNG loads are as expected or where mining loads  
27 are higher than expected would result in the capability of the transmission line



1 being exceeded. Most of the load scenarios considered can be accommodated  
 2 by non-wire upgrades to the existing transmission line to increase its capacity.  
 3 Non-wire upgrades consisting of adding series and shunt compensation and  
 4 transformation capacity would cost approximately \$150 million. The upgrades  
 5 would increase the total transfer capability to around 1,380 MW and would take  
 6 three to four years to complete. A second line from Prince George is required  
 7 only in a scenario where high mining load is combined with a high LNG load. A  
 8 second 500 kV line would have a cost more than \$1.1 billion<sup>37</sup> and have a lead  
 9 time of eight to 10 years.

10  
 11  
 12

**Figure 6-12 North Coast Load Scenarios and the Capability of the Transmission Connection to the Integrated System**



<sup>37</sup> All cost values presented (UECs, UCCs, capital costs) are expressed in \$F2013.

1 Transmission capacity additions allow the generation resources required to  
2 serve LNG and other North Coast loads to be located anywhere within the  
3 integrated system. This flexibility to locate resources would allow BC Hydro to  
4 develop the most cost-effective resources, including capacity options such as  
5 Revelstoke Unit 6, GMS Units 1-5 Capacity Increase and natural gas-fired  
6 generation, to meet need. It also facilitates the use of bridging resources and  
7 non-firm/market energy to bridge short-term capacity and energy requirements.  
8 In general, bridging capacity and additional non-firm/market energy reliance  
9 that are utilized only during years of need is the lowest cost option as opposed  
10 to building new resources that could add to a surplus position when another  
11 large resource such as Site C is developed in subsequent years.

12 (b) An alternative to system supply is to build dependable capacity locally in the  
13 North Coast. The dependable capacity options available in the North Coast are  
14 limited. Pumped storage hydro resource potential in the region is not  
15 cost-effective, as identified in the study described in Appendix 3A-30. As shown  
16 in section 3.4, biomass potential in the region is limited, leaving natural  
17 gas-fired generation as the only available cost-effective option. The British  
18 Columbia Energy Objectives Regulation described in section 1.2.3 exempting  
19 natural gas-fired generation used to serve LNG export facilities from the *CEA*  
20 93 per cent clean or renewal objective enables BC Hydro to serve LNG load  
21 with a greater proportion of natural gas-fired generation. Natural gas-fired  
22 generation also has a relatively short construction lead time once permitting is  
23 secured. The addition of natural gas-fired generation in the North Coast would  
24 provide the following benefits:

- 25 1. Support north coast transmission capability and reliability and address the  
26 issues identified in section [6.5.3](#)
- 27 2. Meet broader system needs for dependable generation capacity

1           3. Provide dispatchable dependable capacity to integrate renewable energy  
2           resources in the region

3           4. Provide the ability to dispatch off in favour of system surplus and low cost  
4           market resource usage at times of the year when there is sufficient  
5           transmission access

6 Natural gas-fired generation can be developed in the North Coast to provide  
7 dependable generation capacity:

- 8       • (B1) with clean or renewable energy resources sourced locally or from the  
9       integrated system
- 10     • (B2) with natural gas-fired units being relied upon for firm energy and operated  
11     as base-loaded units or
- 12     • (B3) with natural gas-fired units being relied upon for firm energy but mostly  
13     dispatched off in favour of lower cost surplus or non-firm energy from the  
14     integrated system or market imports

### 15   **6.5.5           Evaluation of North Coast Supply Options**

16 Portfolio analysis was carried out using the 3,000 GWh/year Expected LNG load and  
17 the 6,600 GWh/year high LNG load to identify the cost-effectiveness of the various  
18 supply alternatives given the context of maintaining the current DSM target and  
19 advancing Site C for earliest ISD.

20 An initial set of portfolios was evaluated to identify the optimal approach towards  
21 meeting LNG and other North Coast loads in the period prior to in-service of Site C.  
22 As described previously, the 3,000 GWh/year Expected LNG level will create a  
23 short-term capacity gap before Site C of up to 600 MW and an energy shortfall of  
24 about 1,500 GWh/year within the BC Hydro integrated system. Several options were  
25 evaluated: 1) Integrated system supply with short-term energy and capacity needs  
26 bridged until Site C's ISD; 2) Integrated system supply with short-term energy needs  
27 bridged until Site C's ISD and with Revelstoke Unit 6 built to meet capacity needs;

1 3) Dependable capacity in the form of natural gas-fired generation developed locally  
2 with short-term energy needs bridged until Site C's ISD; and 4) Dependable capacity  
3 in the form of natural gas-fired generation developed locally along with renewable  
4 energy resources built to meet energy deficit prior to Site C's ISD.

5 [Table 6-16](#) summarizes the portfolio PV of the cost savings, and shows that both  
6 energy and capacity bridging yields significant savings. In planning to average water  
7 conditions at its Heritage hydroelectric facilities, BC Hydro could encounter a market  
8 exposure of about 4,100 GWh/year should critical water conditions occur. BC Hydro  
9 contemplated the pros and cons of additional non-firm/market reliance by looking at  
10 the effects of water variability, market conditions, market access, operational  
11 constraints and additional planning uncertainties. It concluded that the  
12 aforementioned energy gap of approximately 1,500 GWh/year in an expected LNG  
13 load scenario could be filled using additional non-firm/market reliance and would still  
14 result in a highly reliable system if the reliance was limited to the short time frame  
15 leading up to the ISD of Site C. However, BC Hydro is of the view that relying on the  
16 electricity markets for capacity poses a greater reliability risk in comparison to  
17 energy reliance. The reliability risks of additional capacity reliance over and above  
18 the market reliance contemplated in a no LNG scenario as described in  
19 section [6.9.3.1](#). need to be weighed against the potential cost savings. Therefore, a  
20 supply strategy between 1) and 3) seems most prudent allowing BC Hydro to take  
21 advantage of the cost savings offered by bridging using non-firm/market energy  
22 while developing some dependable capacity to ensure reliability. Non-wire upgrades  
23 of the existing 500 kV line to the North Coast and advancing gas-fired capacity in the  
24 North Coast are required to facilitate this intermediate strategy.

1  
2  
3

**Table 6-16 Comparison of Alternative Supply Options to meet needs prior to Site C in-service**

<b>Supply Options</b>	<b>Integrated system supply with short-term energy and capacity needs bridged until Site C in-service</b>	<b>Integrated system supply with short-term energy needs bridged until Site C in-service and with Revelstoke Unit 6 built to meet capacity needs</b>	<b>Dependable capacity in the form of gas-fired generation developed locally with short-term energy needs bridged until Site C in-service</b>	<b>Dependable capacity in the form of gas-fired generation developed locally along with renewable energy resources built to meet energy deficit prior to Site C in-service</b>
Incremental Energy Resource for LNG before Site C	Bridging	Bridging	Bridging	Build B.C. Clean Resources
Incremental Capacity Resource for LNG before Site C	Bridging	Build Revelstoke Unit 6	Build four 100 MW SCGTs to match LNG capacity requirement	Build four 100 MW SCGTs to match LNG capacity requirement
Series Compensation of WSN-SKA transmission Line	Required	Required	Not required	Not required
Portfolio PV cost relative to Reference Portfolio* (\$ million)	(490)	(120)	(280)	Reference Portfolio

4 \*in all of these portfolios, clean or renewable energy resources backed by SCGTs in the North Coast for capacity  
5 are assumed to be built for need subsequent to Site C.

6 BC Hydro also carried out analysis to determine the longer term supply strategy to  
7 supply LNG, subsequent to Site C’s earliest ISD. The high LNG load was used to  
8 identify the relative costs of the various supply alternatives. This analysis assumed a  
9 reliance on non-firm/market energy of 1,500 GWh/year prior to Site C’s ISD, the  
10 implementation of the non-wire upgrades of the existing 500 kV line, and  
11 development of natural gas-fired generation in the North Coast given the benefits of  
12 pursuing those actions as demonstrated in the previous analysis.

---

1 The higher level of LNG load considered would result in 3,600 GWh/year of  
2 additional energy resources being required as well as 400 MW of additional capacity  
3 over and above the requirements for expected LNG. The supply options considered  
4 for this analysis were: (i) Integrated system supply facilitated by the addition of a  
5 second 500 kV line; (ii) Local gas-fired capacity with renewable energy resources  
6 sourced locally or from the integrated system; (iii) Local gas-fired capacity with units  
7 being relied upon for firm energy and operated as base-loaded units; and (iv) Local  
8 gas-fired capacity with the units being relied upon for firm energy but mostly  
9 dispatched off in favour of lower cost surplus or non-firm energy from the integrated  
10 system or market imports. [Table 6-17](#) summarizes the key characteristics and  
11 trade-off parameters of these options.

12 Development of local gas-fired generation that is relied upon for firm energy and  
13 dependable capacity and dispatching the units economically provides the most  
14 cost-effective supply to the LNG loads. Gas-fired generation can be dispatched off  
15 during times when non-firm energy is available and/or market electricity prices are  
16 low such as during the freshet or light load hours of other months. This option avoids  
17 the footprint of new transmission lines and associated clean or renewable resources  
18 across BC Hydro's service area. However, market imports used to displace gas-fired  
19 generation may attract GHG liability in the future. The potential cost of such liability  
20 is not reflected in the analysis.

1  
2  
3

**Table 6-17 Comparison of Alternative Options to meet long-term System Needs due to High LNG**

<b>Supply Options</b>	<b>(i) Integrated system supply facilitated by the addition of a second 500 kV line</b>	<b>(ii) Local gas-fired capacity with renewable energy resources sourced locally or from the integrated system</b>	<b>(iii) Local gas-fired capacity with units being relied upon for firm energy and operated as base-loaded units</b>	<b>(iv) Local gas-fired capacity with the units being relied upon for firm energy but mostly dispatched off in favour of lower cost surplus or non-firm energy from the integrated system or market imports</b>
Incremental Energy Resource for LNG	Renewable energy resources distributed across the integrated system	Renewable energy resources distributed across the integrated system	Generation from gas-fired units located in the North Coast	Combination of gas-fired generation, non-firm energy from the integrated system and market energy
Transmission Requirements over and above non-wire upgrades of existing transmission line	Second 500 kV line from Prince George to Terrace	None	None	None
Incremental Capacity Resource for LNG	Capacity resources distributed across the integrated system	Gas-fired capacity in the North Coast	Gas-fired capacity in the North Coast	Gas-fired capacity in the North Coast
Reliability and Maintenance Flexibility	Provides N-1 service to the region as well as comparatively highest degree of maintenance flexibility	High level of reliability and maintenance flexibility	Higher level of reliability and same level of maintenance flexibility in comparison to (ii) or (iv)	High level of reliability and maintenance flexibility

Supply Options	(i) Integrated system supply facilitated by the addition of a second 500 kV line	(ii) Local gas-fired capacity with renewable energy resources sourced locally or from the integrated system	(iii) Local gas-fired capacity with units being relied upon for firm energy and operated as base-loaded units	(iv) Local gas-fired capacity with the units being relied upon for firm energy but mostly dispatched off in favour of lower cost surplus or non-firm energy from the integrated system or market imports
Portfolio PV (\$M) cost relative to Reference Portfolio	Reference Portfolio	(710)	(2100)	(2900)
GHG emissions ('000 tonnes in F2041) relative to Reference Portfolio	Reference Portfolio	0	700	0
Total Water and Land Footprint (ha in F2041) relative to Reference Portfolio	Reference Portfolio	(2,700)	(5,500)	(7,400)

1 **6.5.6 Conclusions**

2 Given the current DSM target and Site C being advanced for its earliest ISD, the  
 3 most cost-effective option for BC Hydro to supply the Expected LNG load of  
 4 3,000 GWh/year before Site C is with energy delivered from the integrated system,  
 5 including market energy reliance. Non-wire upgrades of the existing 500 kV line  
 6 facilitates system delivery of energy and capacity and allows BC Hydro to derive  
 7 benefits of bridging short-term needs to serve expected LNG. Therefore, it is prudent  
 8 to advance the non-wire upgrade Prince George to Terrace Capacity (**PGTC**) project  
 9 to maintain an in-service date of F2020. BC Hydro should also consider gas-fired



---

1 generation in the North Coast for meeting incremental capacity need from Expected  
2 LNG given the need to limit reliance on market capacity and the benefits gas-fired  
3 generation offers in facilitating maintenance outages and increasing voltage stability.

4 The higher level of LNG load considered would result in 3,600 GWh/year of  
5 additional energy resources being required as well as 400 MW of additional capacity  
6 over and above the requirements for Expected LNG. The analysis of supply options  
7 illustrated that siting natural gas-fired generation locally and dispatching them off in  
8 favour of non-firm energy or market imports is the least cost option. However, this  
9 supply option may expose BC Hydro to GHG liability related to imported energy. The  
10 cost advantage of additional natural gas-fired generation in the North Coast needs to  
11 be weighed against such considerations. The development of clean or renewable  
12 energy resources along with clean capacity resources should be left as an option  
13 should higher levels of LNG loads materialize.

14 The analysis shows that a second 500 kV line to the North Coast to facilitate  
15 integrated system supply is not cost-effective at the load levels analyzed. It does  
16 however provide the North Coast with a high level of reliability and maybe cost  
17 competitive should even higher amounts of LNG and other industrial loads  
18 interconnect in the North Coast.

19 Conclusions in this LNG and the North Coast section support Recommended  
20 Actions 10, 11 and 12 as described in section 8.3.

## 21 **6.6 Fort Nelson Supply and Electrification of the Horn** 22 **River Basin**

### 23 **6.6.1 Introduction**

24 Three HRB scenarios (High, Mid and Low), along with the Fort Nelson mid load  
25 forecast, were used in the IRP analysis. The key IRP questions to address  
26 Fort Nelson supply and the electrification of the HRB are:

- 
- 1 • What actions are required to meet the load growth in Fort Nelson considering  
2 the solution for Fort Nelson may be influenced by the HRB industrial loads and  
3 supply options?
  - 4 • What is BC Hydro's strategy to prepare for significant potential load growth in  
5 the combined Fort Nelson and HRB regions? What actions are prudent in the  
6 absence of load certainty?
  - 7 • What should BC Hydro do to respond to the subsection 2(h) *CEA* energy  
8 objective to encourage the switching from one kind of energy source to another  
9 that decreases GHG emissions in B.C.? This analysis considers the amount of  
10 CO<sub>2</sub> that is produced in the HRB under various gas production/energy supply  
11 scenarios and reduction opportunities.

12 Additional considerations are: 1) the effect of electricity service to the HRB on the  
13 *CEA* 93 per cent clean or renewable energy objective; 2) the potential for additional  
14 benefits related to electricity supply to the HRB, such as access to new clean or  
15 renewable energy resources; and 3) the costs of providing such electricity supply to  
16 HRB.

17 The IRP analytical approach for addressing the Fort Nelson/HRB region's electricity  
18 supply requirements was to consider the LRB assumptions for these regions, both  
19 combined and separately, within various appropriate transmission networks that  
20 BC Hydro would be responsible for serving. The following sections describe the  
21 strategies for providing electricity service to the Fort Nelson and HRB regions, the  
22 analytical approach for assessing those strategies and the results of the analysis.

23 A detailed description of the approach and analysis is provided in Appendix 2E.

## 24 **6.6.2 Load Scenarios**

25 Three HRB electric load scenarios (High, Mid and Low), along with the Fort Nelson  
26 mid load forecast, were used in the IRP analysis. Details of the Fort Nelson load  
27 forecasts and the HRB electrification load scenarios are provided in section 2.5.2

---

1 and Appendix 2E. The Fort Nelson load forecast is driven by a combination of  
2 residential, commercial and industrial growth; while the HRB scenarios are driven by  
3 potential gas production levels.

### 4 **6.6.3 Alternative Supply Strategies**

5 Three basic supply strategies were considered for the Fort Nelson/HRB analysis.  
6 They are:

- 7 • Alternative 1: Supplying clean or renewable electricity to these regions by  
8 connecting these regions to the BC Hydro integrated system
- 9 • Alternative 2: Supplying electricity from within the region
- 10 • Alternative 3: Supplying only Fort Nelson within the region (no supply service to  
11 the HRB)

12 Some of these basic alternative supply strategies were broken down further for a  
13 total of nine alternative supply strategies considered in the analysis, as described in  
14 [Table 6-18](#).

1  
2

**Table 6-18 Summary of Fort Nelson/HRB Electricity Supply Strategies**

Supply Alternative	Strategy Description
Alternative 1 BC Hydro Integrated System	Supply Fort Nelson/HRB with clean or renewable energy from the BC Hydro integrated system. With this strategy; a new transmission line would be built from Peace Region to Fort Nelson and then up to the HRB. This would connect Fort Nelson and the HRB to BC Hydro's existing integrated system.
Alternative 2A Regional-Based: One Fort Nelson/HRB Network	<p>With this strategy, the two regions of Fort Nelson and HRB would be connected via a new transmission line. Generation could be developed in one area to service both regions or plants could be dispersed in both regions. Various gas-fired generation options were examined, along with the option of combining local clean and gas-fired generation resources.</p> <p>The different options considered as part of this strategy include:</p> <ul style="list-style-type: none"> <li>• <b>2A1:</b> Supply with gas co-generation                             <ul style="list-style-type: none"> <li>– One co-generation plant in Fort Nelson</li> <li>– Two co-generation plants in Fort Nelson and HRB</li> </ul> </li> <li>• <b>2A2:</b> Supply with CCGT in Fort Nelson</li> <li>• <b>2A3:</b> Supply with local clean energy (wind) and backed by SCGT in Fort Nelson</li> </ul>
Alternative 2B Regional-Based: HRB alone	<p>With this strategy, both regions are supplied separately and from within their own region. A gas-fired cogeneration plant would service the HRB, and a new SCGT would service Fort Nelson or increased service from Alberta.</p> <p>The different options considered as part of this strategy include:</p> <ul style="list-style-type: none"> <li>• <b>2B:</b> Supply HRB as a separate network with a gas co-generation plant supply Fort Nelson with either:                             <ul style="list-style-type: none"> <li>– a new SCGT in Fort Nelson, or</li> <li>– increased transmission service from Alberta</li> </ul> </li> </ul>
Alternative 3 Supply Fort Nelson alone; HRB producer self-supply	<p>With this strategy, the HRB region is not serviced by BC Hydro but instead companies would self-supply their energy requirements. A new SCGT would service Fort Nelson or increased service from Alberta.</p> <p>The different options considered as part of this strategy include:</p> <ul style="list-style-type: none"> <li>• <b>3:</b> No service to HRB; supply Fort Nelson :                             <ul style="list-style-type: none"> <li>– a new SCGT in Fort Nelson</li> <li>– increased transmission service from Alberta</li> </ul> </li> </ul>

3 **6.6.4 Fort Nelson/HRB Analysis**

4 The analysis presented in this section analyzes the economic costs of the alternative  
 5 supply strategies for the Fort Nelson/HRB region as well as the costs and benefits of  
 6 electrifying the HRB. The effect of the alternative supply strategies on BC Hydro's

1 ability to meet the 93 per cent clean or renewable objective and the risk of stranded  
2 assets is also assessed.

3 The modelling for the Fort Nelson/HRB analysis is done over a very long period (to  
4 2060), which is effectively 43 years from the assessed earliest ISD of new  
5 transmission needed to connect Fort Nelson/HRB to BC Hydro's integrated system.  
6 This approach allows for the testing of whether facilities such as transmission lines  
7 may become stranded, and if the effect, when considered today, is material. It also  
8 provides insight into how the overall system might operate, and issues that might  
9 arise. Where relevant, the three load scenarios identified earlier were analyzed  
10 across Market Scenarios 1, 2 and 3 as described in Chapter 5 and are presented for  
11 each of the strategies analyzed.

#### 12 **6.6.4.1 Economic Analysis**

13 The base metric for much of the Fort Nelson/HRB economic analysis is the PV of the  
14 cost to serve the electricity load. The costs are expressed in PV in 2013 constant  
15 dollars for the period 2014 to 2060. Other assumptions include:

- 16 • For cogeneration plants, BC Hydro sells heat at 85 per cent of producer  
17 avoided cost
- 18 • BC Hydro operates any required transmission networks
- 19 • The benefits of interconnecting the North Peace River cluster, estimated at  
20 \$150 million as discussed in section [6.8.5.2](#), are used to offset the cost of a  
21 Northeast Transmission Line (**NETL**)

22 Total costs for the above combination of scenarios and strategies are presented in  
23 [Table 6-19](#). It is important to note that comparing these costs cannot be done in  
24 isolation of the overall context, and other analysis. There is a significant difference in  
25 loads served across some of the strategies, and such differences must be  
26 considered when making any conclusions based in whole or in part on these costs.

---

1 The following observations can be made on the results of the economic analysis:

- 2 • Where BC Hydro is serving the full Fort Nelson/HRB region, (Columns [1] – [6]):
    - 3 ▶ A local clean or renewable energy strategy of wind, backed by SCGTs
4 (Alternative 2A3, Column [2]) is never the low cost strategy
  - 5 ▶ A supply strategy based on clean energy from the BC Hydro integrated
6 system (Alternative 1, Column [1]) is relatively more expensive than other7 strategies under Market Scenarios 1 and 2, while the difference in cost is8 significantly reduced or eliminated under Market Scenario 3  - 9 ▶ Strategies relying on gas-fired generation are clearly the lowest cost under
10 Market Scenarios 1 and 2, while the difference in cost is significantly11 reduced or eliminated under Market Scenario 3  - 12 ▶ Within the gas-fired generation strategies, the CCGT strategy (Column [5])
13 is in the middle of the cost range. This is because it does not rely on heat14 sales, as cogeneration facilities do. Cogeneration strategies with the highest15 heat sales load (in this set of analysis represented by Alternative 2A1(2),16 Column [4]), show up as having the best cost characteristics
- 17 • Where BC Hydro is serving Fort Nelson/HRB separately with different regional
- 18 networks (the HRB strategy Alternative 2B), (Column [6]):
- 19 ▶ Analytical trends for cogeneration are similar to the full Fort Nelson/HRB
20 network, but the costs are allocated across a smaller load

1  
2

**Table 6-19 BC Hydro's Total Cost to Serve Fort Nelson and HRB (PV \$2013 million)**

Column number	1	2	3	4	5	6	7 <sup>38</sup>
<b>Supply Alternative / Load &amp; Market Scenario</b>	1: BC Hydro System	2A3: Wind & SCGT	2A1(1): One Cogen Plant	2A1(2): Two Cogen Plants	2A2: CCGT	2B(1): One Co-gen, New FN SCGT	3(1): New FN SCGT
	With Sequestration						
<b>High Load Scenario; Market Scenario 1</b>	12,197	11,154	9,560	8,322	9,847	8,853	392
<b>High Load Scenario; Market Scenario 2</b>	12,075	9,966	7,341	6,518	8,051	6,675	312
<b>High Load Scenario; Market Scenario 3</b>	12,360	12,440	11,960	10,272	11,789	10,562	480
<b>Mid Load Scenario; Market Scenario 1</b>	6,821	6,765	5,574	5,109	5,792	4,852	392
<b>Mid Load Scenario; Market Scenario 2</b>	6,698	6,049	4,328	4,004	4,710	3,854	312
<b>Mid Load Scenario; Market Scenario 3</b>	6,983	7,540	6,921	6,303	6,961	5,930	480
<b>Low Load Scenario; Market Scenario 1</b>	3,085	3,480	2,737	2,374	2,737	2,377	392
<b>Low Load Scenario; Market Scenario 2</b>	2,963	3,150	2,171	2,042	2,171	1,947	312
<b>Low Load Scenario; Market Scenario 3</b>	3,246	3,837	3,349	2,734	3,349	2,844	480

3 **6.6.4.2 GHG Emission Production Analysis**

4 In this section, the amounts of vented CO<sub>2</sub> are analyzed as well as the costs and  
5 benefits of moving to supply strategies with clean energy.

<sup>38</sup> For Fort Nelson supply, the lower of the two cost estimates was used. Refer to section [6.6.4.4](#) for more information.

1 The raw natural gas in the HRB has a relatively high concentration (12 per cent) of  
2 CO<sub>2</sub> which is currently removed from the natural gas during processing and vented  
3 to the atmosphere. In the case of the overall Fort Nelson/HRB analysis, the results  
4 include vented CO<sub>2</sub> from both formation and combustion processes. In the case of  
5 BC Hydro's share, the results are limited to the combustion-related CO<sub>2</sub>. The  
6 modelled results for GHG production, as measured by volume in Megatonnes  
7 (MT)/year of vented CO<sub>2</sub>, are insensitive to different Market Scenarios, because the  
8 resources and dispatch are the same for each strategy analyzed.

#### 9 *Overall Fort Nelson/HRB GHG Emission Production*

10 As shown in [Table 6-20](#), GHG emission production is highest with a strategy where  
11 the HRB development proceeds assuming producers self-supply their electricity and  
12 heat requirements, and there is no CO<sub>2</sub> sequestration (Column [8]). In this strategy,  
13 the PV of MT of GHG is 273 MT, 195 MT and 98 MT for the high, mid and low load  
14 scenarios, respectively. If carbon capture and sequestration (CCS) of formation CO<sub>2</sub>  
15 could be successfully implemented, those amounts can be reduced to 121 MT,  
16 86 MT and 44 MT for the high, mid and low scenarios, respectively (Column [7]).  
17 This indicates that approximately 55 per cent of the overall GHG vented can be  
18 eliminated without BC Hydro's involvement, again assuming that sequestration can  
19 be successfully implemented.

20 With BC Hydro's involvement by supplying the region clean or renewable energy via  
21 the integrated system, the overall vented GHG can be further reduced to 73 MT,  
22 59 MT and 31 MT for the high, mid and low scenarios, respectively (Column [1]).  
23 This represents a cumulative reduction of approximately 70 per cent (middle of  
24 [Table 6-19](#)), or an incremental improvement after sequestration of 30 to 40 per cent  
25 (bottom of [Table 6-19](#)).

26 The BC Hydro strategies based on gas-fired generation have less of an incremental  
27 impact; for example, the CCGT strategy (Column [5]) provides an incremental  
28 improvement over the producer self-supply sequestration strategy of 4 to 7 per cent;



1 and successfully implemented cogeneration (Column [4]) somewhat higher. A  
 2 BC Hydro local area isolated network clean strategy (Alternative 2A3), Column [2])  
 3 falls in between the system clean (Column [1]) and the gas-fired strategies  
 4 (Columns [3] [6]), providing an incremental improvement over producer self-supply  
 5 sequestration strategy of approximately 15 per cent).

6 **Table 6-20 Overall Fort Nelson (FN)/HRB GHG**  
 7 **production (PV of MT)**

Column Number	1	2	3	4	5	6	7	8
Supply Alternative / Load Scenario	1: BC Hydro System	2A3: Wind & SCGT	2A1(1): One Cogen Plant	2A1(2): Two Cogen Plants	2A2: CCGT	2B(1): One Cogen, New FN SCGT	3(1): New FN SCGT	3(1): New FN SCGT
	With Sequestration							No Seq'tn
<b>CO<sub>2</sub> Vented (Formation and Combustion) (PV of MT)</b>								
High Load Scenario	73.3	99.4	120.7	110.0	112.8	115.1	121.2	273.4
Mid Load Scenario	58.7	74.1	84.2	80.2	82.0	81.3	86.2	195.0
Low Load Scenario	30.5	37.7	42.1	36.8	42.1	41.4	44.3	97.8
<b>GHG Reduction from No Sequestration (% of PV of MT)</b>								
High Load Scenario	73.2	63.7	55.8	59.8	58.8	57.9	55.7	
Mid Load Scenario	69.9	62.0	56.8	58.9	58.0	58.3	55.8	
Low Load Scenario	68.8	61.4	56.9	62.4	56.9	57.6	54.7	
<b>GHG Reduction from With Sequestration (% of PVs of MT)</b>								
High Load Scenario	39.5	18.0	0.4	9.3	6.9	5.0		
Mid Load Scenario	31.9	14.1	2.3	7.0	4.9	5.7		
Low Load Scenario	31.0	14.7	4.8	16.8	4.8	6.3		

1 *BC Hydro's Share of GHG Emission Production*

2 The CO<sub>2</sub> produced and vented from resources owned or acquired by BC Hydro is  
 3 presented in [Table 6-21](#). With these strategies, a supply strategy based on clean  
 4 energy from the BC Hydro integrated system results in the lowest GHG emissions,  
 5 even when considering the producer self-supply strategy.

6 Cogeneration strategies (Columns [3], [4], [6]) generally show higher CO<sub>2</sub> for  
 7 BC Hydro than the CCGT strategy (Column [5]). One observation that needs  
 8 mentioning is that BC Hydro's share of GHG production is not necessarily aligned  
 9 with GHG emissions from the overall system. While cogeneration strategies show  
 10 higher CO<sub>2</sub> than the CCGT strategy, much of the increase is due to the transfer of  
 11 GHG liability from the host processing plant to BC Hydro's cogeneration plant. The  
 12 cogeneration plants are less efficient for electricity production than CCGTs;  
 13 however, they provide energy via heat sales, which reduces the GHG emissions at  
 14 the host processing plant.

15 **Table 6-21 CO<sub>2</sub> Produced by BC Hydro Facilities in**  
 16 **Fort Nelson/HRB (PV of MT)**

Column Number	1	2	3	4	5	6	7	8
Supply Alternative / Load Scenario	1: BC Hydro System	2A3: Wind & SCGT	2A1(1): One Co-gen Plant	2A1(2): Two Co-gen Plants	2A2: CCGT	2B(1): One Co-gen, New FN SCGT	3(1): New FN SCGT	3(1): New FN SCGT
	With Sequestration							No Seq'tn
High Load Scenario	0.3	26.4	54.4	54.3	39.7	50.4	2.1	2.1
Mid Load Scenario	0.3	15.7	32.2	35.7	23.6	28.4	2.1	2.1
Low Load Scenario	0.3	7.5	16.9	13.4	16.9	13.2	2.1	2.1

---

1 *BC Hydro Cost per Tonne of GHG Reduction*

2 A BC Hydro clean or renewable electricity strategy as compared to any of the  
3 alternative gas-fired generation strategies can be considered as an incremental cost  
4 towards a reduction in Provincial GHG emissions.

5 [Table 6-22](#) provides the cost per tonne to take the total BC Hydro cost for each  
6 strategy and scenario that includes gas-fired generation, to the equivalent scenario's  
7 system clean strategy (notionally a cost to upgrade each BC Hydro gas generation  
8 strategy to clean electricity). For example, on the first row (High Load Scenario and  
9 Market Scenario 1), starting from Alternative 2A1(1) (the one cogen plant,  
10 Column [3]), the incremental cost per tonne to take that strategy and convert it to a  
11 system clean strategy would be \$79/tonne. The cells shaded green indicate  
12 strategies and scenarios that would benefit by being converted to system clean or  
13 renewable strategies, relative to the assumed incremental GHG costs in B.C. for  
14 each Market Scenario, as reflected in the analysis by the B.C. Carbon Tax of  
15 \$30/Tonne.

16 The results show for all Market Scenarios (1, 2 and 3):

- 17 • The additional cost for upgrading to a system clean strategy from any of the  
18 gas-fired generation strategies is generally higher than the expected GHG costs  
19 being offset
- 20 • The strategy of local clean energy with back-up gas-fired resources is economic  
21 compared to the system clean strategy in the Low Load Scenario based on the  
22 expected GHG costs being offset

1  
2  
3

**Table 6-22 Incremental Cost (\$/tonne) to Upgrade Gas-Fired Generation Strategies to a System Clean Energy Strategy**

Column Number	1	2	3	4	5	6	7	8
Supply Alternative / Load & Market Scenario	1: BC Hydro System	2A3: Wind & SCGT	2A1(1): One Co-gen Plant	2A1(2): Two Co-gen Plants	2A2: CCGT	2B(1): One Co-gen, New FN SCGT	3(1): New FN SCGT	3(1): New FN SCGT
High Load Scenario; Market Scenario 1; GHG \$30/tonne of CO <sub>2</sub>		70	79	102	90	103		
High Load Scenario; Market Scenario 2; GHG \$30/tonne of CO <sub>2</sub>		111	118	133	132	138		
High Load Scenario; Market Scenario 3; GHG \$30/tonne of CO <sub>2</sub>		27	37	69	44	66		
Mid Load Scenario; Market Scenario 1; GHG \$30/tonne of CO <sub>2</sub>		34	69	78	74	100		
Mid Load Scenario; Market Scenario 2; GHG \$30/tonne of CO <sub>2</sub>		72	104	106	115	131		
Mid Load Scenario; Market Scenario 3; GHG \$30/tonne of CO <sub>2</sub>		(6)	32	49	31	67		

Column Number	1	2	3	4	5	6	7	8
Low Load Scenario; Market Scenario 1; GHG \$30/tonne of CO <sub>2</sub>		(25)	51	84	51	85		
Low Load Scenario; Market Scenario 2; GHG \$30/tonne of CO <sub>2</sub>		4	78	100	78	109		
Low Load Scenario; Market Scenario 3; GHG \$30/tonne of CO <sub>2</sub>		(52)	24	69	24	61		

1 **6.6.4.3 CEA 93 per cent Clean or Renewable Energy Objective**

2 As noted in section [6.2](#), BC Hydro has sought to identify the optimal use of gas-fired  
 3 generation that is available under the CEA 93 per cent clean or renewable energy  
 4 objective. [Table 6-23](#) presents the effect that each of the alternative supply  
 5 strategies would have on BC Hydro’s ability to meet the 93 per cent clean or  
 6 renewable energy objective.

7 The analysis results are as follows:

- 8 • For the supply strategy based on BC Hydro supplying the region with clean  
 9 energy from the integrated system (Column [1]), BC Hydro is above the  
 10 93 per cent clean or renewable energy objective
- 11 • For the supply strategy for Fort Nelson alone (Columns [7] – [8]), BC Hydro is  
 12 above the 93 per cent clean or renewable energy objective
- 13 • For the gas-fired generation strategies (Columns [3] – [6]), BC Hydro is below  
 14 the 93 per cent clean or renewable energy objective in the mid and high load  
 15 scenarios, but above 93 per cent clean or renewable energy objective in the low  
 16 load scenario

- For Alternative 2A3 (Column [2]), regional clean or renewable energy supply with back up gas-fired resources, BC Hydro is below the 93 per cent clean or renewable only in the high load scenarios; the other two scenarios are above 93 per cent

Given that the PV costs of serving a Fort Nelson/HRB low load scenario (approximately \$350 million) based on a gas-fired generation strategy are lower relative to a system based clean energy strategy, BC Hydro may wish to preserve some of its 7 per cent non-clean headroom as an option to support supplying the Fort Nelson load growth and electrification of the HRB.

**Table 6-23 Comparison of Alternatives Against CEA 93 per cent Clean or Renewable Objective (percentage of BC Hydro System Clean Electricity, Average 2020 to 2030)**


Column	1	2	3	4	5	6	7	8
<b>Supply Alternative / Load Scenario</b>	<b>1: BC Hydro System (%)</b>	<b>2A3: Wind &amp; SCGT (%)</b>	<b>2A1(1): One Co-gen Plant (%)</b>	<b>2A1(2): Two Co-gen Plants (%)</b>	<b>2A2: CCGT (%)</b>	<b>2B(1): One Co-gen, New Fort Nelson SCGT (%)</b>	<b>3(1): New FN SCGT (%)</b>	<b>3(1): New FN SCGT (%)</b>
	With Sequestration							No Seq'tn
<b>High Load Scenario</b>	95.8	91.4	87.9	87.9	87.9	88.4	95.1	95.1
<b>Mid Load Scenario</b>	95.7	93.1	91.0	91.0	91.0	91.5	95.1	95.1
<b>Low Load Scenario</b>	95.6	94.2	93.1	93.1	93.1	93.5	95.1	95.1

**6.6.4.4 Supplying Only Fort Nelson**

Based on the mid and high load forecasts for Fort Nelson, BC Hydro will need to add new capacity resources in order to maintain N-1 level of reliability as shown in [Figure 6-13](#). Until a new supply solution is implemented, some Fort Nelson load may be subject to curtailable service. Accordingly, BC Hydro is working with the Alberta

1 Electric System Operator (**AESO**) to develop a Fort Nelson area load control  
 2 process and remedial action schemes for events of supply shortfall.

3 **Figure 6-13 Fort Nelson Peak Load Scenarios and**  
 4 **Existing Supply Capacity**



5 For meeting load up to 73 MW on a firm basis, BC Hydro could construct new  
 6 gas-fired peaking generation (i.e., SCGT) in Fort Nelson, or contract additional  
 7 Fort Nelson Demand Transmission Service (**FTS**) service from Alberta via the  
 8 AESO. The AESO indicated that it will not offer transmission service beyond 75 MW.  
 9 Analysis of the Alternative 3 – Fort Nelson alone strategies provides a comparison  
 10 between a local SCGT and increased FTS service from the AESO. [Table 6-24](#)  
 11 presents results in a format similar to that in the previous sections. For this analysis,  
 12 only the Fort Nelson mid-load forecast was considered.

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24

**Table 6-24 BC Hydro’s Total Costs (PV, \$ million, without CO<sub>2</sub> Costs)**

Supply Alternative / Load & Market Scenario	3(1): New Fort Nelson SCGT	3(2): AESO
Mid Load Scenario; Market Scenario 1	392	468
Mid Load Scenario; Market Scenario 2	312	388
Mid Load Scenario; Market Scenario 3	480	556

The results suggest that selecting an SCGT is always lower cost than increased FTS reliance on Alberta. In both cases, the incremental energy served would be thermal based. If BC Hydro does not undertake a strategy that involved electrifying the Fort Nelson/HRB region, adding peaking capacity or emergency capacity to FNG to meet Fort Nelson load on a firm basis appears to be the lowest cost and preferable strategy.

**6.6.4.5 Risk Analysis**

The economic and GHG analysis presented earlier provide a range of results for differing uncertainties relating to load and market prices. This section looks at some of the residual risk elements that cannot easily be quantified in that type of analysis. The analysis looks at some of the uncertainties from a perspective of what is at risk if the conditions unfold differently than planned.

A key risk from a long-term planning perspective is the risk of stranded assets. For example, for the supply strategy based on clean or renewable energy from the BC Hydro integrated system, if the Fort Nelson/HRB load that is planned for does not materialize, then the risk consequence would be:

- Low for the clean resources that may have been acquired, as these resources could be redeployed for meeting general integrated system load growth or supply retirements
- High for NETL, as there would be no alternative use for most of NETL (the segment between the Peace Region and North Peace Region may provide access to cost-effective clean energy resources to serve system requirements)



1 Similarly, in the case of supply strategies based on gas cogeneration plants, the risk  
 2 probability lies in the possibility that either the electrical load or the heat load does  
 3 not materialize or continue at the level expected, in which case the consequences  
 4 would be:

- 5 ▶ Very high for the cogeneration plant, which could lose one or both markets
- 6 ▶ Zero for NETL from the Peace Region to FNG, because that transmission  
 7 segment is not required

8 A comparison of stranded asset risk across the alternatives is summarized in  
 9 [Table 6-25](#).

10 **Table 6-25 BC Hydro Stranded Asset Risk Matrix**

<b>Supply Strategies / Drivers for Stranded Asset Risk</b>	<b>System Clean</b>	<b>Local Clean / SCGT</b>	<b>CCGT at Fort Nelson</b>	<b>Cogen at Fort Nelson</b>	<b>Cogen in HRB</b>
<b>HRB Electrification</b>	Yes	Yes	Yes	Yes	Yes
<b>Host Co-gen Competitiveness</b>	No	No	No	Yes	Yes
<b>Electricity Supply (capacity)</b>	Low (redeploy)	High	High	High	Very high
<b>Electricity Supply (energy)</b>	Low (redeploy)	High	Low	High	Very high
<b>GMS-NPR Transmission</b>	Low (redeploy)	Zero (N/A)	Zero (N/A)	Zero (N/A)	Zero (N/A)
<b>NPR-FN Transmission</b>	High	High	Zero (N/A)	Zero (N/A)	Zero (N/A)
<b>FN-HRB Transmission</b>	High (equal)	High (equal)	High (equal)	High (equal)	Zero (N/A)
<b>Sub-transmission</b>	High (equal)	High (equal)	High (equal)	High (equal)	High (equal)

11 If BC Hydro does not undertake a strategy that involved electrifying the  
 12 Fort Nelson/HRB region, the stranded asset risk is related to adding local generating  
 13 capacity to serve future load that does not materialize when expected. As noted in  
 14 Section 2.5.2.1, there are significant uncertainties to the mid load forecast for the  
 15 Fort Nelson/HRB region due to potential impacts from HRB development and/or  
 16 other unexpected load developments such as a restart of currently shut-down  
 17 forestry mills. These uncertainties could defer the expected capacity shortfall to

---

1 beyond F2018, or cause the shortfall to occur earlier than F2018. As such, any  
2 decision to add local generating capacity will be contingent on the load forecast  
3 becoming more certain.

#### 4 **6.6.5 Conclusions**

5 BC Hydro studied two main alternatives for supplying the combined  
6 Fort Nelson/HRB loads under mid, high and low electrification load scenarios and  
7 under Market Scenarios 1, 2 and 3. In summary, BC Hydro believes a definitive  
8 decision on whether or not to electrify the HRB is not required at this time; and that it  
9 should continue to work with the B.C. Government and industry in assessing the  
10 merits of electrifying the HRB.

11 Conclusions in this Fort Nelson section support Recommended Actions 13 and 17  
12 as described in Chapter 8.

### 13 **6.7 General Electrification**

#### 14 **6.7.1 Introduction**

15 This section addresses the implications for BC Hydro of a scenario in which B.C.  
16 Government climate policy leads to a significant increase in the use of electricity to  
17 meet energy end use demands that are currently met by fossil fuels. Electrification  
18 could take place across the economy and across the province in end uses such as  
19 space and water heating, passenger and freight vehicles, and industrial equipment  
20 such as large compressors. The major potential industrial loads in the North Coast  
21 and the Fort Nelson/HRB which could shift from energy supply by fossil fuels to  
22 electricity have already been discussed in section [6.5](#) and section [6.6](#).

23 The section 2 CEA energy objectives include B.C.'s legislated target of reducing  
24 GHG emissions by at least 33 per cent below 2007 levels by 2020 and the long term  
25 target of an 80 per cent reduction below 2007 levels by 2050. Achieving these  
26 targets will likely require large scale fuel switching to low or zero emissions energy  
27 sources such as low emission or renewable electricity. Increased energy efficiency,

1 and switching from fossil fuels with high emissions intensities to those with lower  
2 emissions intensities (i.e., coal to natural gas), will reduce emissions; however, the  
3 reductions required to get emissions to the targeted levels can likely only be  
4 achieved using low or zero emissions energy resources such as hydroelectric  
5 power, wind, solar, or fossil fuels with CCS. None of these resources can be used  
6 directly to meet energy needs such as space and water heating, industrial motor  
7 drives, and transportation. Instead they must be transformed into an energy carrier.  
8 Currently, the only commercially viable energy carrier is electricity. Therefore, large  
9 reductions in GHG emissions will require switching to electricity (i.e., “electrification”)  
10 as a way to substitute low- or zero-emissions energy for the fossil fuels that power  
11 most homes, businesses and vehicles.

12 Climate policies targeting deep GHG emission reductions could result in a significant  
13 increase in electricity demand, and BC Hydro needs to consider the resource  
14 requirement to serve this demand growth. In addition, section 18 of the *CEA*  
15 provides for regulations to enable utilities to implement programs to support projects,  
16 programs, contracts or expenditures for the purposes of reducing GHG emissions in  
17 B.C., and this could include electrification<sup>39</sup>. However, electrification will increase  
18 costs to BC Hydro’s existing ratepayers.

19 The key questions on general electrification in this IRP are:

- 20 • What is BC Hydro’s strategy (what and when) to get ready for potential load  
21 driven by general electrification? What actions (if any) are prudent now in the  
22 absence of load certainty?
- 23 • What should BC Hydro’s role be in reducing GHG emissions through  
24 electrification?

---

<sup>39</sup> To date, one regulation has been enacted under this section – the Greenhouse Gas Reduction (Clean Energy) Regulation, B.C. Reg. 102/2012.

1 To address these questions BC Hydro retained two consultants, Energy and  
2 Environmental Economics Inc. (E3) and MK Jaccard and Associates, to study the  
3 associated issues and understand the potential for climate policy driven  
4 electrification. In 2010, E3 developed two climate policy scenarios for the WECC  
5 region and estimated the resulting impact on electricity demand in B.C. Details on  
6 the E3 scenarios can be found in Appendix 6B. In 2011, BC Hydro engaged MK  
7 Jaccard and Associates to model the impact of climate policy on energy related  
8 GHG emissions in B.C. to provide further information on the end uses where  
9 electrical load could be expected to increase in response to various levels of carbon  
10 pricing. Details of the study can be found in Appendix 6C.

### 11 **6.7.2 WECC Electrification Scenarios**

12 E3 developed two climate policy scenarios, with low and high GHG emission  
13 reduction results, and evaluated how the response to these scenarios could impact  
14 energy consumption and production across the WECC region. The sector-by-sector  
15 GHG reduction assumptions made by E3 were based on expert qualitative  
16 knowledge of the relative costs of various GHG abatement measures, with  
17 conservation related savings generally coming first, and major capital stock turnover  
18 generally coming later in the modelled period.

19 E3 worked closely with BC Hydro to minimize potential double counting of GHG  
20 emission savings, because BC Hydro has already included significant DSM savings  
21 in its load forecast and has made assumptions surrounding the adoption of electric  
22 vehicles and electrification in the oil and gas industry. The GHG emission savings  
23 estimates and additional electric load were incremental to what was assumed in  
24 BC Hydro's load forecast at the time (2010 Load Forecast) and any associated GHG  
25 emission reductions associated with serving the Fort Nelson/HRB and North Coast  
26 loads. This work has not been updated but is not expected to change any of the  
27 conclusions.

---

1 In the low GHG reduction scenario, a 30 per cent reduction in GHG emissions is  
2 achieved by 2050 relative to 2008. Offsets (reductions in non-energy related  
3 emissions, or reductions in other jurisdictions) can account for one third of GHG  
4 emissions reductions; two thirds are achieved through reductions in western states  
5 and provinces' fossil fuel based GHGs. For B.C., 35 per cent of total 2050 emissions  
6 savings come from offsets.


7 In the high GHG reduction scenario, an 80 per cent reduction in GHG emissions is  
8 achieved by 2050, relative to 2008. Of the 80 per cent, 30 per cent can be  
9 accounted for by offsets and the remaining 50 per cent is achieved through  
10 reductions in western states and provinces' fossil fuel based GHGs. B.C. meets the  
11 overall GHG target with 35 per cent of 2050 total emissions savings coming from  
12 offsets.

13 E3 developed electrification scenarios for WECC and produced the corresponding  
14 load scenarios for B.C. BC Hydro then adjusted these load scenarios to load and  
15 resource requirements on the BC Hydro system as shown in [Figure 6-14](#).

16 Electrification 2 corresponds to the low GHG reduction scenario and Electrification 3  
17 corresponds to the high GHG reduction scenario.

1

**Figure 6-14 Electrification Scenarios**



2 A portion of the potential general electrification load is from the transportation sector.  
 3 The corresponding capacity requirements are significant but it is assumed that there  
 4 is opportunity to reduce this requirement by half by shifting charging to off peak  
 5 hours, for example, by encouraging the installation of a timer which prevents the  
 6 charging of vehicles during the system peak hours in the evening. Assuming that the  
 7 charging cycle of the batteries is a few hours, there should be sufficient time to re  
 8 charge the batteries overnight (outside of the system peak hours).

9 In both scenarios, electricity demand does not increase significantly until late in the  
 10 2020s. The large GHG savings that occur in the latter part of the modelled period  
 11 forecast horizon are due to major capital stock turnover, such as vehicles, building  
 12 shells and furnaces (space heating).

---

### 1 **6.7.3 Electrification Potential Review**

2 BC Hydro engaged MK Jaccard and Associates to carry out an electrification  
3 potential review: a detailed analysis of how energy demands and in particular  
4 electricity would be likely to respond to climate policies of varying strength. The  
5 analysis used the CIMS model<sup>40</sup> to produce quantitative forecasts of technology  
6 market shares, electrification abatement and electricity demand. This model is a  
7 technologically detailed model that simulates realistic turnover of capital stock (e.g.,  
8 acquisition and retirement of buildings, cars, boilers) and realistic consumer and firm  
9 decision making when acquiring new capital stock, while integrating energy supply  
10 and demand and macro economic feedbacks. A version of CIMS specific to B.C.  
11 was used to simulate the evolution of energy using technologies to 2050 in each  
12 sector for each scenario of this study.

13 Three climate policy scenarios were simulated, with a carbon price acting as a proxy  
14 for a range of climate policies. The results of the analysis are consistent with the  
15 E3 scenarios. Major conclusions included:

- 16 • Under all GHG price scenarios, the increase in electricity demand is relatively  
17 modest in early years, due to the limitations of capital stock turnover, relatively  
18 low GHG prices, and low natural gas prices
- 19 • Electrification occurs across the economy, and in particular in the natural gas  
20 sector in early years
- 21 • Vehicle penetration is relatively low, even under high GHG price scenario, due  
22 to high capital costs

### 23 **6.7.4 Analysis to Identify System Requirements**

24 Based on the two consultant studies, the findings were that electrical demand could  
25 be as much as 50 per cent higher by 2050 than in the business as usual scenario.

---

<sup>40</sup> CIMS is the name of an energy economy simulation model developed and maintained by the Energy and Materials Research Group at Simon Fraser University, B.C., Canada.

1 However, the rate of electrification is limited by capital stock turnover, and even very  
 2 stringent climate policies do not result in significant increases in demand until well  
 3 past 2020. This suggests that there will be a substantial time lag between shifts in  
 4 climate policy and the resulting electrification effects. As illustrated in [Figure 6-14](#),  
 5 potential general electrification load growth would be gradual, allowing BC Hydro to  
 6 respond to load growth through a traditional planning process. Because of this,  
 7 BC Hydro concluded that there was little benefit in analyzing the requirements for  
 8 general electrification on its own as there is little near-term effect on the LRB.

9 However, for the purposes of stress testing the potential impact of electrification on  
 10 system requirements, BC Hydro considered a scenario that combines the  
 11 requirements of electrified LNG load in the North Coast, oil and gas production in the  
 12 Northeast and general electrification. [Table 6-26](#) summarizes the load and supply  
 13 assumptions for this scenario.

14 **Table 6-26 Electrification Load Scenario Summary**

Load Assumptions	Supply Assumptions*
Mid load forecast	Clean resources from system
LNG/North Coast: Expected LNG load of 3,000 GWh/year all assumed in the North Coast	Clean energy backed by local gas peakers as required
Northeast: High gas production and electrification scenario for Fort Nelson/Horn River Basin	Clean resources from system with Northeast Transmission Line
General Electrification: Electrification 3	Clean resources from system

15 \*supply assumed mostly clean as the intent of electrification is to reduce GHG emission

16 Based on the portfolio analysis on the combined electrification scenario, BC Hydro  
 17 had sufficient amount of viable clean or renewable resources in B.C. to meet the  
 18 electrification load. However, the unadjusted UEC at the POI for the marginal energy  
 19 resource would climb to \$110/MWh by F2021, \$130/MWh by F2031 and \$200/MWh  
 20 by F2041. In addition to the gas peakers targeted to serve LNG load, additional  
 21 gas-fired generation or high cost pumped storage units would be needed by F2026  
 22 to meet capacity need. This scenario requires transmission upgrades starting in



---

1 F2023 in addition to eight new high-voltage transmission lines by F2040. When  
2 comparing this electrification scenario to the mid gap no LNG portfolio, the  
3 incremental annual cost in F2031 would be about \$2.5 billion (real \$F2013). All  
4 these costs and factors should be considered when the Province evaluates the tools  
5 available for reducing GHG emissions.

### 6 **6.7.5 Conclusions**

7 Economy wide electrification could contribute significantly to long term GHG  
8 reductions as part of a climate change strategy to achieve deep cuts in emissions,  
9 however, this would result in significant increases in electricity rates.

10 BC Hydro can support the government's Climate Action Plan by being prepared to  
11 meet the increased load associated with electrification, and by working with the B.C.  
12 Government to examine electrification through potential programs enabled by  
13 regulation under section 18 of the *CEA*. The analysis carried out for this IRP  
14 indicates that a move towards general electrification is unlikely to increase load  
15 significantly in the next 10 years, and therefore does not require BC Hydro to plan  
16 for significant near term resource additions to meet load growth from electrification

17 In the next 10 years, however, there are some preparatory actions that BC Hydro  
18 could undertake in support of government climate policy objectives:

- 19 • Continue to provide analysis and support to the B.C. Government, such as the  
20 electrification potential review carried out for this IRP that identify where  
21 electrification would be expected to occur in response to climate policy, and any  
22 analysis on the cost of electrification related policies
- 23 • Continue distribution system studies and related activities to ensure that  
24 BC Hydro is able to supply the increased loads (e.g., electric vehicles, heat  
25 pumps) that could result from significant electrification
- 26 • Continue to investigate the opportunity of managing capacity requirements from  
27 electric vehicles such as through the use of timers

1 These conclusions align with the actions presented on general electrification in  
2 section 8.5.1.

## 3 **6.8 Transmission**

### 4 **6.8.1 Introduction**

5 The transmission grid that delivers electricity to BC Hydro's customers is divided into  
6 three major infrastructure categories: 1) the high-voltage bulk transmission network,  
7 which carries high-voltage electricity from where it is generated to the transmission  
8 and switching substations in cities and towns; 2) the regional transmission network,  
9 which transfers high-voltage electricity to major delivery points around the cities,  
10 towns and industrial centres; and 3) and the distribution network, which delivers  
11 lower voltage electricity to individual customers. The IRP analysis focuses on the  
12 high-voltage bulk transmission system (primarily 230 kV and above).

13 Pursuant to subsection 3(2) of the *CEA*, the IRP is required to include a description  
14 of BC Hydro's infrastructure and capacity needs for electricity transmission over  
15 30 years. There is also a requirement in subsection 3(3) of the *CEA* to include an  
16 assessment of the potential for developing electricity generation from clean or  
17 renewable resources in B.C., grouped by geographic area (also referred to as  
18 generation clusters).

19 This IRP addresses the following transmission-related questions:

- 20 • What are the transmission requirements to support load and generation  
21 build-out in the Province?
- 22 • Whether, and to what degree, BC Hydro should take a more proactive  
23 approach to building transmission infrastructure? This proactive approach could  
24 be in response to additional need identified in different load scenarios or to  
25 pre-build transmission to areas where there are potential generation clusters.

---

1 When assessing future bulk transmission system requirements, BC Hydro considers  
2 the following:

- 3 • The need to maintain a mandatory level of reliability for customers
- 4 • Growth in demand including DSM impacts by geographic area
- 5 • Potential location and size of new generation resources
- 6 • The need to minimize electricity losses that occur when electricity is carried  
7 over long distances
- 8 • The expected retirement or refurbishment of existing transmission and  
9 generation resources

10 In addition to identifying the transmission system reinforcements required under the  
11 expected load/resource assumptions, the IRP needs to address the following risks  
12 given the long lead times required for planning, siting and constructing transmission  
13 projects, needing to ensure the system can accommodate potential future  
14 requirements and to build an efficient system:

- 15 • New demand for electricity may develop sooner than transmission lines can be  
16 built to provide the service
- 17 • Generation projects may be completed before transmission lines (which  
18 typically have longer lead times) are ready
- 19 • Generation projects may develop in a way that leads to building segmented  
20 transmission lines that are inefficient and have avoidable environmental  
21 footprints

22 The first two risks relate to having sufficient transmission capability when needed,  
23 whereas the third risk relates to having an efficient transmission system.

24 BC Hydro addresses the first two risks by analyzing transmission requirements  
25 taking into account different load scenarios requirements and contingency conditions

---

1 to identify prudent actions for preparing to serve potential larger loads. These  
2 contingency conditions include:

- 3 • an assessment of potential need to develop alternative sources of supply  
4 (transmission contingency plan) to mitigate the risk that a planned transmission  
5 project is not going to be completed in time
- 6 • An assessment of potential need to advance planned transmission projects to  
7 mitigate the risk that the projects are needed sooner than expected. BC Hydro  
8 prepares specific CRPs, which are submitted to the BCUC for approval  
9 pursuant to the Open Access Transmission Tariff (**OATT**) for the purpose to  
10 establish a queue position for a transmission service request because of the  
11 long transmission lead time. The CRP(s) submitted to the BCUC must consider  
12 scenarios that reasonably test the transmission pathways that occur based on  
13 the possibility of resources and loads in specific locations. Without transmission  
14 planning formally including the CRPs in its planning processes and ensuring  
15 that the associated transmission requirements are being maintained,  
16 BC Hydro's CRPs would be ineffectual.

17 BC Hydro addresses the third risk by analyzing the cost-effectiveness of pre-building  
18 transmission to access generation clusters and discussing the pros and cons  
19 associated with a proactive approach to advance transmission infrastructures.

20 In this section, the results of the IRP analysis on transmission requirement are  
21 presented by:

- 22 • First, examining the existing transmission infrastructure to identify the required  
23 upgrades for meeting future electricity demands under mid gap conditions in a  
24 no LNG scenario and assessing the need for transmission contingency plans
- 25 • Second, investigating the effects of the Expected LNG load on transmission  
26 infrastructures need and timing especially in the North Coast and assessing the  
27 need for transmission contingency plans

- 
- 1 • Third, examining the transmission requirements under different contingency  
2 conditions related to load and DSM uncertainty, pumped storage uncertainty,  
3 and higher than expected LNG loads on the North Coast. The results of this  
4 analysis provide a preliminary assessment of transmission implications in the  
5 CRPs.
  - 6 • Finally, analyzing the cost-effectiveness of pre-building transmission to access  
7 generation clusters

### 8 **6.8.2 Transmission Analysis: Mid Gap**

9 BC Hydro reviewed a set of portfolios that meet the mid gap conditions in a scenario  
10 without LNG, and identified the associated bulk transmission requirements<sup>41</sup>. This  
11 review led to the following conclusions:

#### 12 *North Interior Corridor*

13 Non-wire transmission upgrades, such as adding shunt compensation at Williston  
14 (**WSN**) and Kelly Lake Substation (**KLY**) and/or enhancing series compensation at  
15 Kennedy Capacitor Station (**KDY**) and McLease Capacitor Station (**MLS**), are likely  
16 sufficient to provide the needed incremental transfer capability on this path and will  
17 defer the need for new transmission lines to beyond the planning horizon. Analysis  
18 results and rationale are as follows:

- 19 • Flow of electrical power from GMS towards WSN and from WSN towards KLY  
20 is expected to exceed the Total Transfer Capability (**TTC**) of the GMS-WSN  
21 and/or WSN-KLY transmission cut-planes
- 22 • For portfolios that do not include Site C, incremental transfer capability has to  
23 be provided by F2032

---

<sup>41</sup> The transmission implications for the South Peace regional transmission system and the Fort Nelson/HRB regions are address elsewhere in this IRP.

- 
- 1 • For portfolios that include Site C, the required date for incremental transfer  
2 capability is advanced from F2032 to F2024

3 Since the proposed reinforcements are non-wire upgrades, BC Hydro considers the  
4 risk of not meeting the F2024 ISD to be low.

#### 5 *South Interior Corridor*

6 The key transmission reinforcements in the South Interior bulk transmission grid are  
7 non-wire upgrades to provide voltage support by adding series compensation on  
8 500 kV lines 5L91 and 5L98, which are triggered by Revelstoke Unit 6 coming  
9 online. In the BRP, as BC Hydro pursues the DSM target and Site C, Revelstoke  
10 Unit 6 is needed in F2031.

#### 11 *Interior to Lower Mainland*

12 Addition of 5L83 in F2016 will increase TTC of the Interior to Lower Mainland (ILM)  
13 project to approximately 6,550 MW. The regional LRB shown in section 2.5.3 for the  
14 Coastal region demonstrates that in the absence of incremental DSM, and new or  
15 renewed dependable capacity supply in the Coastal region, new transmission  
16 transfer capability beyond the capability provided by 5L83 may be required by  
17 F2022. However, when the expected EPA renewals and incremental savings from  
18 the DSM target are included in the resource portfolios, the power flow on the Interior  
19 to Lower Mainland transmission cut-plane is not expected to exceed the TTC that  
20 5L83 provides until F2030.

21 Non-wire transmission upgrades such as addition of shunt compensation at Nicola  
22 (**NIC**) and Meridian (**MDN**) substations can provide incremental transfer capability.

23 In addition to the non-wire upgrades, a need for further reinforcement of the ILM grid  
24 by building a new 500 kV series compensated transmission line (5L46) between KLY  
25 and Cheekye Substation (**CKY**) near Squamish is identified as early as F2034 if  
26 pumped storage resources in the Lower Mainland are not used or available to

---

1 displace the need for capacity resources from the Interior. See section [6.8.4](#) for a  
2 discussion of the effect of pumped storage in the Lower Mainland on transmission  
3 planning.

#### 4 *Lower Mainland to Vancouver Island*

5 The main supply routes for transferring power from Lower Mainland to Vancouver  
6 Island are two 500 kV, one 230 kV and one 132 kV submarine cables. The regional  
7 LRB shown in Section 2.5.4 shows that without incremental DSM, renewal of the  
8 EPA for Island Generation project (natural gas-fired combined cycle plant) or new  
9 on-island dependable capacity generation, new transmission upgrades between the  
10 Lower Mainland and Vancouver Island may be required by F2023. However, when  
11 these expected resources are included in the portfolios, there is no need to reinforce  
12 the transmission links between the Lower Mainland and Vancouver Island over the  
13 planning horizon. It is noted that the EPA renewal assumption for Island Generation  
14 project (F2023 expiry) has a significant effect on the timing for additional  
15 transmission requirement to Vancouver Island. However, BC Hydro considers that  
16 the likelihood of a combined contingency conditions resulting in a need to advance  
17 transmission infrastructures in this IRP is low.

#### 18 *North Coast*

19 Most of the LNG development is expected in the North Coast. The North Coast is  
20 supplied by a radial transmission line from Prince George to Terrace that consists of  
21 the following three 500 kV circuits: 5L61 from WSN to GLN; 5L62 from GLN to  
22 Telkwa (**TKW**); and 5L63 from TKW to SKA in Terrace. As shown in section 2.5.1  
23 and confirmed with analysis on portfolios meeting the mid gap, in the absence of  
24 new LNG loads on the North Coast, the 500 kV path from WSN to SKA is expected  
25 to be sufficient over the planning horizon.

---

### 1 **6.8.3 Transmission Analysis: Mid Gap with Expected LNG**

2 Section [6.5](#) discusses the unique planning challenges and supply strategies  
3 (additional resource requirements) for LNG and the North Coast. In section [6.5](#), it is  
4 identified that the mid gap scenario with the expected LNG load would require  
5 voltage support and reinforcement on the transmission line to the North Coast. The  
6 reinforcements include series compensation of 5L61, 5L62, and 5L63; plus voltage  
7 support and transformer addition in the existing BC Hydro substations by F2020.  
8 Since the proposed reinforcements are non-wire upgrades, BC Hydro considers the  
9 risk of not meeting the F2020 ISD to be low.

### 10 **6.8.4 Transmission Large Gap Analysis**

11 In addition to the mid gap analysis, the transmission requirements under  
12 contingency conditions (referred to as the large gap) and for higher than expected  
13 LNG load were also studied to inform the development of a robust transmission plan.  
14 These conditions are described below and the results of the transmission analysis  
15 for these conditions are summarized in the following sections. Section [6.9](#) provides  
16 the rationale for considering the large gap scenario in more detail.

- 17 • Large Gap: This scenario addresses the contingency event where a gap larger  
18 than expected results from the high load forecast and low DSM saving level.  
19 For transmission planning, the large gap analysis further tests the transmission  
20 implications if pumped storage in the Lower Mainland is not able to be  
21 developed in a significant manner and is replaced by SCGTs in the Kelly Lake  
22 region.

23 As described in section 4.4.6.1, generic pumped storage units in the Lower  
24 Mainland are used as a clean energy or renewable capacity resource in the IRP  
25 analysis to meet capacity need in the portfolios after considering the capacity  
26 from Site C, Revelstoke Unit 6, GMS Units 1-5 Capacity Increase and SCGTs  
27 (in portfolios where 7 per cent non-clean or renewable headroom is used) are  
28 selected. The addition of pumped storage units allows part of the peak demand



1 in the Lower Mainland to be met locally, which in turn reduces the need for  
2 transmission to bring generation capacity into Lower Mainland. In general, the  
3 addition of Lower Mainland pumped storage units has the effect of indirectly  
4 deferring transmission requirements along the ILM corridors and potentially the  
5 GMS-WSN-KLY corridor as well, and deferring the need for other local capacity  
6 resources.

7 Given that the development of pumped storage is unproven in B.C. (see  
8 section 4.4.6.1), prudent transmission planning must consider a contingency  
9 scenario where pumped storage is not proven out. Since the default capacity  
10 option to replace pumped storage is natural gas-fired generation, the remaining  
11 capacity need after considering the capacity from the projects listed above are  
12 met with SCGTs; such portfolios were created to understand the effects of this  
13 contingent event (i.e., without pumped storage). While siting gas in Lower  
14 Mainland would be beneficial because of its proximity to load centre and  
15 reduces the need for transmission to bring generation capacity into the Lower  
16 Mainland, permitting is expected to be very difficult as discussed in  
17 section [6.2.5](#). Other locations for siting gas, such as Kelly Lake and North  
18 Coast, would have implications on transmission requirements. The portfolio  
19 created assumes SCGTs are sited in the Kelly Lake region. If these units are  
20 sited somewhere else, they could advance transmission lines in other corridors.

- 21 • Higher than Expected LNG load scenario: This scenario contemplates a higher  
22 level of LNG load up to 6,600 GWh/year (800 MW) developing on the North  
23 Coast.

#### 24 **6.8.4.1 Large Gap Scenario**

##### 25 *North Interior Corridor*

26 The results of the portfolio analysis for the large gap show that the need for voltage  
27 support along the GMS-WSN-KLY transmission corridor is advanced from F2024 to

---

1 F2020. In these portfolios, additional 500 kV transmission lines between GMS and  
2 WSN (5L8) and between WSN and KLY (5L14) are also required as early as F2029.

3 *South Interior Corridor*

4 As discussed earlier, the compensation of 500 kV lines 5L91 and 5L98 are triggered  
5 by Revelstoke Unit 6 coming online. In the large gap scenario, the ISD for  
6 Revelstoke Unit 6 is advanced to its earliest ISD of F2021.

7 *Interior to Lower Mainland*

8 In the large gap scenario, the need for non-wire upgrades of the ILM transmission  
9 grid is advanced from F2030 to F2025. The new ILM line 5L46 is advanced from  
10 F2034 to F2029 when pumped storage in the Lower Mainland is not used or  
11 available to displace capacity resources from the Interior.

12 *Lower Mainland to Vancouver Island*

13 As with the mid gap analysis, there is no need to reinforce the transmission links  
14 between the Lower Mainland over the planning horizon assuming incremental low  
15 DSM savings and renewal of the Island Generation EPA.

16 **6.8.4.2 Higher than Expected LNG Load**

17 For the North Coast, higher level of LNG load up to 6,600 GWh/year (800 MW) and  
18 corresponding supply options including transmission requirements are discussed in  
19 section [6.5](#). Higher levels of LNG load will likely require either additional  
20 transmission reinforcements or local dependable (gas-fired) generation. The System  
21 Supply option with a second 500 kV line to the North Coast is more costly to  
22 alternative options of siting gas-fired generation locally. However, it does provide the  
23 North Coast with the high level of reliability.

---

### 1 **6.8.5 Generation Cluster Analysis**

2 Pursuant to subsection 3(3) of the *CEA* requirements to include an assessment of  
3 the potential for developing electricity generation from clean or renewable resources  
4 in B.C. grouped by geographic area, BC Hydro assesses where large potential for  
5 low cost clean generation resources exists in B.C. (these areas are referred to as  
6 clusters). As part of this IRP, BC Hydro analyzed the cost-effectiveness of  
7 pre-building transmission to access clusters and the pros and cons associated with a  
8 proactive approach to advance these infrastructures.

9 In the traditional evaluation framework used in resource planning, transmission  
10 capability is generally added in response to interconnection requests from individual  
11 generation projects. Building a common transmission line to access a cluster of  
12 projects was done only if opportunity arises, such as when multiple requests are  
13 made at similar time. With the cluster approach, it is assumed that a new bulk  
14 transmission line and substation would be pre-built to connect the projects within a  
15 cluster to the existing transmission grid. A potential benefit of the cluster approach is  
16 that it reduces the environmental footprint by minimizing the number of transmission  
17 corridors in an area. However, it also carries significant risk in that the transmission  
18 investment could be stranded or under-utilized if the generation resources did not  
19 develop as expected.

20 This IRP cluster analysis considers the cost benefit of pre-building transmission to  
21 areas with high concentration of generation resources by comparing portfolios  
22 created according to the following two approaches:

- 23 • **Bundle approach:** The traditional evaluation framework used in resource  
24 planning reflects the current approach to interconnecting individual generation  
25 projects to existing transmission grid. Each project within a bundle has a  
26 separate transmission connection to the system.

- 
- 1 • **Cluster approach:** Pre-building bulk transmission into a region of high  
2 generation resource potential. A cluster is a geographic area where there is  
3 high energy and/or capacity density.

#### 4 **6.8.5.1 Cluster Identification**

5 To identify areas of high generation resource potential (referred to as clusters), the  
6 following criteria was used as a guide: 1) a minimum capacity density of  
7 0.06 MW/km<sup>2</sup>, 2) a minimum generating capacity of 500 MW, and 3) at least 50 km  
8 away from the bulk transmission system.

9 For each identified cluster, a central node which represents a potential new  
10 transmission substation and collector hub for the electricity generated from the  
11 resources within the cluster was selected based on geography, proximity of  
12 generation resources and professional judgement. The length and cost of a bulk  
13 transmission line connecting the central node to the existing transmission grid were  
14 then determined. These line options are referred to as T3 options<sup>42</sup> in the following  
15 discussion. The cluster and T3 option analysis was conducted by Kerr Wood Leidal,  
16 and the report describing the approach and results is included in Appendix 6D.

17 The analysis identified nine clusters:

- 18 • North Peace River (**NPR**), connecting to GMS  
19 • Fort Nelson (**FTN**)<sup>43</sup>, connecting to NPR  
20 • Liard (**LRD**), connecting first to FTN and then to NPR  
21 • Telegraph Creek (**TGC**), connecting to the future Bob Quinn Substation (**BQN**)  
22 • Dease Lake (**DLK**), connecting to TGC

---


<sup>42</sup> The term 'T3 Options' builds off terminology used by BC Hydro in its resource options assessment to categorize the types of power lines required to connect new generation projects to the existing transmission grid. Refer to Appendix 6D for more information.

<sup>43</sup> The region around Fort Nelson did not have greater than 500 MW of potential generation resources in close proximity and therefore did not meet the definition of a generation cluster. However, it is recognized as having load growth potential and was therefore considered in the analysis.

- 1 • Hecate (**HCT**), connecting to the SKA
- 2 • Knight Inlet (**KTI**), connecting to the Dunsmuir Substation (**DMR**) on Vancouver
- 3 Island
- 4 • Bute Inlet (**BUI**), connecting to DMR
- 5 • North Vancouver Island (**NVI**), connecting to DMR.

6 [Figure 6-15](#) shows the central nodes of the clusters (labelled as “new nodes”) and  
 7 the area covered by each cluster (delineated by the red border). In [Figure 6-15](#),  
 8 many of the clusters are located in areas less densely covered by transmission, and  
 9 hence have reduced access to the existing transmission system.

Figure 6-15 Cluster Analysis Nodes



---

**6.8.5.2 Portfolio Cost Analysis**

1 The analysis presented here is based on an older vintage LRB mid gap, which  
2 contains a much larger load resource gap than the mid gap LRB described in this  
3 IRP. However, the conclusions still hold true for when additional resources are  
4 needed in the future.  
5

6 To analyze whether there is a potential benefit of pre-building transmission for  
7 generation clusters, a 30-year portfolio was created using the cluster approach. The  
8 System Optimizer model was given the option to select T3 options, and the cost of  
9 interconnection for generation resources was adjusted to the central nodes. The  
10 present value of this cluster portfolio was then compared to the present value of the  
11 corresponding portfolio with a bundle approach.

12 The comparison shows that the cluster approach results in a lower present value  
13 than the bundle approach (less than 2 per cent difference in PV for a 30 year  
14 portfolio). With the mid gap LRB used in this IRP, the difference in present value  
15 between the cluster and bundle approach would likely be reduced, or even swing in  
16 favour of the bundle approach as the much lower resource gap would lower the  
17 utilization of the T3 line in the cluster approach but still incur the entire cost of the T3  
18 line.

19 It should be noted that the portfolio analysis is based on the resource selection being  
20 optimized given perfect foresight of future conditions within the portfolio construct.

21 The costs and availability of resources analyzed represent planning level estimates  
22 that are sufficient for comparing resource options but this information is highly  
23 uncertain/unreliable for predicting which and where resources would be developed.

24 In addition and in practice, the cluster approach also assumes the risk of stranded or  
25 under-utilized transmission assets that represent significant expenditures. The  
26 cluster approach may also have potential negative impacts on bidding behaviour in a  
27 potential future acquisition process, which could erode any benefits.



---

1 Given all of the above considerations, the difference in portfolio PV results is not  
2 significant enough to support a cluster approach.

3 An additional analysis was conducted for the NPR cluster to determine if any  
4 benefits of the NRP cluster could offset the cost of NETL which is being  
5 contemplated in the NPR area. An additional portfolio allowing only the NPR cluster  
6 was created and compared to the bundle approach, again with the older vintage of  
7 LRB mid gap. In this comparison, the PV of the NPR cluster portfolio was marginally  
8 higher than the bundle approach, suggesting that the benefit of building out the NPR  
9 cluster does not fully offset the cost of the GMS to NPR transmission line over the  
10 planning horizon. However, the difference in portfolio cost without the cost of the T3  
11 line from the Peace Region could be used to offset the cost of NETL because NETL  
12 enables access to the NPR cluster. By assuming the annual benefit at the end of the  
13 30 year portfolio persists until the end of the project life of NETL, the benefit  
14 associated with the NPR cluster is about \$150 million.

### 15 **6.8.5.3 Simple Cost Analysis for Clusters**


16 In addition to the portfolio analysis described in section [6.8.5.2](#), a simple analysis of  
17 estimating potential cost savings for the cluster approach was completed to  
18 understand potential benefits in the long run (beyond the planning timeframe). The  
19 potential cost savings were estimated as the annual difference in cost, between the  
20 two approaches, incurred up to the POI at existing transmission grid (i.e., the bundle  
21 approach includes the generation resource cost and interconnection cost (T1) to the  
22 POI; the cluster approach includes the generation resource cost and interconnection  
23 cost (T2) to T3 and the cost of T3 from the respective central nodes to POI.

24 As an example of the analysis, [Figure 6-16](#) shows a comparison of costs for the  
25 bundle approach versus the cluster approach for a 500 kV T3 option connecting to  
26 the NPR node. For the bundle approach, the weighted average cost of resources  
27 increases as increasingly more expensive projects are interconnected. The cluster  
28 approach has a higher weighed average cost than the bundle approach when only a

1 few projects are interconnected, but the cost decreases as more resources are  
 2 interconnected as utilization of the T3 line is increased. At some point, the weighted  
 3 average cost for the cluster approach may increase again, as the addition of more  
 4 expensive resources outweigh the benefit of higher utilization of T3 line. In this  
 5 example, 800 MW of resources have to be built for the cluster approach to yield  
 6 lower average cost than the bundle approach. This speaks to the risk of stranded  
 7 assets if the T3 line is built, but the assumed generation resources in the cluster are  
 8 not needed or are not developed.

9  
10  
11

**Figure 6-16 Comparison of Weighted Average Annualized Cost for the Bundle Versus Cluster Approach**



12 The resulting weighted average costs and total costs from the two build out  
 13 approaches for two T3 sizes (i.e., 230 kV and 500 kV where meaningful) are  
 14 summarized in [Table 6-27](#) to [Table 6-30](#). Clusters which depended on other clusters



1 to be built first (e.g., DLK) were not included in this simple analysis. The annualized  
 2 costs reflect the condition when the lines are close to fully utilized. As shown in  
 3 these tables, the cluster approach is generally of lower cost than the bundle  
 4 approach for clusters studied, except for the NPR and NVI clusters with a 230 kV  
 5 line. This confirms the intuition that the cluster approach generally has a cost  
 6 advantage in the long run when the line is fully utilized. However, there is uncertainty  
 7 regarding resource development leading to risk of stranded/underutilized asset, and  
 8 uncertainty as to when benefit can outweigh cost.

9 **Table 6-27 UEC Cost Comparison for Bundle**  
 10 **Approach versus Cluster Approach for a**  
 11 **230 kV Line**

Cluster	Bundle	Cluster (230 kV)
	UEC of generation + T1 (\$/MWh)	UEC of generation + T2 +T3 (\$/MWh)
NPR	97	109
TGC	286	174
NVI	129	145
KTI	142	94
BUI	124	88

12 **Table 6-28 UEC Cost Comparison for Bundle**  
 13 **Approach versus Cluster Approach for a**  
 14 **500 kV Line**

Cluster	Bundle	Cluster (500 kV)
	UEC of generation + T1 (\$/MWh)	UEC of generation + T2 +T3 (\$/MWh)
NPR	111	104
TGC	794	348
HCT	132	128
NVI	137	133
KTI	301	177
BUI	266	169

1  
2  
3

**Table 6-29 Total Cost Comparison for Bundle Approach versus Cluster Approach for a 230 kV Line**

Cluster	Bundle	Cluster (230 kV)
	Cost of generation + T1 (\$ million)	Cost of generation + T2 +T3 (\$ million)
NPR	99	78
TGC	304	181
NVI	96	93
KTI	177	112
BUI	151	97

4  
5  
6

**Table 6-30 Total Cost Comparison for Bundle Approach versus Cluster Approach for a 500 kV Line**

Cluster	Bundle	Cluster (500 kV)
	Cost of generation + T1 (\$ million)	Cost of generation + T2 +T3 (\$ million)
NPR	432	393
TGC	2,389	1,047
HCT	317	306
NVI	320	356
KTI	1377	802
BUI	835	532

7

**6.8.5.4 Transmission for Clusters**

8  
9  
10  
11  
12  
13

The construction of transmission lines has a long lead time and delays to the in-service date of a transmission line may have effects on BC Hydro’s ability to deliver supply to customers. Given the potential early need for some of the lines identified in this analysis, it is beneficial to begin developing the lines and corridors to minimize the amount of time required to bring them into service when their need is confirmed.

14  
15  
16  
17

The IRP analysis concludes that there could be marginal financial benefits in pre-building transmission into clusters of generation resources over the 30-year planning horizon. It also has the potential to reduce environmental footprints somewhat as a result of optimal transmission configurations. However, there are

---

1 also significant risks associated with pre-building transmission for generation  
2 clusters that include:

- 3 • Stranded transmission investment if the expected generation projects do not  
4 materialize
- 5 • Potential negative impacts on acquisition process bidding behaviour, which  
6 could erode any financial benefit to pre-building

7 To reap some potential pre-building benefits while minimizing risk, BC Hydro could  
8 evaluate building adequate transmission to the identified high potential generation  
9 cluster regions during future acquisition processes if and when projects in these  
10 regions are proposed. The NPR cluster could provide an estimated \$150 million of  
11 benefit to offset the cost of NETL.

### 12 **6.8.6 Conclusions**

13 The IRP analysis concludes that the following transmission reinforcements should  
14 be considered in this IRP. Detailed studies are required to finalize the scope and  
15 cost of the required upgrades:

#### 16 *North Interior Corridor:*

- 17 • Non-wire upgrades to the existing transmission lines and substations on the  
18 GMS-WSN-KLY 500 kV transmission system are expected to be required by  
19 F2024 (mid-gap), but may be required as early as F2020 (large-gap). BC Hydro  
20 should reinforce this corridor by F2024. Although developing alternative supply  
21 options (transmission contingency plan) are not required at this time, studies to  
22 keep an early ISD of F2020 open for the non-wire upgrades on the  
23 GMS-WSN-KLY corridor may be initiated as part of BC Hydro's CRPs.
- 24 • New 500 kV transmission from GMS to KLY is not expected over the planning  
25 horizon, although the large gap scenarios indicate new transmission may be  
26 required by F2029. Given the long lead time before new transmission is

1 required under the large gap scenario, there is no need to develop contingency  
2 plans at this time.

3 *South Interior Corridor:*

- 4 • Non-wire upgrades to the 500 kV lines of 5L91 and 5L98 are needed to support  
5 the delivery of power from Revelstoke Unit 6, which is expected to be required  
6 in F2031 in the BRP and as early as the earliest ISD of Revelstoke Unit 6 in  
7 F2021 (large-gap). A transmission contingency plan is not required and studies  
8 to ensure the timing for these upgrades to match the Revelstoke Unit 6 earliest  
9 ISD will likely be initiated as part of BC Hydro's CRPs.

10 *Interior to Lower Mainland:*

- 11 • Following completion of 5L83, no new upgrades are expected to be required  
12 until F2030. However, in the large gap scenario the non-wire upgrades to the  
13 ILM transmission grid will be required as early as F2025. A transmission  
14 contingency plan is not required and studies to define the scope and cost of the  
15 upgrades for an early ISD will likely be initiated as part of BC Hydro's CRPs.

16 *Lower Mainland to Vancouver Island.*

- 17 • Assuming EPA renewal of the Island Generation project and some level of DSM  
18 delivery, the transmission links between the Lower Mainland and Vancouver  
19 Island are not expected to require reinforcement within the 30-year planning  
20 horizon. BC Hydro considers the likelihood of a combined contingency  
21 conditions resulting in a need to advance transmission infrastructures in this  
22 IRP is low, therefore, BC Hydro has not reflected this risk in its CRPs.

23 *North Coast:*

- 24 • Adding three new series capacitor stations to the existing 500 kV lines from  
25 WSN to SKA and installing adequate transformation capacity and voltage  
26 support in the existing BC Hydro substations is required by F2020 to serve

1 expected load LNG load in the region. Work needs to be advanced to maintain  
2 this in-service date. Since the proposed reinforcements are non-wire upgrades,  
3 BC Hydro considers the risk of not meeting the F2020 ISD to be low.

4 Consequently, there is no need to develop a transmission contingency plan at  
5 this time. Higher levels of LNG load will likely require either additional  
6 transmission reinforcements or local dependable (gas-fired) generation.

#### 7 *Generation Clusters:*

- 8 • BC Hydro concludes there are no clear net benefits for pre-building new  
9 transmission lines to access generation clusters. However, BC Hydro could  
10 evaluate building adequate transmission to the identified high potential  
11 generation cluster regions during future acquisition processes if and when  
12 projects in these regions are proposed.

13 Conclusions related to the mid gap and Expected LNG support Recommended  
14 Actions 8 and 12 as described in Chapter 8. Conclusions related to the transmission  
15 contingency analysis indicates the load forecast, DSM delivery and supply-related  
16 risks may require advancement of bulk transmission system reinforcements by a  
17 number of years. As a result, transmission-related contingencies are considered in  
18 the development of BC Hydro contingency plans, which are described in section [6.9](#);  
19 and reflected in BC Hydro's recommended CRPs and Transmission Contingency  
20 Plan, which are described in section 8.4.

## 21 **6.9 Capacity and Contingency Analysis**

### 22 **6.9.1 Introduction**

23 Ensuring an adequate supply of capacity is a primary concern for BC Hydro.  
24 Dependable, dispatchable<sup>44</sup> capacity resources ensure system security and  
25 reliability by allowing customer loads to be met at all times throughout the year,

---

<sup>44</sup> A resource whose output can be adjusted to meet various conditions including fluctuating customer demand, weather changes, outages, market price changes and non-power considerations.

1 including winter peak loads. Dispatchable capacity resources are also critical in  
2 integrating intermittent, renewable generation that primarily supply energy, and may  
3 not necessarily be available during times of system need.

4 The need for capacity is subject to a range of uncertainties that can increase or  
5 decrease need relative to the planned level (i.e., mid gap). A smaller LRB gap than  
6 expected could result in an excess of capacity resources and pose a financial risk.  
7 BC Hydro addresses this by incorporating flexibility and off-ramps into the  
8 development process of future capacity resources. A larger than expected LRB gap  
9 poses a significant risk to reliability as it may result in a capacity shortfall either at  
10 the system level or in a specific region, and ultimately result in an inability to meet  
11 customer load. To mitigate this risk, BC Hydro plans for different contingency  
12 conditions that could result in a large gap.

13 BC Hydro plans the development of capacity resources considering the following  
14 conditions:

- 15 • Mid gap that leads to recommendations for the BRP
- 16 • Expected LNG load that leads to recommendations for the LNG BRP
- 17 • Contingency conditions with greater need that leads to recommendations for  
18 the CRPs with and without LNG

## 19 **6.9.2 Capacity Resource Options**

20 An inventory of resource options in B.C. is provided in Chapter 3. The resource  
21 options focused on capacity are summarized in [Table 6-31](#). This section describes  
22 the different characteristics of capacity options and their values to BC Hydro. The  
23 key characteristics are timing/availability of capacity resources and their  
24 dispatchability.

---

1 *Availability during times of need:*

2 Capacity is most valuable if it is available at the same time as the demand for  
3 electricity, especially during times of peak load. The BC Hydro system is a winter  
4 peaking system, meaning that the integrated system demand is highest during the  
5 winter. Demand within each week is highest during weekday evenings around dinner  
6 time and second highest on weekday mornings before residential customers leave  
7 home for work. However, peak load of individual regions may occur at times that do  
8 not coincide with the integrated system peak (coincident peak).

9 Some capacity resource options have limited availability, being available only for a  
10 few hours per day. Examples include resources with limited storage or fuel supply,  
11 and some load curtailment products which are available only for a few hours or  
12 infrequently throughout the year. They are generally used towards meeting demand  
13 during system peak times. Such resources that have limited availability are of lesser  
14 value to BC Hydro. To the extent that more and more capacity in BC Hydro's system  
15 has limited availability, BC Hydro could find itself resource-constrained during  
16 shoulder periods that immediately precede or follow peak load hours. Furthermore,  
17 some DSM programs such as load curtailment and DSM capacity programs that aim  
18 to reduce peak demand can have an unintended consequence of moving the peak  
19 to a different time as opposed to reducing overall peak demand for the system.

20 Given these considerations, BC Hydro must be confident that capacity resources  
21 (particularly ones that have limited availability) can reliably reduce system peak  
22 requirement before relying on them in the resource plans.

23 *Dispatchability:*

24 Capacity that is fully dispatchable and has a quick response time is of high  
25 value to BC Hydro as it allows generation to be varied to meet customer  
26 demand as it occurs. Examples of such resources include Site C and pumped  
27 storage. Gas-fired generation while being fully dispatchable has

1 comparatively slower response times especially when they are required to  
2 start-up from a shut-down state. Dispatchable capacity also enhances the  
3 capability of integrating intermittent renewable generation such as wind, and  
4 the capability of managing freshet oversupply.

5 • Wind Integration

6 As discussed in section 3.4.1.4, wind power is subject to natural variations in  
7 wind speed and the amount of electricity generated is difficult to forecast. The  
8 generation is highly variable on timescales of seconds to minutes, requiring  
9 the electric system to have additional dispatchable capacity with fast  
10 response times. The dispatchable generation can ramp-down their output as  
11 wind generation increases or ramp-up as wind generation dies down to  
12 ensure that the net generation of the BC Hydro system can meet customer  
13 demand at all times.

14 • Freshet oversupply

15 The BC Hydro system is a winter peaking system, meaning demand is  
16 highest during the winter. However, inflows into BC Hydro's reservoirs and  
17 energy from non-storage hydroelectric facilities are generally highest during  
18 the late spring/early summer freshet period (May to July), when customer  
19 demand is the lowest. As a consequence, BC Hydro's system generally has  
20 an oversupply of energy during this time that must be stored, sold to the  
21 market or spilled, even when the system is load resource balanced for the  
22 year.

23 BC Hydro's oversupply period has a significant overlap with the oversupply  
24 period in the U.S. Pacific Northwest that also has significant large hydro  
25 resources and a freshet period. This leads to low electricity market prices in  
26 the spring. In recent years, additions of significant volumes of non-  
27 dispatchable wind generation in the U.S. Pacific Northwest region have



1 contributed additional energy in the same spring freshet period. This  
2 additional wind energy further reduces electricity market prices in this period,  
3 at times driving them negative.

4 BC Hydro utilizes the storage capability and dispatch flexibility of its Heritage  
5 hydro system to store most of the energy for later use and minimize exports  
6 during the freshet period. However, this flexibility is limited and BC Hydro is  
7 forced to sell energy into the market during freshet or spill the water/energy  
8 because of an oversupply that cannot be stored. There is also a lost  
9 opportunity that results from having increased resources delivering in the  
10 freshet. Under conditions when BC Hydro is not forced to sell during the  
11 freshet, increases in freshet generation (e.g., from non dispatchable  
12 resources and resources with minimum flow requirements) erode BC Hydro's  
13 ability to purchase very low priced market energy to serve our customers'  
14 load while saving water/energy for sale later in higher price period. This has a  
15 negative financial impact on BC Hydro.

16 To avoid further negative impacts of surplus energy in the freshet, BC Hydro  
17 must take into consideration the impact of freshet period energy deliveries in  
18 any resources evaluation. The following are potential mitigation measures to  
19 the freshet oversupply/low market price concerns:

- 20 (i) Reduce purchases of non-dispatchable energy during freshet periods;
- 21 (ii) Link purchase prices of any additional energy during freshet periods to  
22 actual market prices and market availability;
- 23 (iii) Include more dispatchable generation resources in BC Hydro's supply  
24 portfolio;
- 25 (iv) Increase loads during freshet periods.

26

---

1 When dispatchable capacity is combined with storage capability, it can also  
2 maximize the benefit of energy limited resources by shaping its energy production  
3 from low value time to high value time. Of lesser value is capacity that is  
4 dispatchable but requires pre-scheduling and/or long ramp times. The longer lead  
5 time diminishes value because it is less flexible to match capacity needs at specific  
6 times, requires guessing, and can come with an opportunity cost. Capacity that is  
7 non-dispatchable has the least value.

8 [Table 6-31](#) shows the capacity potential, lead time, UCC and some key  
9 considerations for different capacity options. The UCC and MW shown in the table  
10 have not been adjusted to reflect the different characteristics of the options.  
11 BC Hydro examines all of these characteristics in evaluating capacity resources and  
12 preparing recommendations related to the development of capacity resources.

1

**Table 6-31 Inventory of Capacity Resource Options**

Resource Option	Potential (MW)	Lead Time (years) or Earliest In-Service Date	Cost at Point Of Interconnection (\$F2013/kW-yr)	Reference Sections and Key Considerations
Market purchase backed by Canadian Entitlement (CE)	Up to 500	n/a	varies	Section 3.4.2.4 Low cost- bridging option Prescheduled capacity
Revelstoke Unit 6	500	F2021	50	Section 3.4.2.3 Low cost long term option, clean Dispatchable capacity with fast response time
GMS Units 1-5 Capacity Increase	220	F2021 first unit	35	
Natural Gas-fired Generation	100 (per unit)	4 – 5	$\geq 84^{45}$	Section 3.4.2.2 Long term option, but not clean Dispatchable capacity with ramp rate restrictions
Pumped Storage (LM/VI)	500 – 1000 (per unit)	8	$\geq 118^{46}$	Section 3.4.2.1 High cost long term option, clean Dispatchable capacity with fast response time

2 Note that capacity options such as load curtailment, DSM capacity programs and Mica pumped storage have  
3 been screened out as not viable options for planning purpose at this time, as discussed in section 3.7.

4 **6.9.3 Capacity Planning – Mid Gap**

5 As shown in [Table 6-31](#), the viable long term clean capacity options available to  
6 BC Hydro are limited. BC Hydro is counting on the DSM target and Site C to  
7 contribute 1,400 MW by F2021 and 1,100 MW by F2024, respectively. To replace  
8 the capacity contribution from any one of these resources would require BC Hydro to


<sup>45</sup> The UCC shown is for a SCGT located at Kelly Lake which is in close proximity to transmission and a major gas pipeline. SCGTs located elsewhere are likely to have higher fixed costs in terms of firm gas tolls and transmission interconnection costs.

<sup>46</sup> The UCC shown is for the lowest cost pumped storage site identified in studies on potential pumped storage sites in B.C. A pumped storage project located at another site would have a higher UCC.

1 use up its identified low cost Resource Smart options as well as needing non-clean  
 2 options or high cost clean options like pumped storage.

3 BC Hydro develops two BRPs to meet mid gap conditions, one without Expected  
 4 LNG and one with Expected LNG. The yearly forecast peak capacity requirements  
 5 based on mid gap with and without Expected LNG (excluding planning reserve  
 6 requirements) are shown in [Figure 6-17](#). These lines show the capacity  
 7 requirements after considering the capacity contribution from the DSM target and  
 8 Site C. In each of these cases, there are two distinct periods for capacity  
 9 requirements (i.e., before and after Site C).

**Figure 6-17 Capacity Requirements under Mid Gap**



11 **6.9.3.1 Mid Gap without LNG**

12 In the without LNG case shown in [Figure 6-17](#), there is a two-year gap up to about  
 13 200 MW before Site C. Given the short term nature of this gap, the lowest cost

1 option to meet the capacity requirement during this time is to rely on the market,  
2 backed up by the CE provided under the Columbia River Treaty.<sup>47</sup> This is the lowest  
3 cost option as BC Hydro can defer building long-term B.C.-based capacity resources  
4 which would otherwise result in unnecessary surplus shortly after (when Site C  
5 comes online).

6 As set out in section 2.3.1.4 and 3.4.2.4, market purchases and CE are not  
7 categorized as long-term resource options because BC Hydro is precluded from  
8 planning to rely on them to meet its long-term needs. However, BC Hydro is  
9 recommending reliance upon them for short-term bridging purposes. The delivery of  
10 CE capacity is more reliable than pure market purchases because the electricity and  
11 transmission to transport the CE electricity to B.C. have higher priority given it is  
12 backed by an international treaty. However, BC Hydro still estimates that in practice  
13 market purchases backed up by CE would only be available to supply BC Hydro with  
14 a maximum of 500 MW given transmission constraint through the Interstate 5  
15 corridor during peak winter conditions when U.S. utilities have similar very high load  
16 conditions.

17 There are risks associated with relying on the market:

- 18 • There is uncertainty associated with the delivery of CE post-F2024. While the  
19 Columbia River Treaty has no termination date, either Canada or the U.S. can  
20 unilaterally terminate most of the provisions of the Columbia River Treaty any  
21 time after September 16, 2024, providing that at least 10 years' notice is given.
- 22 • Reliance on the market for capacity is generally risky as capacity is required at  
23 specific times to meet load requirements. Planning conditions have been  
24 evolving with more intermittent resources (poor in dependable capacity) in both  
25 the B.C. system as well as in U.S. Pacific Northwest. Integration issues with

---

<sup>47</sup> Burrard would continue to be available to provide transmission support services and in the case of emergency as permitted by section 13 of the *CEA*.

1 intermittent resources and the tight capacity margin in the market means  
2 BC Hydro prefers to have an adequate amount of dependable generation in its  
3 service area to maintain system security and reliability.

4 With all of the above factors considered, BC Hydro is comfortable relying on the CE  
5 for the 200 MW gap identified before Site C as a short-term bridging resource.

6 However, it should be noted that this option does not meet the self-sufficiency  
7 requirement; refer to section 8.2.7.

8 At the same time, it is noted that the two DSM capacity focused options described in  
9 section 3.3.2 are potential low cost options in B.C. They are not viable options at this  
10 time because they represent new capacity resources to BC Hydro that are subject to  
11 uncertainty with respect to its ability to reduce the system peak over the long term.

12 Recommended Action 2 set out in Chapter 8 will allow BC Hydro to confirm savings  
13 potential from DSM capacity focused options for two purposes: to displace  
14 market/CE bridging reliance and to confirm the reliable potential as a long-term  
15 planning resource.

### 16 **6.9.3.2 Mid Gap with LNG**

17 With Expected LNG, there is a five-year gap up to 580 MW before Site C as shown  
18 [Figure 6-17](#). This gap is more than double in size and duration compared to the case  
19 without Expected LNG. In consideration of the risks associated with the market/CE  
20 bridging and DSM deliverability risk, BC Hydro is not prepared to rely upon  
21 market/CE bridging beyond the 200 MW two-year gap prior to Expected LNG.

22 Section [6.5](#) provides a discussion on the capacity resources to serve the expected  
23 LNG with a conclusion that gas-fired generation in the North Coast would provide  
24 valuable system flexibility and reliability value when sited in North Coast where most  
25 of the LNG developments are expected. BC Hydro should therefore explore gas in  
26 the North Coast at this time so it is a feasible option when LNG load commitment is  
27 confirmed.

---

## 6.9.4 Contingency Planning

Contingency planning is done as a reliability management tool to manage the risk (consequences) of not being able to meet load by identifying alternative sources of supply that should be available should the BRP not materialize as expected. As discussed in Chapter 4, the need for energy and capacity is subject to a range of uncertainties that can increase or decrease need relative to the planned mid gap which forms the basis for the BRP:

- The risk of energy shortfall is less of a concern for BC Hydro because more short lead time options are available, and given BC Hydro system's energy shaping capability, it is less risky to rely on the market for energy in the meantime before additional resources can be built to mitigate the shortfall.
- The risk of capacity shortfall is BC Hydro's primary concern because capacity is required at specific times to meet peak load requirements and maintain system security and reliability. BC Hydro also has limited short lead time capacity options in BC and relying on market comes with the risks as discussed in section [6.9.3.1](#).

The capacity planning concern includes both generating capacity and transmission capacity. To mitigate the capacity shortfall risks on the generation side, BC Hydro develops contingency plans to identify additional resources that should be maintained as feasible options and reduce their lead times so to ensure the flexibility to use these options should greater need results. On the transmission side, BC Hydro prepares specific CRPs that are used in the analysis of associated transmission requirements. Section [6.8](#) presents the results of a preliminary assessment for transmission requirements for the CRPs as well as an assessment of the need for transmission contingency plan (i.e., a plan to address key transmission shortage or delay that can impact BC Hydro's resource plan).

---

1 **6.9.4.1**     ***Uncertainties***

2 As discussed in Chapter 4, there are a number of uncertainties and risks that  
3 BC Hydro considers in its resource planning and analysis. [Table 6-32](#) summarizes  
4 each uncertainty in terms of its potential impact on the need for capacity, the type of  
5 indication that would let BC Hydro know that a change has occurred and the amount  
6 of warning time that BC Hydro would likely have to respond from the time of  
7 indication of a change to the requirement to serve. BC Hydro categorized the  
8 uncertainties by three important traits:

- 9 (i) Timing in which a change to the capacity requirements may occur (near term or  
10 long term)
- 11 (ii) Whether or not BC Hydro would have sufficient time to react to a change
- 12 (iii) Whether the change will happen gradually or immediately with a specific  
13 'signpost' that indicates that there is a change in capacity requirements



1

**Table 6-32 Capacity Need Uncertainties**

Category	Uncertainty	Potential Impact on Capacity Gap Size	Leading Indicator	Number of Years of Advance Warning
Near-Term, Possible Insufficient Reaction Time, Gradual	Load (inc. Mining + Oil & Gas)	+1,050 MW in F2021	Year-by-year load growth	1-4
	DSM	+300 MW in F2021	Year-by-year load growth	1-4
Near-Term, Possible Insufficient Reaction Time, Signpost	Wind ELCC	Up to about +150 MW in F2021	Experience & Internal analysis	1-4
Near-Term, Sufficient Reaction Time, Signpost	LNG	+ 500 MW in F2021	Customer requests	4
	High FN/HRB	+ 1,000 MW in F2021	NETL commitment	4
Long-Term, Sufficient Reaction Time, Signpost	Site C	Material delay in delivery of Site C's +1,100 MW	Approvals to proceed; ISD.	4
Long-Term, Sufficient Reaction Time, Gradual	General Electrification	Growing to +400 MW in F2021 (E3)	Gov't policy, load growth, technology	3-6

2 BC Hydro considers the inventory of available capacity resources in conjunction with  
 3 the list of uncertainties to prioritize resource options that can be used to respond to  
 4 changes in need as they happen. BC Hydro is most concerned with uncertainties in  
 5 the near term with insufficient reaction time. The key uncertainties that fall under this  
 6 category are listed below and should be considered in developing contingency  
 7 plans.

- 8 • Load forecast uncertainty
- 9 • DSM deliverability risk
- 10 • ELCC of clean or renewable intermittent resources

---

#### 1 **6.9.4.2 Load Forecast Uncertainty and DSM Deliverability Risk**


2 As discussed in Chapter 4, the uncertainties from load forecast and DSM  
3 deliverability are significant. Section 2.2.4 describes the uncertainty band around the  
4 mid load forecast. A low load forecast (about P10) represents the expected outcome  
5 if the load is less than the twentieth percentile in each year; and the high load  
6 forecast (about P90) represents the expected outcome if the load exceeds the  
7 eightieth percentile in each year. This uncertainty band is also reflective of the  
8 uncertainties associated with major industrial sectors including mining, oil and gas,  
9 and forestry. As shown in [Figure 6-18](#), by F2021, the high load forecast could be  
10 1,050 MW higher than the mid load forecast used for developing the BRP. This  
11 figure also shows that load forecast uncertainty is the more significant uncertainty  
12 than DSM delivery. While the uncertainty band is large, some of the new load would  
13 have warning signs (such as new load interconnection requests from the mining, and  
14 oil and gas sector) to allow BC Hydro time to react. These loads account for a  
15 substantial portion of the uncertainty band. The oil and gas sector makes up about  
16 50 per cent of the uncertainty band in F2021 with about 70 per cent of the oil and  
17 gas sector being a new load.

18 Section 4.3.4.2 describes the uncertainty band around the mid-level of DSM savings.  
19 The low level of savings (about P10) represents the expected outcome if the saving  
20 level is less than the 20<sup>th</sup> percentile, whereas the high level of savings represents  
21 the expected outcome if the saving level exceeds the 80<sup>th</sup> percentile. As shown in  
22 [Figure 6-18](#), by F2021, the low level of savings could be 300 MW lower than the  
23 mid-level used for developing the BRP.

24 BC Hydro has traditionally planned to the high load forecast with a low level of DSM  
25 savings (referred to as the large gap) in developing its CRPs. As [Figure 6-18](#)  
26 highlights, there is substantial amount of uncertainties around the size of the gap  
27 (could be about 1,350 MW larger than mid gap by F2021). This underscores the

1 importance of having adequate capacity resources ready in the near term to respond  
 2 in case demand drifts away from its expected level in the coming years.

3 **Figure 6-18 Load and DSM uncertainty Bands**



4 **6.9.4.3 Effective Load Carrying Capability of Intermittent Resources**

5 As discussed in section 4.3.4.5, BC Hydro considers additional uncertainty with  
 6 respect to the reliance on the effective load carrying capability of intermittent  
 7 resources such as wind. Relying on intermittent resources such as wind to meet  
 8 peak demand has risks.

9 As described in Appendix 3C, BC Hydro currently uses an assessment of ELCC for  
 10 intermittent resources. The capacity contribution is calculated based upon the  
 11 probability of capacity being available under peak load conditions and is currently  
 12 24 per cent of installed capacity for existing and committed wind resources. As  
 13 BC Hydro gains experience in the operation of intermittent resources and as the

1 penetration of intermittent resources grows, BC Hydro will assess the extent to  
2 which the capacity materializes and the ability to utilize the capacity on an  
3 operational basis. Wind generation causes particular concerns due both to its high  
4 degree of short term variability and the experience of neighbouring jurisdictions of  
5 having little wind available during peak load circumstances. BC Hydro currently  
6 relies on approximately 150 MW from existing EPAs with wind resources. If study or  
7 operational experience were to reduce the 24 per cent ELCC, BC Hydro would need  
8 to acquire additional capacity to back it up.

9 Given BC Hydro's current capacity reliance on wind resources is small, the range of  
10 uncertainty captured by load forecast and DSM delivery uncertainties is considered  
11 sufficient to cover this additional uncertainty for the purpose of contingency planning.  
12 BC Hydro will continue to monitor the capacity contribution from its intermittent  
13 resources and make adjustments as more operational experience is available.

#### 14 **6.9.4.4 Large Gap**

15 [Figure 6-19](#) shows the large capacity gap with and without Expected LNG assuming  
16 High Load and Low DSM uncertainties. The large capacity gap without Expected  
17 LNG shows need starting in the first planning year, F2017, and growing to 1,700 MW  
18 before Site C's earliest ISD in F2024. To meet the potential early need and  
19 significant capacity requirement, resource options with short lead time and  
20 significant potential will need to be considered.

21 As described in Chapter 3, the remaining large and cost-effective Resource Smart  
22 projects are Revelstoke Unit 6 and GMS Units 1-5 Capacity Increase. As shown in  
23 [Table 6-31](#), these projects are relatively low cost long term capacity options. They  
24 also provide the highly valued dispatchable capacity. However, they have longer  
25 lead times and are not available until F2021 for Revelstoke Unit 6 and F2021 for  
26 GMS Units 1-5 Capacity Increase (first unit). In addition, the GMS Units 1-5 Capacity  
27 Increase would be limited to one unit (about 40 MW) being upgraded per year.

---

1 During this process, the unit being upgraded would likely required to be out of  
2 service, thus reducing the supply by 270 MW.


3 As described in section [6.2](#), natural gas-fired generation has special value as a  
4 transmission alternative or for contingency conditions. The short lead time to build  
5 gas-fired generation (given permits are obtained) makes it an ideal contingency  
6 resource.

7 Given the above considerations, BC Hydro should advance the two Resource Smart  
8 options, and gas options to have the flexibility to choose the more cost-effective  
9 option or combination of options should a larger gap materialize. To strike a balance  
10 between preparing for contingency conditions and incurring unnecessary costs,  
11 BC Hydro should continue to advance these options through Identification and early  
12 Definition phase activities such as regulatory approval processes, but avoid  
13 committing significant capital before need is confirmed.

14 The large capacity gap with Expected LNG, shown in [Figure 6-19](#), indicates a  
15 capacity need growing to 2,200 MW before Site C's F2024 ISD. Based on the larger  
16 gap size and the flexibility to serve LNG with gas-fired generation, BC Hydro would  
17 consider using additional gas-fired generation to meet the incremental capacity need  
18 for LNG.

1

**Figure 6-19 Large Gap Capacity Requirements**



2 **6.9.5 Conclusions**

3 The capacity and contingency analysis has shown the following:

- 4 • Capacity savings associated with the DSM target and Site C are required to
- 5 serve the mid gap. Given the capacity contribution from these resources, there
- 6 remains capacity gap before Site C in both the no LNG and the Expected LNG
- 7 cases.
- 8 • For the BRP prior to Expected LNG, market purchases backed up by the
- 9 Canadian Entitlement serving as bridging capacity until Site C is in-service is
- 10 the most cost-effective option. The gap is small and only lasts for a short time.
- 11 This option does not meet the self-sufficiency requirement and would require
- 12 B.C. Government approval. The two DSM capacity-focused options are
- 13 potential low cost options and efforts to confirm savings potential should be

---

1           undertaken and have the ability to displace bridging capacity and be included in  
2           future resource planning assessments.

- 3           •   BRP with Expected LNG: To meet the incremental capacity need from  
4           Expected LNG load before Site C, BC Hydro should consider gas-fired  
5           generation in the North Coast given the transmission benefits related to  
6           facilitating maintenance outages and increased voltage stability.
  
- 7           •   In light of significant planning uncertainties such as those related to load  
8           forecast and DSM deliverability, BC Hydro should advance the following options  
9           so to have the flexibility to choose the more cost-effective option or combination  
10          of options should a larger gap materialize:
  - 11          ▶   Advance Revelstoke Unit 6 and GMS Units 1-5 Capacity Increase through  
12          low cost Investigation and Definition phase activities to maintain their  
13          earliest ISDs
  
  - 14          ▶   Advance gas-fired generation to reduce its in-service lead time from  
15          potential length siting and approval process. Locations considered for siting  
16          gas-fired generation as contingency resource include the North Coast, Kelly  
17          Lake, and Vancouver Island.

18       Conclusions in this section support Recommended Actions Nos. 2, 7, 10, 14, 15 and  
19       16 as described in Chapter 8.