

BC Hydro e.Catalog
Product Acceptance Criteria



BC Hydro e.Catalog
Product Acceptance Criteria

Table of contents

e.CATALOG MANUFACTURER ACCEPTANCE CRITERIA	4
INCENTIVE PROGRAMS OVERVIEW.....	5
PRODUCT INCENTIVE PROGRAM	5
POWER SMART PARTNER EXPRESS PROGRAM.....	5
LIGHTING	6
HALOGEN INFRARED LIGHTING	7
T8 FLUORESCENT LIGHTING	8
T8 DIMMING BALLASTS	9
T5 FLUORESCENT LUMINAIRES	10
COMPACT FLUORESCENT LIGHTING	11
BI-LEVEL STAIRWELL LIGHTING SYSTEM.....	12
LOW/ HIGH-BAY FLUORESCENT LUMINAIRES	13
SCREW-IN COLD CATHODE LIGHTING	13
HIGH INTENSITY DISCHARGE LIGHTING	13
ENERGY-EFFICIENT METAL HALIDE LAMP.....	15
PULSE START/ CERAMIC METAL HALIDE LAMPS WITH MAGNETIC BALLASTS	16
HIGH INTENSITY DISCHARGE ELECTRONIC BALLASTS	16
HIGH INTENSITY DISCHARGE LIGHTING FOR ORNAMENTAL STREET LIGHTING	16
HID HIGH / LOW SWITCHING SYSTEM	17
INDUCTION LUMINAIRES FOR INDOOR AND OUTDOOR LIGHTING APPLICATIONS.....	18
LED EXIT SIGNS.....	18
NON-ELECTRICAL EXIT SIGNS	19
LED REPLACEMENTS FOR INCANDESCENT LAMPS AND LUMINAIRES	19
LARGE WATTAGE LED LUMINAIRES FOR INDOOR AND AREA LIGHTING.....	21
LED COMMERCIAL AND ARCHITECTURAL SIGNS	22
LED REFRIGERATED LIGHTING.....	23
LIGHTING CONTROLS.....	23
CONTROLS AND SENSORS	24
VENDING MACHINE CONTROLLER	24
PARKING LOT CONTROLLER	24
VOLTAGE OPTIMIZATION	25
COMPUTER MANAGEMENT	25
POWER MANAGEMENT SOFTWARE FOR COMPUTER WORKSTATIONS	25
EFFICIENT POWER BARS FOR COMPUTER WORKSTATIONS.....	25
UPS.....	26
NETWORK TRAFFIC ANOMALY MONITORING/DETECTION SENSORS	26
HIGH VOLUME COLOUR PRINTER	26
SERVER	26
POWER DISTRIBUTION UNITS (PDU) FOR DATA CENTERS.....	26
HVAC	27
VARIABLE FREQUENCY DRIVE.....	27
VARIABLE SPEED ELECTRONICALLY COMMUTATED MOTOR (ECM) BASED PUMPS	27
HVAC OCCUPANCY SENSOR.....	28
TEMPERATURE SENSORS FOR ECONOMIZERS	28
AIR-COOLED ELECTRIC CHILLERS.....	28
UNITARY AIR-CONDITIONERS AND CONDENSING UNITS	29
REFRIGERATION.....	29
LOW TEMPERATURE VERTICAL DISPLAY CASE.....	29
ADDING GLASS DOORS TO LOW TEMPERATURE VERTICAL DISPLAY CASE.....	29
ANTI-SWEAT HEATER (ASH) HUMIDISTAT CONTROL FOR VERTICAL DISPLAY CASE.....	29
EVAPORATOR FAN MOTOR (ECM)	30
NIGHT COVERS FOR OPEN VERTICAL DISPLAY CASE (LOW OR MEDIUM TEMPERATURE)	30
NIGHT COVERS FOR OPEN LOW TEMPERATURE HORIZONTAL DISPLAY CASE	30

BC Hydro e.Catalog
Product Acceptance Criteria

STRIP CURTAINS FOR WALK-INS (LOW OR MEDIUM TEMPERATURE).....	30
COMPACT REFRIGERATOR.....	30
BARE SUCTION PIPE INSULATION	30
COMMERCIAL KITCHEN	32
ELECTRIC GRIDDLE.....	32
ELECTRIC PRESSURELESS STEAMER.....	32
CONVECTION OVEN	32
COMBINATION OVEN	32
DEMAND VENTILATION CONTROLS.....	32
INSULATED HOT FOOD HOLDING CABINET	32
REFRIGERATORS AND FREEZER	32
ICE MAKING MACHINES	33
COMMERCIAL DISHWASHER.....	33
OTHERS	33
LOW-E CEILING	33
FIXED SPEED REDUCED FLOW PUMPS.....	33
LIVESTOCK WATERER	33
SYNCHRONOUS BELTS.....	34

**BC Hydro e.Catalog
Product Acceptance Criteria**

e.CATALOG MANUFACTURER ACCEPTANCE CRITERIA

The following outlines the criteria that manufacturer's must meet in order for their products to be accepted into the BC Hydro e.Catalog:

- Products must meet local building codes and be approved by local electrical inspectors.
- Products must meet as a minimum Energy Star or the Federal Energy Management Program (FEMP) energy efficiency standard. For details on energy efficiency standards see the BC Hydro e.Catalog Energy Efficiency Criteria listed below.
- Where no standard exists or where data is unavailable BC Hydro applies its own criteria as determined by BC Hydro's Power Smart technical department. The product review process assesses each case individually and considers the following:
 - Products must be commercially available and both technically and economically feasible
 - Priority is given to products which consume electrical power to operate and meet high energy efficiency criteria
 - Resource constraints require BC Hydro to focus on the most obvious commercial electrical energy consuming products that have energy efficiency criteria
 - Products are rejected when technology is unproven. We rely on having criteria for e.Catalog approval because BC Hydro does not have resources to endorse or test vendor claims. Exceptions are made only when the Power Smart Technical department is comfortable with approving the product as is in the case where the technology is proven and product is clearly far more energy efficient than what is normally used.
 - Currently fuel substitution products are not accepted
- Manufacturers must have authorized distributors which are available and responsive regarding after sales service and warranty support as shown by:
 - local (British Columbia) contact information (phone and address),
 - demonstrated ability to follow up with customers on site, and
 - demonstrated ability to respond to customer issues within 48 hours.
- Manufacturers must not sell products exclusively online.
- Manufacturers must have been in business for a minimum of 3 years.
- Exceptions to these guidelines may be considered by BC Hydro on a case-by-case basis only.
- Manufacturer must be willing to invest the time and resources required to keep their product data current
- BC Hydro makes no representation, guarantee or warranty to any third party regarding the intellectual or other property rights of any person or party in any of the products listed on e.Catalog."
- BC Hydro reserves the right to remove any products from e.Catalog at any time if, in BC Hydro's opinion, the product acceptance criteria are not met, or for any other reason as BC Hydro determines necessary for the proper administration of e.Catalog.

BC Hydro e.Catalog
Product Acceptance Criteria

INCENTIVE PROGRAMS OVERVIEW

PRODUCT INCENTIVE PROGRAM

The Power Smart Product Incentive Program (“Program”) is intended to provide incentives for simple retrofits with energy-efficient products to BC Hydro business customers with no key account manager and who spend less than \$200,000 annually on electricity. This document establishes the minimum acceptable technical and product requirements for the Program.

All products eligible for incentive funding under the Program are listed and identified in the BC Hydro e.Catalog. Manufacturers confirm that their products meet these minimum guidelines and based on their declaration, their product is added to the list of eligible products in e.Catalog.

BC Hydro reserves the right to remove any products from e.Catalog at any time if, in BC Hydro’s opinion, the product acceptance criteria are not met, or for any other reason as BC Hydro determines necessary for the proper administration of e.Catalog.

BC Hydro makes no representation, guarantee or warranty to any third party regarding the intellectual or other property rights of any person or party in any of the products listed on e.Catalog.

In the future, new products will be evaluated and if they meet PIP requirements, they will be added to the Program’s product list. This document will be modified as Program updates occur.

POWER SMART PARTNER EXPRESS PROGRAM

The Power Smart Partner (PSP) Express program offers an online self-serve application with quick and easy financial incentives for your simple retrofit projects. Only BC Hydro commercial, government and institutional customers with a Key Account Manager are eligible.

All products eligible for incentive funding under the Program are listed and identified in the BC Hydro e.Catalog. Manufacturers confirm that their products meet these minimum guidelines and based on their declaration, their product is added to the list of eligible products in e.Catalog.

BC Hydro reserves the right to remove any products from e.Catalog at any time if, in BC Hydro’s opinion, the product acceptance criteria are not met, or for any other reason as BC Hydro determines necessary for the proper administration of e.Catalog.

BC Hydro makes no representation, guarantee or warranty to any third party regarding the intellectual or other property rights of any person or party in any of the products listed on e.Catalog.

In the future, new products will be evaluated and if they meet PIP requirements, they will be added to the Program’s product list. This document will be modified as Program updates occur.

**BC Hydro e.Catalog
Product Acceptance Criteria**

LIGHTING

GENERAL SPECIFICATIONS FOR ELIGIBLE LIGHTING PRODUCTS

- The objective of the Power Smart Product Incentive Program is to provide incentive for simple retrofits where one product is removed and replaced with another more energy-efficient product. It is not intended to involve situations where a lighting design is necessary.
- All products must be listed in the BC Hydro e.Catalog to be eligible for incentives.
- When retrofitting a luminaire, a lamp and ballast from e.Catalog must be used in order to qualify for a Program incentive.
- All products shall be new, of current manufacture and CSA approved or certified by an accredited independent organization such as Intertek-ETL or Underwriters Laboratory (UL) as required by the current Canadian Electrical Code with the exception of lamps without an integral ballast or power supply.
- Average lighting levels and measurements of the same shall comply with Illuminating Engineering Society of North America (IESNA) recommended practice and Worker's Compensation Board (WCB) regulations. BC Hydro will **not** monitor lighting levels but reserves the right to occasionally check levels and design quality. Lighting levels before and after the retrofit must meet the requirements of the end user and be to the satisfaction of all approving authorities having jurisdiction for specific applications.
 - *In specific applications, the Contractor or Supplier must make the end user aware where there is a potential reduction in light levels, and confirm that the lighting levels will meet the minimum regulatory requirements.*
These applications include but are not limited to:
 - *Reduced number of lamps in retrofit luminaire;*
 - *Conversions from 2-lamp, 8' T12 high output lamps to 4-lamp, 4' T8 lamps with low power input ballast*
 - *Conversions from High Pressure Sodium lamps/luminaires to Metal Halide lamps/ luminaires*
 - *It is the end users responsibility to ensure that the light levels meet the minimum regulatory requirements.*
- All retrofitted luminaires shall be suitably identified with appropriate labeling, listing the related parameters.
- In delamping situations, the customer/contractor shall remove the unused T12 sockets from the luminaire. If new T8 sockets are provided, they should be centered in the fixture as far as is practical.
- In redesign situations, removing existing luminaire means disconnection and total removal of the luminaire. Where removals require extensive, costly labor or lifting equipment, the luminaires can remain in location, but be total disconnected from the electrical circuit/ distribution. Note that light levels should meet IES and WorkSafe BC standards.
- In any installation, in the event of abnormally high product failure rates within the first year of operation (in excess of 5%) BC Hydro reserves the right to reject specific products from the Program and from e.Catalog. Where applicable, products shall be constructed of individually replaceable compatible lighting components, such as ballasts, starters, capacitors, sockets and lamps so as not to invalidate any of the components' warranties.
- Lighting retrofits shall be designed for optimum energy efficiency. All eligible products shall be represented by an authorized local representative or distributor, who is capable of providing after sales service. Manufacturers must have an approved local representative in B.C. with authority from the manufacturer to handle warranty claims and after sales support.

BC Hydro e.Catalog
Product Acceptance Criteria

- BC Hydro reserves the right to request manufactures to provide independent laboratory results certifying the parameters such as lamp life, lumen output , input watts etc are as specified by the manufacturer and at the cost of the manufacturer

In addition to the General Specifications for the products, each of the eligible products is warranted by the Suppliers to meet the following minimum requirements:

HALOGEN INFRARED LIGHTING

- It is the responsibility of the customer and/or installing contractor to ensure that the chosen HIR lamps are suitable for the specific application, and in full compliance with the building codes.
- HIR lamps shall be a minimum of 3,000 hours.
- HIR lamps shall replace incandescent or standard halogen lamps of equivalent beam distribution, lighting outputs and provide a minimum of 25% reduction in wattage, as suggested by the following table (present table does not include all existing types of HIR lamps).

<i>Present System</i> Halogen (HAL) / Incandescent (INC)	<i>Proposed System*</i> Halogen Infrared (HIR)	Life (Hours)	Energy Saved (%)
PAR 38 lamps			
75W HAL-PAR 38	50W HIR-PAR 38	3,000 vs. 2,000	33%
90W HAL-PAR 38	60W HIR-PAR 38	3,000 vs. 2,000	33%
120W HAL-PAR 38	70W HIR-PAR 38	3,000 vs. 2,000	42%
150W INC-PAR 38	90W HIR-PAR 38	3,000 vs. 2,000	40%
250W INC-PAR 38	100W HIR-PAR 38	3,000 vs. 2,000	60%
PAR 30 lamps			
60W HAL-PAR 30	45W HIR-PAR 30	3,000 vs. 2,000	25%
75W HAL-PAR 30	50W HIR-PAR 30	3,000 vs. 2,000	33%
MR-16 lamps			
35W HAL-MR-16	20W HIR- MR-16	5,000 vs. 4,000	42%
50W HAL-MR-16	35W HIR- MR-16	5,000 vs. 4,000	30%
75W HAL-MR-16	45W HIR- MR-16	5,000 vs. 4,000	40%

Note:

* Lamps have been compared at similar lighting outputs.

BC Hydro e.Catalog
Product Acceptance Criteria

T8 FLUORESCENT LIGHTING

The Program incentive applies only to the replacement of T12 or T8 fluorescent lamps using electromagnetic or hybrid/ electronic ballast with T8 lamps using electronic ballasts. It also applies to replacements of T12 technology complete luminaires with new T8 technology luminaires (T8 lamps and electronic ballasts).

Following are the technical criteria for T8 lamps and electronic ballasts:

- It is the responsibility of the customer and/or installing contractor to ensure that the retrofit luminaires are CSA certified or approved by an accredited third party laboratory for the specific application, and in full compliance with the building codes.
- Incentive applies to new T8 luminaires at any mounting type provided the ballasts are meeting the technical criteria specified below.
- T8 Lamps
 - All makes and models of T8 lamps are eligible.
 - Color rendering index (CRI) shall be 80 minimum. There is no restriction on lamp color temperature.
 - The configuration of T12 U-tubes to T8 U-tubes is permitted under the PIP program.
 - Energy saving (ES) T8 lamps represent all makes of T8 technology lamps with nominal wattage lesser than the industry standard. For example, in the 4-foot T8 range ES lamps could be anything lesser than 32W, respectively: 30, 28 and 25W. Note that ES T8 lamps usually have some limitations (such as min. 60°F operating temperature and restricted dimming abilities) that have to be considered when choosing the suitable retrofit measure for the given application.
 - T8 lamps may be remote tandem mounted as recommended by the ballast manufacturer (usually up to 20 feet).
- T8 Ballasts
 - Ballasts shall be dedicated only for T8 systems and shall be high frequency electronic type. Ballasts shall operate lamps between 20 kHz and 60 kHz.
 - Ballast power factor shall be 0.95 minimum (lead or lag).
 - Instant Start ballasts are not recommended in applications where the lamps are turned on and off frequently (i.e. with occupancy sensors) because they may shorten lamp life. Programmed Start ballasts are recommended for these applications.
 - Programmed Start ballasts are eligible for incentives. Rapid Start non-dimming ballasts are not eligible for incentives as they are currently replaced by Programmed Start ballasts.
 - Normal Ballast Factor ballasts have a ballast factor of between 0.85 and 1.00.
 - Low Ballast Factor ballasts shall have a ballast factor lower than 0.85.
 - High Ballast Factor ballasts shall have a ballast factor higher than 1.00.
 - For the standard ballast, Total harmonic distortion (THD) limits for the electronic T8 ballast shall not exceed 20% at either rated 5% above and 5% below nominal primary voltage. For high efficiency electronic ballasts, THD shall be less than 10%.
 - 4 foot T8 ballast (120, 277 and 347V) must be on the current approved list of the Consortium for Energy Efficiency (CEE) Commercial Lighting Systems Initiative.
<http://www.cee1.org/com-lt/com-lt-main.php3>
- 2, 3 and 8 foot Instant Start electronic ballasts shall have **low ballast factor for 2 to 4 lamp ballasts**
The input wattage shall not exceed (for 120/277V ballasts):

BC Hydro e.Catalog
Product Acceptance Criteria

Maximum Input Watts (standard efficiency)				
Lamp Length	LBF or NBF	LBF		
	1 lamp	2 lamp	3 lamp	4 lamp
2 foot	18W	29W	47W	56W
3 foot	26W	42W	60W	78W
8 foot	65W	102W	N/A	N/A

- 2, 3 and 8 foot High efficiency instant start electronic ballasts shall provide a minimum 3W energy savings over comparable standard efficiency electronic ballasts of similar ballast factor.

Maximum Input Watts (high efficiency)			
Lamp Length	NBF		
	2 Lamp	3 lamp	4 lamp
2 foot	30W	45W	56W
3 foot	42W	68W	84W
8 foot	108W	N/A	N/A

- Above mentioned maximum input wattages do not apply for 2, 3, or 8 foot 347V ballasts. However, 347V ballasts need to be either LBF or high efficient NBF for 2 to 4 lamp ballasts. When 347V ballasts are used to drive lesser lamps than they are built for, it is acceptable as long as the ballasts meet the basic criteria.
- High Ballast Factor Instant Start ballasts for T8 lamps are only accepted for T12HO retrofits
- Standard Normal Ballast Factor and High Ballast Factor Instant Start ballasts for T8 lamps are only accepted for T12VHO and HO retrofits

Minimum MLPW (mean system efficacy) for T8 lamps and electronic ballasts		IS	PS
8'	T8 (59W)	88	
	T8HO (86W)	82	78

- Above minimum MLPW does not apply to T8HO 8' 1 lamp system.
- When retrofitting T12HO and T12VHO luminaires in low-temperature application such as refrigerated areas, building exteriors, open exterior structures, T8HO ballasts have to be rated for -20°F (-30°C) minimum starting temperature.

T8 DIMMING BALLASTS

- Dimming T8 ballasts (rapid or program start) are allowed for incentives only when controlled by individual or group photo sensors/ photocells for daylight harvesting.
- Photocells for daylight harvesting –close and open loop, group/ field or individual/ luminaire installed. Photocells to be of the appropriate type (and installation procedure) for the application. Initial calibration and continuous maintenance is required when installing photocells.
- Dimming ballasts can be step or continuous dimming with a reduction in input power of at least 60%.
- Dimming T8 Ballasts shall have the following minimum specifications:
 - Dimming luminaires shall be on the current approved list of the Consortium for Energy Efficiency (CEE) High Performance Commercial Lighting Systems Initiative. <http://www.cee1.org/com-com-lt/com-lt-main.php3>
 - operate without visible flicker through the operating dimming range. All lamps shall remain on at minimum light levels.
 - be compatible with power line carrier systems.

BC Hydro e.Catalog
Product Acceptance Criteria

- operate fixed or continuous level control and/or daylight harvest dimming control with at minimum the use of integral or external photocell controls.
- High ballast factor dimming ballasts as direct replacements as not accepted for the present rebate program

T5 FLUORESCENT LUMINAIRES

The Program incentive applies to the replacement of luminaires that use T12 and T8 fluorescent or incandescent technology with new high efficient fluorescent luminaires complete with T5 lamps and electronic ballasts. Self ballasted T5 retrofit kits are eligible only when retrofitting selected T12 luminaires.

For T12 luminaires (any mounting):

- T12 fluorescent luminaires with 4 lamps can be replaced with new T5 fluorescent luminaires/ or combinations of retrofit kits equipped with:
 - up to two T5 standard lamps (ex: 14W lamp for 2ft-long luminaires, 28W for 4ft-long luminaires)
 - one T5HO lamp (ex: 24W lamp for 2ft-long luminaires, 54W for 4ft-long luminaires).
 - one TT5 lamp (bi-ax) of 40W or 50W – for 2-foot luminaires. This selection does not apply to T5 retrofit kits.
 - Two energy saver TT5 lamp of 25W for 2-foot luminaires

For T8 luminaires (whole fixture):

- T8 fluorescent luminaires with 4 lamps can be replaced with new T5 fluorescent luminaires equipped with:
 - up to two T5 standard lamps (ex: 14W lamp for 2ft-long luminaires, 28W for 4ft-long luminaires)
 - one T5HO lamp (ex: 24W lamp for 2ft-long luminaires, 54W for 4ft-long luminaires).

For Incandescent luminaires:

- Incandescent luminaires greater than 100W can be replaced with new T5 fluorescent luminaires equipped with:
 - up to two T5 standard lamps (ex: 14W lamp for 2ft-long luminaires, 28W for 4ft-long luminaires)
 - one T5HO lamp (ex: 24W lamp for 2ft-long luminaires, 54W for 4ft-long luminaires).

Following are technical criteria for T5 retrofits:

- All T5 lamps are eligible
- New general illumination T5 luminaires (except decorative luminaires) shall have an efficiency of minimum 70% to qualify for product incentives.
- All T5/ TT5/ T5HO luminaires or retrofit kits have to be equipped with electronic ballasts of instant or program start technology.
- Use of T5 retrofit kits requires fixture modification and re-certification. Please consult with the electrical inspection branch in your jurisdiction for more information on re-certification
- Electronic ballasts shall have a 5-year warranty.
- Ballasts shall be dedicated for T5/ TT5/ T5HO systems and shall be high frequency electronic type. Ballasts shall operate lamps between 20 kHz and 60 kHz.

BC Hydro e.Catalog
Product Acceptance Criteria

COMPACT FLUORESCENT LIGHTING

The Program incentive applies to the following:

- Hardwired retrofit kits or new luminaires, or
- Screw-in compact fluorescent lamps complete with ballast for wattages up to and including 42 watts.
- Screw-in high-wattage compact fluorescent lamps complete with ballast for wattages above 42 watts.
- Compact fluorescent manufacturers must have International Organisation for Standardisation (ISO) 9001 certification.
- Colour rendering index (CRI) for all compact fluorescent lamps shall be 80 minimum.
- For lamps used in indoor applications, lamps shall start and operate reliably at temperatures down to +10°C throughout their rated lives. For outdoor applications, low temperature ballasts shall be suitably rated for cool temperature applications, minimum -28°C and maintain 95% of rated lumen output.
- Screw-in up to 42W compact fluorescent lamps with integral ballasts and GU10/GU24 CFL lamp
 - must be Energy Star approved.
 - Dimming (continuous or 3-way step) and/or Normal power factor screw-in compact fluorescent lamps under 42W are eligible for an incentive.
 - Life rating of lamps greater and equal to 13W shall be a minimum of 8000 hours. Life rating of lamps less than 13W shall be a minimum of 8000 hours unless Energy Star approved.
 - Candle type and candelabra base lamps lower and equal to 9W do **not** need to meet the 8000 hour requirement, or be Energy Star Approved. The same will apply to GU-10 socket integral ballasted lamps lower and equal to 13W.
- High-wattage CFL lamps (exceeding 42W)
 - shall have an efficacy of minimum 60 lm/W and lumen depreciation of maximum 10% from initial output at 1,000 hours and maximum 80% from initial output at 40% rated life.
 - shall be operated by external or integral (screw-in combinations), high power factor (>0.90) and/or low THD (<10%) electronic ballasts. Lamps, ballast and screw-base integral combinations should have end-of-life protection
 - It is required that CFL luminaires, hardwired retrofit kits and CFLs over 42W be operated by high power factor ballasts (>0.90) to limit stress to the electrical distribution system and to avoid possible power factor penalties to the owner.
- Permanent or “hard-wired” types of luminaires
 - For pin-based CFL lamps excluding GU24 socket, shall be completed with integral replaceable ballast thermally protected with a high power factor (> 0.90). Where multiple lamps are used, ballasts may be the multi-lamp type. It shall be possible to reconnect multiple ballasts individually to achieve multi-level switching within individual fixtures.
 - Existing luminaires with more than one socket are admissible provided the maximum Wattage criteria per socket is respected.
 - CFL sockets of the conversion luminaires must be no more than number of sockets of the existing incandescent/ halogen fixtures.
 - The incentive calculations only account for the luminaire quantity and not for the combined number of sockets.
 - Hardwired retrofit kits for the conversion of existing incandescent luminaires shall have permanent mounting features, with thermally protected high power factor ballasts. All attachments shall be by

BC Hydro e.Catalog
Product Acceptance Criteria

mechanical means and not dependent upon tape or adhesives. All displaced incandescent lamp sockets shall be permanently removed.

- Major hardware shall identify this kit as a retrofit type, with make/model number and nominal lamp rating. Kit components are not to be modified in a manner so as to invalidate CSA approval for the intended function.
- GU24 base luminaire
 - New luminaires and retrofit kits using CFL units with GU-24 sockets are considered “hard-wired” luminaires types. Normal power factor GU-24 lamps and full units are eligible for an incentive. Luminaires needs to be Energy Star approved.
 - Existing luminaires with more than one socket are admissible provided the maximum Wattage criteria per socket is respected.
 - CFL sockets of the conversion luminaires must be no more than number of sockets of the existing incandescent/ halogen fixtures.
 - The incentive calculations only account for the luminaire quantity and not for the combined number of sockets.
- A lamp replacement table is included to illustrate the expected lamp wattages from incandescent/mercury vapour to CFL. Refer to *Table 1: Lamp Replacement Guideline*.

BI-LEVEL STAIRWELL LIGHTING SYSTEM

Existing	Retrofit
2' 2 lamp T12, magnetic ballast	2' 2 lamp T8, electronic ballast bi-level
4' 1 lamp T12, magnetic ballast	2' 2 lamp T8, electronic ballast bi-level
4' 2 lamp T12, magnetic ballast	4' 2 lamp T8, electronic ballast LBF, bi-level
2x26W CFL	4' 2 lamp T8, electronic ballast LBF, bi-level
2x26W CFL	2x26W CFL bi-level

Only complete, new fluorescent luminaires with program start electronic ballasts and lamps or compact fluorescent luminaires that meet requirements listed in above table qualify.

- Qualifying fixtures must be manufactured with fixture integrated occupancy sensors that control the individual fixture and meet safety requirements
- All lamps must be pin-based fluorescent or other permanent installed technology.
- For linear fluorescent luminaires ballasts shall be program start type
- Must include a passive infrared and/or ultrasonic occupancy sensor with a fail safe feature in case lamp fails due to a sensor failure.
- The fixture must operate in low-standby light level during vacancy and switch to full light output upon occupancy.
- The fixture cannot exceed 35% of full wattage during unoccupied periods.
- Only for 24/7 illuminated interior stairwells.

Exclusions:

- Luminaires whose settings can be overridden are not eligible.
- Screw-in lamps are not eligible.
- Not eligible for additional rebates through the “Occupancy Sensors” or “High Performance T8 or T5 Linear Fluorescent Lamps with Electronic Ballasts” categories.

BC Hydro e.Catalog
Product Acceptance Criteria

Installation Process:

- Low mode setting should be chosen so that the surface illuminate levels are building code compliant.

LOW/ HIGH-BAY FLUORESCENT LUMINAIRES

The Program incentive applies to the replacement of the low/high-bay luminaires that use incandescent or HID technology with new high efficient fluorescent luminaires.

- The Low/High-bay fluorescent luminaire conversion must save a minimum of 80 input watts per luminaire.
- It is the responsibility of the customer and/or installing contractor to ensure that the new luminaires are CSA certified or approved by an accredited third party laboratory for the specific application, and in full compliance with the building codes.
- Accepted lamps for low/high-bay fluorescent luminaires are: T8, T5, T5HO and CFL. Ballasts shall be high power factor electronic and suitable for the lamp type.
- High-bay fluorescent luminaires shall be capable of multiple switching.
- Luminaires to be provided with optimal heat dissipation for electronic ballasts.

SCREW-IN COLD CATHODE LIGHTING

The Program incentive applies to the following:

- Screw-in compact cold cathode lamps complete with ballast for low wattages.
- Screw-in cold cathode lamps are eligible for incentives when displacing incandescent lamps` .
- Life rating of lamps shall be a minimum of 18,000 hours.
- There is no restriction on the lamp color temperature, but the color rendering index (CRI) shall be 80 minimum.
- Products shall be ULC or CSA listed and suitable for indoor or outdoor use

HIGH INTENSITY DISCHARGE LIGHTING

The Program incentive applies to both interior and exterior lighting systems for new and retrofitted luminaires.

- Pulse start metal halide and high pressure sodium luminaries are eligible for incentives when displacing mercury vapor luminaires of higher wattage.
- Pulse Start Metal Halide retrofit kits are eligible for an incentive if they replace standard mercury vapor of higher wattage.
- Lamps and ballasts must be of the current commercial production.
- Pulse start metal halide fixtures installed under the Program should be totally enclosed on interior installations or use a protective shroud to contain an arc tube rupture. This requirement also applies to ceramic metal halide lamps.
- All HID ballasts shall have a ballast factor of 0.95 minimum and a high power factor (0.90 minimum).
- HID ballasts must have a 2-year warranty.
- High / Low ballast and switching system included in new luminaires will also be eligible for incentives under HID luminaires.

BC Hydro e.Catalog
Product Acceptance Criteria

- A lamp replacement table is included to illustrate the expected lamp wattages from incandescent/mercury vapour to pulse start metal halide or high pressure sodium. Refer to *Table 1: Lamp Replacement Guideline*.

MERCURY VAPOUR LAMP REPLACEMENT GUIDE

The following table is intended to illustrate the expected wattages for lamp changes from mercury vapour lamps to either compact fluorescent, metal halide pulse start or high pressure sodium lamps.

Table 1: Lamp Replacement Guideline

BC Hydro e.Catalog Product Acceptance Criteria

Lamp Replacement Guideline

Existing Lamp			Potential Replacement Lamp								
Lamp Wattage	Fixture Wattage	Mean Lumen Output	Compact Fluorescent			Metal Halide Pulse Start			High Pressure Sodium		
			Lamp Wattage	Fixture Wattage	Mean Lumen Output	Lamp Wattage	Fixture Watts	Mean Lumen Output	Lamp Wattage	Fixture Watts	Mean Lumen Output
Standard Incandescent											
40 watt	40	415	9 watt	10	500						
50 watt	50	545	11 watt	13	680						
60 watt	60	900	15 watt	18	900						
75 watt	75	1,200	20 watt	23	1,200						
100 watt	100	1,600	25 watt	33	1,530				35 watt	46	2,000
150 watt	150	2,400	34 watt	41	2,100	39 watt	57	2,800			
200 watt	200	3,600	42 watt	48	2,720	50 watt	68	3,200	50 watt	66	3,600
250 watt	250	3,750	50 watt	60	3,870						
300 watt	300	6,000	80 watt	90	5,400	70 watt	90	5,400	70 watt	95	5,450
500 watt	500	9,500				150 watt	190	10,000	100 watt	138	8,500
620 watt	620	11,000				175 watt	208	11,200			
750 watt	750	15,000				250 watt	288	16,600	150 watt	188	14,000
1000 watt	1000	24,000				350 watt	400	27,000	250 watt	295	27,000
1500 watt	1500	31,000				400 watt	456	30,000	310 watt	365	33,000
Typical Rated Avg. Lamp Life 1,000 to 2,000hrs											
Mercury Vapour											
50 watt	63	1,260	20 watt	23	1,200				35 watt	46	2,000
75 watt	95	2,250	34 watt	41	2,100				50 watt	66	3,600
100 watt	125	3,400	50 watt	60	3,870	50 watt	68	3,200	100 watt	138	8,500
175 watt	210	7,400	105 watt	115	6,900	100 watt	125	7,000	150 watt	188	14,000
250 watt	290	10,500				150 watt	190	10,000	200 watt	250	19,800
400 watt	450	19,000				320 watt	365	22,000	310 watt	365	33,000
700 watt	775	33,600				400 watt	456	30,000	400 watt	465	45,000
1000 watt	1100	45,000									
Typical Rated Avg. Lamp Life 24,000hrs											

Notes:

- The lumen output values shown in table are intended as a guideline only. These values are an average of various manufacturers published data. It is not to be relied on for detail design.
- The lumen output of all the lamps will vary depending on the exact lamp selected.
- A lighting designer should be consulted to ensure the correct application of lamps is selected to meet the required lighting levels, lamp life, colour rendition etc..
- The lighting output values shown are **mean** not initial lumens.

Standard Wattage and Lumen Output for Various Lamp Styles

Compact Fluorescent			Metal Halide Pulse Start			High Pressure Sodium		
Lamp Wattage	Fixture Wattage	Mean Lumen Output	Lamp Wattage	Fixture Wattage	Mean Lumen Output	Lamp Wattage	Fixture Wattage	Mean Lumen Output
9 watt	10	500	39 watt	57	2,800	35 watt	46	2,000
11 watt	13	680	50 watt	68	3,200	50 watt	66	3,600
15 watt	18	900	70 watt	90	5,400	70 watt	95	5,450
18 watt	21	1,100	100 watt	125	7,000	100 watt	138	8,500
20 watt	23	1,200	150 watt	190	10,000	150 watt	188	14,000
25 watt	33	1,530	175 watt	208	11,200	200 watt	250	19,800
34 watt	41	2,100	250 watt	288	16,600	250 watt	295	25,000
42 watt	48	2,720	320 watt	365	22,000	310 watt	365	33,000
50 watt	60	3,870	350 watt	400	27,000	360 watt	414	42,800
65 watt	75	4,200	400 watt	456	30,000	400 watt	465	45,000
80 watt	90	5,400	750 watt	810	60,000	600 watt	660	81,000
105 watt	115	6,900	1000 watt	1075	96,000	750 watt	810	99,000
						1000 watt	1100	112,000
Typical Rated Avg. Lamp Life 6,000 to 10,000hrs			Typical Rated Avg. Lamp Life: <= 150 W: 9,000 to 12,000hrs > 150W : 15,000 to 20,000 hrs			Typical Rated Avg. Lamp Life 24,000hrs		

ENERGY-EFFICIENT METAL HALIDE LAMP

The Program incentive applies to the replacement of the:

- 175W metal halide lamp with the 150W energy saving metal halide lamp. No ballast change is required for the lamp.
- 250W metal halide lamp with the 225W or 205W energy saving metal halide lamp. No ballast change is required for the lamp.

BC Hydro e.Catalog
Product Acceptance Criteria

- 400W metal halide lamp with the 360W energy saving metal halide lamp. No ballast change is required for the lamp.

PULSE START/ CERAMIC METAL HALIDE LAMPS WITH MAGNETIC BALLASTS

The Program incentive applies to the replacement of the:

- 75W and 90W Halogen PAR38 incandescent lamps with the 25W, PAR 38 integrated ceramic metal halide lamp and magnetic ballast unit
- 175W metal halide lamp in overlit areas with 100W pulse start metal halide
- 175W metal halide lamp with the 125W/150W pulse start metal halide lamp.
- 250W metal halide lamp with the 150W/175W/200W pulse start metal halide lamp
- 400W metal halide lamp with the 320W pulse start metal halide lamp or 330W metal halide lamp
- 400W metal halide lamp in overlit areas with the 250W pulse start metal halide lamp
- 1000W metal halide lamp with the 750W/775W/875W pulse start metal halide lamp
- 150W high pressure lamp with the 100W pulse start metal halide lamp and magnetic ballast
- 200W/250W high pressure lamp with the 175W pulse start metal halide lamp and magnetic ballast
- 400W high pressure lamp with the 320W/350W pulse start metal halide lamp and magnetic ballast
- 1000W high pressure lamp with the 750W/875W pulse start metal halide lamp and magnetic ballast

For the replacements above, except for the integrated lamps, the appropriate magnetic ballast must be used with the retrofitted lamp.

HIGH INTENSITY DISCHARGE ELECTRONIC BALLASTS

The Program incentive applies to high pressure sodium and pulse start metal halide/ceramic metal halide electronic ballasts, low-frequency or high-frequency.

HID electronic ballasts must:

- Meet all ANSI requirements
- CSA or CUL approved
- Ballast factor of 0.85 to 1.0.
- Power Factor > 90%.
- Total Harmonic Distortion of < 32%.
- minimum ballast efficiency of 90 percent for lamp wattages <= 250W
- minimum ballast efficiency of 92 percent for lamp wattages > 250W

HIGH INTENSITY DISCHARGE LIGHTING FOR ORNAMENTAL STREET LIGHTING

The Program incentive applies to street and roadway lighting systems for new and retrofitted luminaires.

- High intensity discharge luminaires are eligible for incentives when displacing mercury vapor, metal halide or high pressure sodium luminaires of higher wattage.
- Optical improved HPS retrofit kits are eligible for an incentive if they retrofit high pressure sodium luminaires of higher wattage.
- All new replacement energy efficient luminaires or (optical improved) retrofit kits must be flat lens.

BC Hydro e.Catalog
Product Acceptance Criteria

- Any new replacement luminaires and/or retrofit kits should be minimum 15% more efficient than the one it replaces.
- The replacing energy efficient new/ retrofitted luminaires have to provide a suitable lighting output meeting the required IESNA and/or any federal, provincial or municipal codes that apply.

The Program incentive applies to the replacement of the following high intensity discharge streetlights (including retrofit kits):

- 100W HPS unit with the 70W energy efficient unit completed with flat lens.
- 150W HPS unit with the 100W energy efficient unit completed with flat lens.
- 200W HPS unit with the 150W energy efficient unit completed with flat lens.
- 250W HPS unit with the 150W or 200W energy efficient unit completed with flat lens.
- 400W HPS unit with the 250W energy efficient unit completed with flat lens.
- 100W MH unit with the 70W or 75W energy efficient HPS or MH unit with flat lens.
- 150W MH unit with the 100W energy efficient HPS or MH unit with flat lens.
- 175W MH unit with the 150W energy efficient HPS or MH unit with flat lens.
- 250W MH unit with the 150W energy efficient HPS or 175W energy efficient MH unit with flat lens.
- 175W MV unit with the 100W energy efficient HPS or MH unit with flat lens.
- 250W MV unit with the 150W energy efficient HPS or MH unit with flat lens.
- 400W MV unit with the 250W energy efficient HPS or MH unit with flat lens.

HID HIGH / LOW SWITCHING SYSTEM

- High / Low switching system shall be a complete system to allow the controller switching of High Intensity Discharge (HID) luminaires, including Metal Halide, Pulse Start Metal Halide and High Pressure Sodium, from full ballast power input in High mode to 50% or less ballast power input in Low mode.
- Input for lighting control shall be accomplished by manual or automated controls, light level photosensor or occupancy sensor control.
- High / Low switching system shall start all lamps in high mode during initial start-up and shall restrict system from switching modes during initial lamp warm-up cycle.
- High / Low switching shall be accomplished with zero or no lamp strobing or drop out.
- Where photo sensor control is used to initiate High / Low switching system, controls shall have adjustable sensitivity.
- Where occupancy sensor control is used to initiate High / Low switching system, sensors shall be a Passive Infrared (PIR) type, designed for narrow pattern detection zone and oriented downward toward the floor or target area.
- High / Low switching systems shall be a complete system ready for wiring and installation. System shall include mounting and come with all components including any; contactors, low voltage relays, isolated relay contacts, power packs, interfaces, control mounting boxes, manual switches and photo sensors as required to interface with high / low switching ballasts to provide fully functional control of HID luminaires.
- Sensors shall have advanced signal-processing, integrated circuitry to provide high immunity to RFI and EMI influences. Low voltage photo sensors shall be powered by a self contained low-voltage power pack.

BC Hydro e.Catalog
Product Acceptance Criteria

- High / Low control systems shall be manufactured by luminaire manufacturer or system approved by ballast and luminaire manufacture for interface with luminaire ballast.
- High / Low control systems and all components shall have a minimum five year manufacturers warranty from the date of installation

INDUCTION LUMINAIRES FOR INDOOR AND OUTDOOR LIGHTING APPLICATIONS

The program incentive applies to the replacement of interior and street/ area luminaires that use induction (electrodeless) technology.

- Induction luminaries or retrofit kits are eligible for incentives when displacing mercury vapour, metal halide or high pressure sodium high intensity discharge (HID) luminaires of higher wattage
- The luminaire conversion must save a minimum of:
 - 50W if the replaced HID lamp is under 175W
 - 100W if the replaced HID lamp is greater than or equal to 175W
- The ballast must have a power factor greater than 0.95
- The ballast must have a total harmonic distortion of less than or equal to 20%
- The induction lamp and ballast must be rated for an operating ambient temperature of between -20°C and +40°C or better
- Induction lamp and ballast must have at least a 5-year maintenance warranty
- Manufacturers of induction luminaires must be able to provide IES photometric data for their products
- The replacing energy efficient new/ retrofitted luminaires have to provide a suitable lighting output meeting the required IESNA and/or any federal, provincial or municipal codes that apply.
- It is the responsibility of the customer and/or installing contractor to ensure that the new luminaires are CSA certified or approved by an accredited third party laboratory for the specific application, and in full compliance with the building codes

LED EXIT SIGNS

The Program incentive applies to the following retrofits that are applicable under this Program:

- All new LED exit signs and retrofit kits
- LED conversion kits comprising 2 screw-in lamps with diffuser or 1 bar with diffuser for existing signs. Options to purchase LED single lamps are available, however two are required per sign.
- Options are available for conversions from either existing incandescent or CFL exit signs.

To be eligible for an incentive, the retrofit must:

- Meet Energy Star guidelines,
- Comply with CSA standards C22.2 No. 9.0 and C860; (Note if the retrofitted sign cannot comply it must be replaced),
- Have a minimum of 1-year warranty.

For new exit signs a maximum of 2.0 input watts is allowed and for new self powered exit signs a maximum of 3.5 input watts is allowed.

LED conversion kits shall be permanently mounted within the housing with any unused incandescent lamp sockets and any diodes removed or disabled. Any necessary stand-by DC lamps may remain. Retrofit kits shall be identified as such, including lamp wattage. Retrofit kits shall include a replacement diffuser, to

BC Hydro e.Catalog
Product Acceptance Criteria

ensure correct luminance levels are maintained. The existing high density, red diffuser, designed to diffuse the high brightness of the incandescent source, must be replaced with a less dense diffuser designed for use with the LED source.

NON-ELECTRICAL EXIT SIGNS

The Program incentive applies to the following retrofits that are applicable under this Program:

- New non-electrical, self illuminated exit signs using Tritium gas (H3) luminous tubes
- Options are available for conversions from either existing incandescent or CFL exit signs.

To be eligible for an incentive, the retrofit products must:

- Be approved by BCH-PS Engineering
- Comply with CSA standards C22.2 No. 9.0 and C860 and all other existing Provincial Building code and City Bi-Laws in effect.
- Have minimum initial brightness of 0.15FI (0.5 cd/m²)
- Brightness variation between letters to not exceed 3:2
- Minimum 16 years useful life
- Have a minimum of 1-year warranty.

Photoluminescent signs that need the presence of an additional light source are NOT eligible.

LED REPLACEMENTS FOR INCANDESCENT LAMPS AND LUMINAIRES

The Program incentive applies to:

- LED direct replacements for MR Halogen Dichroic lamps.
 - LED MR16 lamps greater than 200 lumen to replace MR halogen (or HIR) lamps greater than or equal to 20W
- LED replacements for all screw-base, incandescent/ halogen lamps, or new LED luminaires when replacing incandescent/ halogen luminaires.
 - Ominidirectional LED lamp with minimum 450 lumen to replace 40W/60W incandescent lamps
 - Decorative LED lamp with less than 450 lumen to replace decorative 25W/35W incandescent lamps
 - LED Reflector lamp (BR, R, PAR lamps) with maximum 600 lumen (check below chart for minimum light output for each lamp type) to replace halogen reflector lamps less than or equal to 60W
 - LED Reflector lamp (BR, R, PAR lamps) with greater than 600 lumen to replace halogen reflector lamps greater than 60W and less than or equal to 100W
 - maximum 15W LED luminaires to replace maximum 60W incandescent/ halogen
 - LED luminaires greater than 15W are allowed to replace incandescent/ halogen greater than 60W

Following are technical criteria for LED lamps:

- LED MR16 lamps can be standard 2 pin MR16 GX 5.3 base (12V AC/DC) or GU10 (120V) screw-in base.
- Screw-in replacements LED lamps shall have screw-in or pin base similar with the replaced incandescent/ halogen lamps.
- Screw-in replacements LED retrofit kits shall have screw-in or pin connectivity similar with the replaced incandescent/ halogen lamps.

BC Hydro e.Catalog
Product Acceptance Criteria

- For LED luminaires, or direct replacement LED lamps, the total input wattage has to include the losses to the source.
- LED lamps can be white or coloured.
- It is the responsibility of the customer and/or installing contractor to ensure that the new lamps meet the current BC Electrical Code requirements.
- LED products currently do not have the equivalent visual performance measures designed for conventional technologies such as CRI and CCT. Customer should test and try out the LED's color appearance before purchase. Recommend CRI above 80.
- Provide LM-79 and 6000 hours of Lumen Maintenance test meeting the following criteria defined by Energy Star and DesignLights Consortium. Testing must be conducted by a NVLAP accredited lab.

Application	Minimum Light Output	Zonal Lumen Density	Minimum Luminaire Efficacy	Power Factor	Allowable CCTs (ANSI C78.377-2008)	Minimum L70 Lifetime
Track or Mono-point Directional Lighting Fixtures	250 L	>85% 0-90°	30 lm/W	0.9	2700K, 3000K, 3500K, 4000K, 5000K	50,000 hrs
Recessed, surface and pendant-mounted downlights	<4.5" 345 L, >4.5" 575 L	75% 0°-60°	35 lm/W	0.9	2700 K, 3000 K, 3500 K, 4000K, 5000K	35,000 hrs (94.1%)
Under cabinet shelf-mounted task Lighting	125 L/ft	60% 0°-60°, 12.5% 60°-90°	29 lm/W	0.9	2700K, 3000K, 3500K, 4000K, 5000K	35,000 hrs
Wall wash luminaires	575 L	50% 20°-40°	40 lm/W	0.9	2700K, 3000K, 3500K, 4000K, 4500K, 5000K	35,000 hrs
Bollards	N/A	<15% 90°-110°, 0% >110°	35 lm/W	0.9	NA	35,000 hrs
Omnidirectional LED lamp	Target wattage of lamp replaced: 25W - 200 lm 35W - 325 lm 40W - 450 lm 60W - 800 lm 75W - 1100 lm 100W - 1600 lm 125W - 2000 lm 150W - 2600 lm	N/A	40 lm/W	0.7 for lamp > 5W	2700K, 3000K, 3500K, 4000K, 5000K	25,000 hrs (91.8%)

**BC Hydro e.Catalog
Product Acceptance Criteria**

Directional LED lamp (MR, PAR, R)	Equal to target wattage of the lamp replaced *10 MR16 - 200 lm R20 - 300 lm BR30/R30 - 600 lm PAR20 - 350 lm PAR30 - 350 lm PAR38 - 450 lm R40/BR40 - 650 lm	N/A	40 lm/W	0.7 for lamp > 5W	2700K, 3000K, 3500K, 4000K, 5000K	25,000 hrs
Decorative LED lamp	N/A	N/A	30 lm/W	N/A	2700K, 3000K, 3500K, 4000K, 5000K	15,000 hrs (86.7%)

LARGE WATTAGE LED LUMINAIRES FOR INDOOR AND AREA LIGHTING

The Program incentive applies to:

- Complete large wattage (higher than 5W) LED direct replacements of HID (Metal Halide, High Pressure Sodium) technology for indoor and outdoor area applications.
- LED Retrofit kits or new LED luminaires can be:
 - Low/high pole/ stand/ bollard or surface mounted for area/ parking lighting
 - Low/high bay surface or recessed mounted for warehouses, parking garages and other applications that require reliable low maintenance lighting
- Suggested LED direct replacements of HID technology: 50W to 250W for indoor (parking and low-bay) and 50W to 400W for outdoor area lighting
- The LED luminaire conversion must save a minimum of:
 - 50 input watts if the replaced HID lamp is up to and including 150W
 - 100 input watts if the replaced HID lamp is greater than or equal to 175W

Following are technical criteria for LED indoor and outdoor luminaires:

- It is the responsibility of the customer and/or installing contractor to ensure that the retrofit kits/ new luminaires meet the current Canadian Electrical Code requirements.
- Lighting levels after the retrofit must meet the requirements of the end user and be to the satisfaction of all approving authorities having jurisdiction for specific applications.
- LED retrofit kits or new luminaires to be provided with LED modules/ kits, optical/ reflector installations, protective lenses, integral connectivity wiring, mounting accessories, power supply/ driver and controls as per the manufacturer specifications. New or retrofitted LED luminaires to be sealed and suitable for outdoor wet locations as required by electrical code.
- Have CSA or ULC certification
- Have acceptable thermal management control for the LED modules.
- LED products currently do not have equivalent visual performance measures designed for conventional technologies such as CRI and CCT. Customer should test and try out the LED's color appearance before purchase. Recommend CRI above 70.
- Provide LM-79 and 6000 hours of lumen maintenance test (or LM-80 and In situ Temperature Measurement test) meeting the following criteria defined by DesignLights Consortium. LM79 testing must be conducted by a NVLAP accredited lab. In situ temperature measurement testing must be

BC Hydro e.Catalog
Product Acceptance Criteria

conducted by Nationally recognized testing lab approved by OSHA or labs qualified under the DOE CALiPER. For 347V LED equipment the 120V test measurement results are admissible.

Application	Minimum Light Output	Zonal Lumen Density	Power Factor	Minimum Luminaire Efficacy	Minimum L70 Lifetime
Outdoor Pole/Arm-Mounted Area and Roadway Luminaires	1000 lm	100% 0-90°, <10% 80-90° plus meet IES Type I, II, III, IV, or V	0.9	50 lm/w	50,000 hrs (95.8%)
Outdoor Pole/Arm-Mounted Decorative Luminaires	1000 lm	95% 0-90°	0.9	40 lm/w	50,000 hrs
Outdoor Wall-Mounted Area Luminaires	300 lm	100% 0-90°, <10% 80-90°	0.9	40 lm/w	50,000 hrs
Parking Garage/Low bay Luminaires	2000 lm	>20% 60-70°, >15% 70-80°	0.9	56 lm/w	50,000 hrs
High-bay and Low-bay fixtures for commercial and industrial buildings	10,000 lm	>=30% 20-50°	0.9	60 lm/W	35,000 hrs AND 3-year warranty
High-bay-Aisle Lighting	10,000 lm	>=50% 20-50°, >=30% 0-20°	0.9	60 lm/W	35,000 hrs AND 3-year warranty

LED COMMERCIAL AND ARCHITECTURAL SIGNS

The Program incentive applies to:

- direct replacements for commercial neon signs of the linear or channel letters type and for architectural linear neon or cold cathode luminaires. **Where the length of the existing sign differs from the length of the replacement sign, the incentive is calculated on the shorter length.**
- replacements for commercial fluorescent signs. LED replacements modules will be considered as replacing individual rows of fluorescent lamps. Calculations will consider the linear length of the modules as a multiplication of the length of fluorescent rows times the number of rows.
For example: for a fluorescent sign size 4'x9' containing 2 x 8' T12 lamps, incentives will be based on a total LED linear length of 16'.

Following are technical criteria for LED signs

- It is the responsibility of the customer and/or installing contractor to ensure that the new lamps meet the current Canadian Electrical Code requirements.
- LED retrofit kits for commercial signs to be provided with LED modules, integral connectivity wiring, mounting accessories, power supply/ driver and controls as per the manufacturer specifications. New or retrofitted tubes or case sign to be sealed and suitable for outdoor wet locations as required by electrical code.
- Under work conditions as specified by manufacturers, LED modules will have an average rated lamp life of:
 - over 50,000 hours, for red, orange and yellow/ amber

BC Hydro e.Catalog
Product Acceptance Criteria

- over 20,000 hours, for green, blue and white
- and a minimum warranty of 3 years

LED REFRIGERATED LIGHTING

The program applies to:

- LED luminaires used for refrigerated lighting for enclosed, front window door, product displays in grocery stores, and convenience stores.
- Refrigerated LED luminaires are direct replacements for T12 HO and T10 VHO refrigerated lighting systems.

Following are technical criteria for refrigerated LED lighting systems:

- It is the responsibility of the customer and/or installing contractor to ensure that the new lamps meet the current Canadian Electrical Code requirements.
- Retrofit kits for refrigerated LED Lighting systems have to be designed for this type of application and be provided with LED modules, integral connectivity wiring, mounting accessories, power supply/ driver and controls as per the manufacturer specifications.
- LED products currently do not have equivalent visual performance measures designed for conventional technologies such as CRI and CCT. Customer should test and try out the LED's color appearance before purchase. Recommend CRI above 70.
- Provide LM 79 and 6000 hours of lumen maintenance test (or LM-80 and In situ Temperature Measurement test) meeting the following criteria defined by DesignLights Consortium. LM79 testing must be conducted by a NVLAP accredited lab. In situ temperature measurement testing must be conducted by Nationally recognized testing lab approved by OSHA or labs qualified under the DOE CALiPER.

Application	Minimum Light Output	Maximum Light Output	Zonal Lumen Density	Minimum Luminaire Efficacy	Power Factor	Allowable CCTs (ANSI C78.377-2008)	Minimum L70 Lifetime
Refrigerated Case Lighting	Center-mounted*: >100 lm/ft End-mounted**: >50 lm/ft	Center-mounted*: <300 lm/ft End-mounted**: <150 lm/ft	10°-90°: ≥95%	35 lm/W	0.90	2700K, 3000K, 3500K, 4000K, 4500K, 5000K	50,000 hrs AND 5-year warranty

LIGHTING CONTROLS

The Program incentive applies to the following lighting controls:

- Timers (switch plate mounted) – add interior space where no automated controls existed. Incentive is offered per circuit.
- Occupancy/motion sensors – add to interior space where no automated controls existed. Incentive is offered per circuit and hardwired only with or without an override mechanism.

BC Hydro e.Catalog
Product Acceptance Criteria

- Photocells with timers – add to outdoor high intensity discharge luminaires where only photocell existed. Incentive is offered per luminaire.
- Photocells for daylight harvesting – refer to Fluorescent T8 Dimming ballasts.

CONTROLS AND SENSORS

VENDING MACHINE CONTROLLER

The vending machine controller (VMC) is an energy control device for refrigerated vending machines that provides a simple and cost-effective way to reduce electrical loads. Using an occupancy sensor, the VMC turns off the machine when no one is nearby. Incentive is provided on a one controller per machine basis.

Technical Requirements For Vending Machine Controller

- Optimal VMC occupancy sensor positioning is key to minimize false or insufficient triggering that could impact energy savings or product sales.
- Each vending machine must be connected to a separate vending machine controller. Powering more than one vending machine through one vending machine controller will result in voided warranty and a potential fire hazard.
- It is essential that the vending machine controller does not face any reflective surfaces, even for example a glass door housing a fire extinguisher, as the sensor may sense constant occupancy and run the vending machine fully on 24/7. If this occurs on a defective vending machine it may create a safety hazard.
- The following vending machine end use applications will **not** be eligible for incentives:
 - Indoor Locations: Inside specific 24-hour facilities that have vending machines will not be retrofitted due to the relative constant activity that result in low savings. These are 24-hour convenience stores and employee break rooms in 24-hour operations, hospital cafeterias etc.
 - Outdoor Locations: Within 60' of a public street or where the VMSC would be subject to direct weather contact.
 - Vending machines that contain perishable goods.
 - Sited machines that do not have a wall behind it or a wall that is not suitable for mounting the vending machine controller (such as glass.)

PARKING LOT CONTROLLER

The parking lot controller is a device which controls electricity going to outdoor plugs thereby allowing effective management of electricity use for heating car engine blocks in cold weather.

Technical Requirements For Parking Lot Controller

- All parking lot controllers must include outside temperature control.
- The controllers must be rated for exterior use with satisfactory operation from -40°C (-40°F) to +40°C (+104°F).
- Minimum product warranty shall be one year from the date of installation.
- All controllers shall be new and CSA or UL approved or certified by an accredited independent organization to conform to CSA Standards for the intended application.
- Controller components shall not contain hazardous components.

BC Hydro e.Catalog
Product Acceptance Criteria

- Any subsequent significant reduction in controller quality and/or performance may result in excluding this product from the list of eligible vendors.

VOLTAGE OPTIMIZATION

By reducing voltage levels towards the lower limits of the CSA standard CAN3-C235-83, the energy consumption for certain types of end uses can be reduced. Voltage can be reduced within a customer's facility by conducting transformer tap changes (if available) and/or installing voltage optimization devices.

All Voltage Optimizations projects will be evaluated on an individual basis by Power Smart Engineering. Energy Savings and appropriate product selection will be reviewed at application stage.

COMPUTER MANAGEMENT

POWER MANAGEMENT SOFTWARE FOR COMPUTER WORKSTATIONS

Customers may only apply for a power management software incentive once for a computer workstation and the software must be for a new installation. Software upgrades or brand switching are ineligible

The Program incentive applies to software which:

1. reduces the on-time of computers and their monitors or screens.
2. may be deployed by means of a LAN network and/or by individual workstation installation
3. end users may not alter power save features
4. is not free
5. is proven to work as confirmed by third-party or BC Hydro pilots, and at BC Hydro's discretion
6. is applied to PC workstations only – laptops, laptop stations and thin clients are not eligible

Customers may only apply for a power management software incentive once for a computer workstation and the software must be for a new installation. Software upgrades or brand switching are ineligible.

EFFICIENT POWER BARS FOR COMPUTER WORKSTATIONS

The Program incentive applies to efficient power bars used for commercial computer workstations:

Technical Requirements For Timer Based Smart Power Bars:

- The timer based power bar must use digital timer and not mechanical controls.
- The timer power bar must be programmable.
- The timer power bar must include a digital LED screen.
- These power bars are not recommended to shut down computers or control equipment.

Technical Requirements For Current Sensor Smart Power Bars:

- Include Safe Passive Current Sensor based switching.
- The current sensor power bar must automatically switch off peripheral plug load from it's control plug outlet.
- The current sensor power bar must prohibit false switching for example by incorporating resistor-capacitor circuit filters.
- Computers should be plugged into the colour coded (often coloured red) power bar sockets where they will be left powered on.

Additional Technical Requirements For Efficient Power Bars:

- The smart power bar must be CSA, cUL or UL approved.

BC Hydro e.Catalog
Product Acceptance Criteria

- The smart power bar must have a 3-prong grounded plug outlet.
- The smart power bar must offer electrical 3-way surge protection as follows: (1) Live to neutral (2) live to ground and (3) neutral to ground.
- The smart power bar must be designed to run on 120V ac 60 Hz ac mains power.

UPS

UPS systems in e.Catalog should offer an electrical energy efficiency of $\geq 92\%$ at 30% load factor. This means the UPS systems will be either Delta-Conversion or Flywheel with only a few Double-Conversion UPS systems qualified.

NETWORK TRAFFIC ANOMALY MONITORING/DETECTION SENSORS

- The product must be commercially available and used in the marketplace.
- The product must replace network hardware with electrical demand $\geq 40W$.
- The product must have an electrical demand $\leq 20W$.
- The product must be CSA, CSA/UL or UL approved.

HIGH VOLUME COLOUR PRINTER

- For printers and copiers to be eligible for inclusion in BC Hydro e.Catalog, the products must be Energy Star approved.
- Only high volume colour and black and white printers qualify for e.Catalog which capable of printing typical workloads of 100,000 printed pages per month per printer
- Maximum printing speeds need be ≥ 100 ppm (printed pages per minute)
- The electrical energy consumption for printers conforming to 1. and 2. above must be ≤ 90 kWh/month/printer

Optional:

- Printers need conform to the above essential high volume colour or black and white printer criteria but use heatless printing process's.
- Printers need conform to the above essential high volume colour or black and white printer criteria but include organic printer inks

SERVER

Server OEM's need clearly specify that their servers are energy efficient and be listed on the Energy Star website as conforming to Energy Star criteria.

http://www.energystar.gov/ia/products/prod_lists/enterprise_servers_prod_list.xls

POWER DISTRIBUTION UNITS (PDU) FOR DATA CENTERS

- Only PDU's which have energy efficient power supplies with energy efficiency levels equivalent to Energy Star specifications for server power supplies:
http://www.energystar.gov/ia/partners/product_specs/program_reqs/computer_server_prog_req.pdf

BC Hydro e.Catalog
Product Acceptance Criteria

Power Supply Type	Rated Output Power	10% Load	20% Load	50% Load	100% Load
Multi-Output (AC-DC & DC-DC)	All Output Levels	N/A	82%	85%	82%
Single-Output (AC-DC & DC-DC)	≤ 500 watts	70%	82%	89%	85%
	> 500 - 1,000 watts	75%	85%	89%	85%
	> 1,000 watts	80%	88%	92%	88%

- Only PDU's which have energy efficient power supplies with Power Factor levels equivalent to Energy Star specifications for server power supplies:

http://www.energystar.gov/ia/partners/product_specs/program_reqs/computer_server_prog_req.pdf

Power Supply Type	Rated Output Power	10% Load	20% Load	50% Load	100% Load
DC-DC (All)	All Output Levels	N/A	N/A	N/A	N/A
AC-DC Multi-Output	All Output Levels	N/A	0.80	0.90	0.95
AC-DC Single-Output	≤ 500 watts	N/A	0.80	0.90	0.95
	> 500 - 1,000 watts	0.65	0.80	0.90	0.95
	> 1,000 watts	0.80	0.90	0.90	0.95

HVAC

VARIABLE FREQUENCY DRIVE

A Variable Frequency Drive (VFD) is an add-on for an HVAC fan or pump with a 10 HP and greater motor.

In regards to installation requirements, the VFD supplier must visit the site and recommend the appropriate VFD drive, filters and line/load reactors suitable for the existing motor to avoid premature motor failure.

VFD incentives are for fan and pump applications on HVAC distribution systems. The maximum fan size is 100 HP. The installation of a VFD on a HVAC fan or pumps is eligible for a rebate only if throttling devices, such as inlet vanes, bypass dampers and throttling valves, are removed or permanently disabled.

VARIABLE SPEED ELECTRONICALLY COMMUTATED MOTOR (ECM) BASED PUMPS

The pump utilises an electronically commutated motor (ECM) technology and an integral variable speed drive to deliver up to 75% energy savings compared to a conventional single speed pump. It provides automatic adjustment of pump performance to the continually changing hydraulic system load conditions. The pump has an Energy Efficiency Class A rating in the European Energy labelling scheme.

The incentive applies to ECM-based pumps that are 1 to 2 HP and used in heating applications. This product may be used in large residential buildings, apartment blocks, housing developments, commercial real-estate complexes, hospitals, schools, as well as industrial and institutional buildings.

BC Hydro e.Catalog
Product Acceptance Criteria

The circulating pumps are used to circulate liquids in

- Warm or hot water heating systems, not cooling systems
- Closed circulation systems

Careful pump sizing should be encouraged when selecting a replacement to ensure that the sizing range of the system falls within the duty range of the pump.

HVAC OCCUPANCY SENSOR

The Program incentive applies to the HVAC occupancy sensor control for a packaged terminal air conditioning unit or a heat pump unit, with built-in electric resistance heater. The program offers incentive per packaged terminal air conditioning unit or heat pump unit controlled by the sensor. This incentive is only eligible to applications in hotel/motel and strata units.

Recommended features of the occupancy sensor:

- Dual sensing technology – passive infrared (PIR) and motion sensing
- At least three possible temperature settings (unoccupied, occupied, sleep, unsold)
- Pre-programmed with default setpoint temperatures – published in the specification sheet and made available to customers

TEMPERATURE SENSORS FOR ECONOMIZERS

The new replacement dry bulb temperature sensor:

- Has a changeover dead band of no more than 2 degrees Fahrenheit, providing greater accuracy for when and when not to use outdoor air for cooling.
- Has selectable temperature settings.
- Is easy to replace in the field.
- Is to be used with single temperature change over with the sensor located in the outdoor air.
- Is compatible with existing economizer logic modules.
- The rooftop units that will have the temperature sensor replaced should have 7.5 tons cooling capacity or greater.

AIR-COOLED ELECTRIC CHILLERS

The table below outlines the energy efficiency source and criteria applied.

Compressor Type and Capacity	Full Load (kW/Ton)	IPLV (kW/Ton)	Criteria Source
Scroll 30-60 Tons	1.23 or less	0.86 or less	FEMP
Reciprocating 30-150 Tons	1.23 or less	0.90 or less	FEMP
Screw 70-200 Tons	1.23 or less	0.98 or less	FEMP

Chiller Efficiency Criteria

The table below outlines the energy efficiency source and criteria applied.

Product Type	Full Load (kW/Ton)	IPLV (kW/Ton)	Criteria Source
Centrifical 150-299 Tons	0.59 or less	0.52 or less	FEMP
Centrifical 300-2,000 Tons	0.56 or less	0.45 or less	FEMP
Rotary Screw \geq 150 Tons	0.64 or less	0.49 or less	FEMP

**BC Hydro e.Catalog
Product Acceptance Criteria**

UNITARY AIR-CONDITIONERS AND CONDENSING UNITS

The table below outlines the energy efficiency source and criteria applied. Note this criteria also applies to split air conditioning systems.

Equipment Type	Size Category	Specification	Criteria Source
Air-Source Conditioners (3 phase)	<65,000 Btu/h	≥ 13 <u>SEER</u>	Energy Star
Air-Source Conditioners	≥65,000 Btu/h - <135,000 Btu/h	≥ 11.0 EER; 11.4 IPLV	Energy Star
Air-Source Conditioners	≥135,000 Btu/h - <250,000 Btu/h	≥ 10.8 EER; 11.2 IPLV	Energy Star
Air-Source Conditioners	>250,000 Btu/h	≥ 10.0 <u>EER</u>	Energy Star
Water Source	<65,000 Btu/h	≥ 12.0 EER	Energy Star
Water Source	≥65,000 Btu/h - <135,000 Btu/h	≥ 11.5 EER	Energy Star
Water Source**	>135,000 Btu/h	≥ 11.0 EER	Energy Star
Condensing units, water or evaporative cooled	–	≥ 12.9 IPLV	Energy Star

** Includes Evaporative Condenser and Evaporative Pre-Cooled Condenser

REFRIGERATION

LOW TEMPERATURE VERTICAL DISPLAY CASE

Replace an existing open low temperature vertical display case with a new low temperature vertical display case equipped with glass or acrylic doors, new electronically commutated fan motor(s) (ECM), T8 lamps, and electronic ballasts. Additional separate rebates cannot be claimed for new ECM fan motor(s) or T8 lamps and electronic ballasts. New case length must be equal or shorter than the original case. The rebate is limited to low temperature vertical display cases with a case temperature below –18 °C (0 °F). The rebate for this measure applies to self-contained or remote cases. Rebate is based on the linear footage (horizontal length) of the cases installed.

ADDING GLASS DOORS TO LOW TEMPERATURE VERTICAL DISPLAY CASE

Install glass or acrylic doors on existing low temperature open vertical display cases to reduce the loss of cold air and infiltration of warm air. The rebate is limited to low temperature vertical display cases with a case temperature below –18 °C (0 °F). The rebate for this measure applies to self-contained or remote cases. Rebate is based on linear footage (horizontal length) of the doors installed..

ANTI-SWEAT HEATER (ASH) HUMIDISTAT CONTROL FOR VERTICAL DISPLAY CASE

Install a device that reduces the operation of the anti-sweat heaters by at least 50% (from 100%) for the glass door and door frame. Technologies that reduce or turn off anti-sweat heaters based on simple timing or by sensing humidity or condensation qualify. Timer must not be equipped with a “hold-on” feature. This rebate does not apply to the Special Doors with No Anti-Sweat Heat Controls (ASH) measure. The rebate for this measure applies to remote cases only. Rebate is based on the number of doors controlled.

BC Hydro e.Catalog
Product Acceptance Criteria

EVAPORATOR FAN MOTOR (ECM)

Applicable to existing shaded pole or permanent split capacitor evaporative fan motor on low or medium temperature display cases and fan coil system of low or medium temperature walk-ins. The rebate for this measure applies to remote cases and remote walk-ins only. Rebate is a fixed amount per motor installed. This rebate cannot be claimed in conjunction with the low temperature vertical display case rebate. The existing fan motor must be replaced by an electronically commutated motor(s) (ECM) with the following efficiencies:

Existing Configuration	Retrofit ECM Efficiency
Walk in coolers (low and medium temperature)	> 70% efficiency
Reach-in refrigerated cases (Low and medium temperature)	> 65% efficiency

NIGHT COVERS FOR OPEN VERTICAL DISPLAY CASE (LOW OR MEDIUM TEMPERATURE)

Install a cover on an otherwise open low or medium temperature vertical display case to decrease infiltration of warm air into the case at night. The case manufacturer must have no objections to the use of such front covers. It is recommended that film type covers have small, perforated holes to decrease moisture buildup. The rebate for this measure applies to self-contained or remote cases. Rebate is based on linear footage (horizontal length) of night cover installed.

NIGHT COVERS FOR OPEN LOW TEMPERATURE HORIZONTAL DISPLAY CASE

Install a cover on an otherwise open horizontal display case to decrease infiltration of warm air into the case at night. The case manufacturer must have no objections to the use of such covers. It is recommended that film type covers have small, perforated holes to decrease moisture build-up. The rebate is limited to low temperature horizontal display cases with a case temperature below -18°C (0°F). The rebate for this measure applies to remote cases only. Rebate is based on linear footage (horizontal length) of night cover installed.

STRIP CURTAINS FOR WALK-INS (LOW OR MEDIUM TEMPERATURE)

Install new strip curtains on doorways of low or medium temperature walk-ins. The rebate for this measure applies to self-contained or remote walk-ins that currently do not have curtains. Rebate is based on square footage of strip curtain installed.

COMPACT REFRIGERATOR

For classification as a compact refrigerator it must have a volume not exceeding 7.75 cu. ft. and overall height no greater than 38in. It must pass the CAN/CSA C300-00 test standard and in addition meet the most recent Energy Star Guidelines. The compact refrigerator must not be used in any food preparation locations in accordance with appropriate standards. The compact refrigerator must replace an existing fridge of similar size.

BARE SUCTION PIPE INSULATION

Pipe insulation must meet the below criteria:

- Temperature of refrigeration is required to be below 2°C

BC Hydro e.Catalog
Product Acceptance Criteria

- Insulation material must be flexible, closed-cell polyethylene foam with a maximum thermal conductivity of 0.27 Btu-in/hr-ft²-F
- The minimum insulation thickness is 1 inch
- Maximum pipe diameter: 1.5 inches
- Incentive is only available for insulating existing bare refrigeration suction pipes

BC Hydro e.Catalog
Product Acceptance Criteria

COMMERCIAL KITCHEN

ELECTRIC GRIDDLE

This incentive applies towards the replacement to energy efficient electric griddles. Used or rebuilt equipment and fuel switching applications are not eligible for incentives. Customers must provide proof that the appliance is Energy Star rated.

ELECTRIC PRESSURELESS STEAMER

This incentive applies towards the replacement to energy efficient electric steamers (fuel switching applications are not eligible). Used or rebuilt equipment is not eligible. Customers must provide proof that the appliance is Energy Star® rated.

CONVECTION OVEN

This incentive applies towards the replacement to energy efficient electric convection ovens (fuel switching applications are not eligible). Customers must provide proof that the appliance meets ASTM F1496 tested with 70% or greater energy efficiency.

COMBINATION OVEN

This incentive applies towards the replacement to energy efficient electric combination ovens for heavy load cooking energy efficiency ASTM F1639-05 $\geq 60\%$

DEMAND VENTILATION CONTROLS

This incentive applies towards the retrofit to demand ventilation controls for dedicated (single zone) commercial kitchen exhaust and make-up air systems. The control system must be used in conjunction with variable speed fan motor controls.

INSULATED HOT FOOD HOLDING CABINET

This incentive applies towards the replacement to energy efficient commercial electric hot food holding cabinets. This measure does not include cook and hold equipments. All measures must be electric hot food cabinets that are fully insulated and have solid doors in half sizes (internal volume less than or equal to 10 ft³) and full sizes (internal volume less than or equal to 20 ft³ and greater than 15 ft³). Used or rebuilt equipment is not eligible. Customers must provide proof that the appliance meets a maximum idle energy rate of 20 W/ft³. Eligible products must be CEE Tier 2 rated.

REFRIGERATORS AND FREEZER

This incentive applies towards the replacement to energy efficient refrigerators or freezers. Used or rebuilt equipment is not eligible. Customers must provide proof the appliance is Energy Star Version 2.0 rated. Incentives are eligible for the following refrigerator sizes:

- Solid door refrigerator
 - 15-30 cu. Ft.
 - 31-50 cu. Ft.
 - > 50 cu. Ft.
- Solid door freezer
 - < 15 cu. Ft.
 - 15-30 cu. Ft.
 - 31-50 cu. Ft.
 - >50 cu. Ft.
- Glass door refrigerator

BC Hydro e.Catalog
Product Acceptance Criteria

- 31-50 cu. Ft.
- >50 cu. Ft.

ICE MAKING MACHINES

This incentive applies towards the replacement to energy efficient Air cooled ice machines that are CEE Tier 3 rated. Customers must provide proof that the appliance is CEE Tier 3 rated. Used or rebuilt equipment is not eligible.

Commercial Making Ice Machines (ice making head)

- Inefficient ice machines (<450 lbs of ice/ 24 hours) replaced with CEE Tier 3 ice machine
- Inefficient ice machines (>= 450 lbs of ice/ 24 hours) replaced with CEE Tier 3 ice machine

Commercial ice making machines (remote condensing with compressor)

- Inefficient ice machines (>= 934 lbs of ice/ 24 hours) replaced with CEE Tier 3 ice machine

Commercial ice making machines (self contained)

- Inefficient ice machines (<175 lbs of ice/ 24 hours) replaced with CEE Tier 3 ice machine
- Inefficient ice machines (>= 175 lbs of ice/ 24 hours) replaced with CEE Tier 3 ice machine

COMMERCIAL DISHWASHER

This incentive applies towards the replacement of an existing standard efficiency commercial dishwasher to an energy efficient commercial dishwasher. Used or rebuilt equipment is not eligible. **Only eligible for dishwashers connected to an electrically heated domestic hot water supply.** Customers must provide proof that the new appliance is Energy Star® rated.

OTHERS

LOW-E CEILING

The Program incentive applies to a foil faced radiant barrier ceiling material rated for ice arena applications. The emissivity rating must be between 0.03-0.05 (tested to ASTM #E408) with a temperature rating from – 60F (15C) to 180F (82C) and has the approved Building Code flame rating.

FIXED SPEED REDUCED FLOW PUMPS

The brine pump pony motor and variable frequency drive are add-on products used in ice arenas and curling rinks to reduce energy consumption. The Program incentive applies to the following:

- 5HP brine pump pony motor added to a 15HP brine pump
- 7.5HP brine pump pony motor added to a 20HP brine pump or 25HP brine pump
- 10HP brine pump pony motor added to a 30HP brine pump

- 15HP VFD added to a 15HP brine pump
- 20HP VFD added to a 20HP brine pump
- 25HP VFD added to a 25HP brine pump
- 30HP VFD added to a 30HP brine pump

LIVESTOCK WATERER

Energy Efficient Livestock Waterers

- These must have a minimum 2" of R10 Insulation.

BC Hydro e.Catalog
Product Acceptance Criteria

- These must have electrical heater elements of $\leq 350\text{W}$.
- Each energy efficient livestock waterer should be ≤ 50 US gallons (190L) in water holding capacity.

Energy Free Livestock Waterers

- These must have a minimum of 3.5" of R25 Insulation.
- Each energy free livestock waterer should be ≤ 50 US gallons (190L) in water holding capacity.

SYNCHRONOUS BELTS

Replacing a Vbelt with a synchronous belt installed in industrial facilities. Synchronous belts (also called timing, positive-drive, or high-torque drive belts) are toothed and require the installation of mating toothed-drive sprockets. Synchronous belts offer an efficiency of 98% and maintain that efficiency over a wide load range.