

---

**Revenue Requirement Application**

**2004/05 and 2005/06**

---



**Volume 2**

**Appendix L.**

**System Performance Indicators**

---

## **Table of Contents**

---

<b>LIST OF FIGURES</b> .....	<b>1</b>
<b>LIST OF TABLES</b> .....	<b>1</b>
<b>LIST OF SCHEDULES</b> .....	<b>1</b>
<b>SYSTEM PERFORMANCE INDICATORS</b> .....	<b>1</b>
<b>AVERAGE SYSTEM AVAILABILITY INDEX (ASAI)</b> .....	<b>1</b>
<b>SYSTEM AVERAGE INTERRUPTION FREQUENCY INDEX (SAIFI)</b> .....	<b>3</b>
<b>SYSTEM AVERAGE INTERRUPTION DURATION INDEX (SAIDI)</b> .....	<b>4</b>
<b>CUSTOMER AVERAGE INTERRUPTION DURATION INDEX (CAIDI)</b> .....	<b>4</b>

## **List of Figures**

---

Figure 1. Average System Availability Index, F1994 to F2003.....	2
Figure 2. System Average Interruption Frequency Index, F1994 to F2003 .....	3
Figure 3. System Average Interruption Duration Index, F1994 to F2003 .....	4
Figure 4. Customer Average Interruption Duration Index, F1994 to F2003.....	5

## **List of Tables**

---

None.

## **List of Schedules**

---

None.

1 **System Performance Indicators**

2 This appendix discusses BC Hydro's system performance in terms of generally accepted  
3 industry measures of service reliability. Since the mid-1980s, BC Hydro has been collecting  
4 and analyzing data that identifies specific system characteristics or components that affect  
5 performance. Concurrently, major electric utilities in Canada have been providing  
6 comparative data to the CEA so that utilities are able to monitor their performance over time  
7 as well as comparing their system performance with other utilities.

8 There are four indicators commonly used by electric utilities to measure distribution system  
9 reliability:


- 10 1. Average System Availability Index (ASAI)
- 11 2. System Average Interruption Frequency Index (SAIFI)
- 12 3. System Average Interruption Duration Index (SAIDI)
- 13 4. Customer Average Interruption Duration Index (CAIDI)

14 In the following figures, BC Hydro's reliability performance for the period F1994 to F2003 is  
15 compared to the CEA composite.

16 Average System Availability Index (ASAI)

17 ASAI, shown in Figure 1, measures the percentage of time during a year that power is  
18 available to customers. It is defined as:

19 
$$1 - \frac{\text{Interrupted Customer Hours}}{\text{Available Customer Hours}}$$
  
20



1 **Figure 1. Average System Availability Index, F1994 to F2003**

2 Since data was first collected in the mid-1980s, BC Hydro's ASAI has remained stable and  
 3 has performed better than the CEA composite for most of the period.

4 In 1998, BC Hydro's ASAI was lower than the CEA composite because of adverse weather  
 5 conditions experienced during the year. The CEA composite index for 1998 did not include  
 6 impacts of the ice storm in Quebec and Ontario. The winter in 1998/99 was the stormiest  
 7 November-March period in British Columbia in 27 years. Interrupted customer hours due to  
 8 adverse weather and tree-related problems more than tripled compared to the previous year  
 9 and accounted for 62% of the total interrupted customer hours in 1998.

10 BC Hydro's ASAI was lower in F2002 because of the impact of severe windstorms that hit  
 11 both the Lower Mainland and Vancouver Island. The three-day windstorms in December  
 12 were the cause of about 36% of the annual customer-hours lost during the 12-month period.  
 13 Steady winds measuring between 80 to 100 km/hour were recorded in some parts of the  
 14 Fraser Valley. During the storm, the above ground portion (around Texada Island) of the  
 15 transmission line to Vancouver Island became loaded with ice and failed, resulting in  
 16 significant reduction of supply to the Island.

17 There were also six major weather events in F2003. On April 14, 2002, a windstorm hit the  
 18 Lower Mainland and parts of Vancouver Island, accounting for 4.9 per cent of the total  
 19 customer-hours lost during this period. On December 15, 2002 another windstorm struck

1 the Lower Mainland and Vancouver Island and accounted for 6.9 per cent of the total  
 2 customer-hours lost during this period. On December 25-26, 2002, another windstorm  
 3 knocked down trees and power lines in the Lower Mainland, cutting electricity to parts of the  
 4 area for much of Christmas Day. The two-day storm accounted for 4.0 per cent of the total  
 5 customer-hours lost during this period. On January 2-3, 2003, another windstorm caused  
 6 widespread power outage to thousands of customers in the Lower Mainland and south  
 7 Vancouver Island for several hours. The two-day storm accounted for 8.9 per cent of the  
 8 total customer-hours lost during this period. On the morning of March 13, 2003, a powerful  
 9 windstorm blew in from the Pacific, causing numerous outages all across B.C. The storm  
 10 accounted for 2.6 percent of the total customer-hours lost during this period. Finally, on  
 11 March 22, 2003 a severe storm with high winds, heavy snowfall and lightning rolled across  
 12 the path of 5L30 and 5L32 circuits feeding Vancouver Island. The source outage accounted  
 13 for 3.1 percent of the total customer-hours lost during this period.


14 The number and magnitude of these storms over the last two years was greater than  
 15 historically experienced and expected.

16 System Average Interruption Frequency Index (SAIFI)

17 SAIFI, shown in Figure 2, measures the average number of power interruptions per  
 18 customer served during a year. It is defined as:

19 
$$\frac{\text{Total Customer Interruptions}}{\text{Total Customers Served}}$$

20



21 **Figure 2. System Average Interruption Frequency Index, F1994 to F2003**


1 BC Hydro has considerably fewer power supply interruptions than the CEA composite.

2 System Average Interruption Duration Index (SAIDI)

3 SAIDI, shown in Figure 3, measures the amount of time the average customer is without  
4 power during a year. It is defined as:

5 
$$\frac{\text{Total Customer Hours of Interruptions}}{\text{Total Customers Served}}$$

6



7

7 **Figure 3. System Average Interruption Duration Index, F1994 to F2003**


8 With the exceptions of 1998, when British Columbia experienced the stormiest November-  
9 March period in 27 years, and of F2002, when there were severe windstorms, BC Hydro's  
10 system average interruption duration index has been consistently better than the CEA  
11 composite.

12 Customer Average Interruption Duration Index (CAIDI)

13 CAIDI, shown in Figure 4, measures the amount of time the interrupted customer is without  
14 power during a year. It is defined as:

15 
$$\frac{\text{Total Customer Hours of Interruptions}}{\text{Total Customer Interruptions}}$$

16



- 1 **Figure 4. Customer Average Interruption Duration Index, F1994 to F2003**
- 2 Storms and tree-related problems in 1998 resulted in a 60% increase in customer
- 3 interruptions hours. The F2002 and F2003 windstorms that affected the Lower Mainland
- 4 and Vancouver Island also heavily impacted CAIDI.