

Integrated Resource Plan

Chapter 9

Recommended Actions

Table of Contents

9.1	Introduction	9-1
9.1.1	Recommended Action Summary	9-3
9.1.2	Action Plan Alignment with BRP & CRP Scenarios	9-5
9.1.3	Chapter Structure.....	9-7
9.2	Base Resource Plan	9-7
9.2.1	Recommended Action 1: Moderate current DSM spending and maintain long-term target	9-8
9.2.1.1	Justification.....	9-11
9.2.1.2	Execution.....	9-16
9.2.1.3	Future Review Process.....	9-19
9.2.2	Recommended Action 2: Pursue DSM capacity conservation.....	9-20
9.2.2.1	Justification.....	9-22
9.2.2.2	Execution.....	9-22
9.2.2.3	Future Approval Process	9-23
9.2.3	Recommended Action 3: Explore more codes and standards	9-23
9.2.3.1	Justification.....	9-24
9.2.3.2	Execution.....	9-24
9.2.3.3	Future Approval Process	9-24
9.2.4	Recommended Action 4: Optimize existing portfolio of IPP resources	9-25
9.2.4.1	Justification.....	9-25
9.2.4.2	Execution.....	9-26
9.2.4.3	Future Approval Process	9-27
9.2.5	Recommended Action 5: Investigate customer incentive mechanisms.....	9-27
9.2.5.1	Justification.....	9-27
9.2.5.2	Execution.....	9-28
9.2.5.3	Future Approval Process	9-28
9.2.6	Recommended Action 6: Continue to advance Site C	9-28
9.2.6.1	Justification.....	9-30
9.2.6.2	Execution.....	9-33
9.2.6.3	Future Review Process.....	9-38
9.2.7	Recommended Action 7: Pursue bridging options for capacity.....	9-39
9.2.7.1	Justification.....	9-40

	9.2.7.2	Execution	9-40
	9.2.7.3	Future Approval Process	9-40
9.2.8	Recommend Action 8: Advance reinforcement along existing GMS-WSN-KLY 500 kV transmission		9-40
	9.2.8.1	Justification	9-42
	9.2.8.2	Execution	9-43
	9.2.8.3	Future Approval Process	9-43
9.2.9	Recommended Action 9: Reinforce South Peace transmission		9-43
	9.2.9.1	Justification	9-43
	9.2.9.2	Execution	9-44
	9.2.9.3	Future Approval Process	9-44
9.2.10	Recommended Action 10: Supporting Clean Energy Sector		9-44
	9.2.10.1	Justification	9-44
	9.2.10.2	Execution	9-45
	9.2.10.3	Future Approval Process	9-48
9.2.11	Base Resource Plan LRBs		9-48
9.2.12	Long Run Marginal Cost		9-51
	9.2.12.1	Definition	9-51
	9.2.12.2	Setting the LRMC	9-52
9.3	LNG Base Resource Plan		9-55
9.3.1	Recommended Action 11: Explore natural gas-fired generation for the North Coast		9-55
	9.3.1.1	Justification	9-56
	9.3.1.2	Execution	9-57
	9.3.1.3	Future Approval Process	9-57
9.3.2	Recommended Action 12: Explore clean or renewable supply options, if LNG demand exceeds available resources		9-57
	9.3.2.1	Justification	9-58
	9.3.2.2	Execution	9-58
	9.3.2.3	Future Approval Process	9-59
9.3.3	Recommended Action 13: Advance reinforcement of the 500 kV transmission line to Terrace		9-59
	9.3.3.1	Justification	9-59
	9.3.3.2	Execution	9-59
	9.3.3.3	Future Approval Process	9-60
9.3.4	Recommended Action 14: Explore supply options for Horn River Basin and northeast gas industry		9-60
	9.3.4.1	Justification	9-61

	9.3.4.2	Execution	9-62
	9.3.4.3	Future Approval Process	9-63
	9.3.5	LNG Base Resource Plan LRBs	9-63
9.4		Contingency Resource Plans.....	9-66
	9.4.1	Contingency Planning	9-66
	9.4.2	Recommended Action 15: Advance Revelstoke Unit 6 Resource Smart project	9-68
	9.4.2.1	Justification.....	9-69
	9.4.2.2	Execution.....	9-70
	9.4.2.3	Future Approval Process	9-71
	9.4.3	Recommended Action 16: Advance GM Shrum Resource Smart Project	9-71
	9.4.3.1	Justification.....	9-72
	9.4.3.2	Execution.....	9-74
	9.4.3.3	Future Approval Process	9-74
	9.4.4	Recommended Action 17: Investigate natural gas-fired generation for capacity.....	9-75
		Working with industry, explore natural gas supply	9-75
	9.4.4.1	Justification.....	9-75
	9.4.4.2	Execution.....	9-75
	9.4.4.3	Future Approval Process	9-77
	9.4.5	CRP1	9-77
	9.4.6	CRP2	9-79
	9.4.7	Recommended Action 18: Investigate Fort Nelson area supply options.....	9-80
	9.4.7.1	Justification.....	9-81
	9.4.7.2	Execution.....	9-82
	9.4.7.3	Future Approval Process	9-82
	9.4.8	Transmission Contingency Plans.....	9-83
9.5		Additional IRP Recommendations	9-83
	9.5.1	Province-Wide Electrification/GHG Reduction Initiatives	9-83
	9.5.2	Export Market Analysis	9-84
	9.5.3	Transmission Planning for Generation Clusters.....	9-84
	9.5.4	IRP Submission Cycle and Amendments	9-85

List of Figures

Figure 9-1	Environmental Assessment Process.....	9-36
Figure 9-2	Northern Region Transmission	9-41

Figure 9-3	Energy LRB for BRP	9-50
Figure 9-4	Capacity LRB for BRP	9-50
Figure 9-5	Energy LRB for LNG BRP	9-64
Figure 9-6	Capacity LRB for LNG BRP	9-65
Figure 9-7	Energy LRB for CRP1	9-78
Figure 9-8	Capacity LRB for CRP1	9-78
Figure 9-9	Energy LRB for CRP2	9-79
Figure 9-10	Capacity LRB for CRP2	9-80

List of Tables

Table 9-1	IRP Recommended Action Description	9-4
Table 9-2	IRP Recommended Action Category Summary	9-6
Table 9-3	Utility Cost of DSM Target (\$ million) (cumulative over the years indicated).....	9-10
Table 9-4	DSM Implementation Plan: Cumulative Energy Savings since F2013 at Customer Meter in F2021	9-10
Table 9-5	DSM Implementation Plan: Cumulative Capacity Savings since F2013 in F2021 at Customer Meter	9-11
Table 9-6	DSM Implementation Plan – UC and TRC Benefit-Cost Ratios at Alternate LRMCS	9-14
Table 9-7	DSM Programs TRC and Savings	9-15
Table 9-8	Percentage of DSM Program Spend by Sector (F2014-F2016).....	9-18
Table 9-9	Percentage of DSM Energy Savings by Sector (F2021) (includes programs, codes and standards, and rate structures)	9-18
Table 9-10	Utility Cost of Capacity-Focused DSM (\$ million).....	9-21
Table 9-11	Key Project Risks and Risk Management	9-36
Table 9-12	F2014 to F2016 BRP Recommended Action Execution Expenditure.....	9-49
Table 9-13	F2014 to F2016 LNG BRP Recommended Action Execution Expenditure	9-64
Table 9-14	CRP Energy and Capacity Shortfalls	9-68
Table 9-15	Clean or Renewable Capacity Options	9-69
Table 9-16	F2014 to F2016 CRPs Recommended Action Execution Expenditure.....	9-83

1 9.1 Introduction

2 This chapter presents BC Hydro's 18 Recommended Actions to ensure that
3 BC Hydro can reliably and cost-effectively supply its customers' load requirements
4 under expected (or base) conditions through Base Resource Plans (**BRPs**) and
5 contingency conditions through Contingency Resource Plans (**CRPs**).

6 BC Hydro developed two BRPs: one that contains Recommended Actions prior to
7 considering load growth from Expected Liquefied Natural Gas (**LNG**) and one that
8 contains the incremental Recommended Actions to address the Expected LNG
9 requirements. Expected LNG load warrants specific analysis and associated
10 recommendations given the potential large size of this identifiable load. Presenting
11 the BRP prior to LNG is consistent with the treatment of the load-resource balance
12 (**LRB**) in the Site C Environmental Impact Statement (**EIS**). These actions will be
13 required regardless of the level of LNG load that BC Hydro supplies.

14 BC Hydro develops CRPs to address load growth and resource uncertainty,
15 including those associated with the delivery of transmission resources. There are
16 two CRPs to address contingencies without Expected LNG load (**CRP1**) and with
17 Expected LNG load (**CRP2**).

18 The Recommended Actions meet BC Hydro's energy and capacity planning criteria
19 (discussed in section 1.2.2), and align with the British Columbia's energy objectives
20 in section 2 of the *Clean Energy Act* (**CEA**) as described in section 1.2.3 of this
21 Integrated Resource Plan (**IRP**). Chapter 8 describes the Clean Energy Strategy and
22 the associated Recommended Action 10 that have been developed in response to
23 the request from the Minister of Energy and Mines (**Minister**) for BC Hydro to
24 support the clean energy sector and promote clean energy opportunities for First
25 Nations, and comments received during BC Hydro's last IRP consultation.

26 Recommended Action 10 has been captured in the BRP without LNG section, but
27 while some of the actions comprising the Clean Energy Strategy are reflected in the
28 BRP (such as increasing the Standing Offer Program (**SOP**) target), other actions

1 are preparatory in nature that support the CRPs. Chapter 7 reviews the
2 consultations with First Nations and stakeholders during development of the IRP and
3 the May 2012 Draft IRP. Chapter 7 also provides BC Hydro's response to
4 consultation input to date and a reflection on the extent to which the Recommended
5 Actions contained in this IRP align with these consultations.

6 For each Recommended Action, BC Hydro:

- 7 1. Summarizes the justification found elsewhere in the IRP such as Chapters 4, 6,
8 and 8
- 9 2. Sets out the anticipated expenditures. The expenditures are generally provided
10 for the F2014 to F2016 period for each Recommended Action. Longer-term
11 expenditures for large initiatives such as implementing the Demand Side
12 Management (**DSM**) target, and capital costs for projects such as Site C are
13 also provided
- 14 3. Lists the steps to be taken over the next five years to advance the specific
15 project or initiative including: a) risk mitigation measures; and b) potential major
16 regulatory review processes and other trigger events.

17 As described in Chapters 2, 4 and 6, economic conditions, developments in the
18 mining and gas sectors, the timing and scope of new LNG requirements, and
19 continued uncertainty in the delivery of DSM energy and associated capacity
20 savings contribute to significant uncertainty in the need for new resources. Many of
21 the Recommended Actions are designed to, among other things, keep options open
22 so that BC Hydro can reliably and cost-effectively meet need, while providing
23 off-ramps should the need change.

24 Approval of the IRP does not by itself lead to implementation of the Recommended
25 Actions. For example, implementing the proposed capital projects entails securing
26 government agency and regulatory approvals, and undertaking additional First
27 Nations consultation and public engagement processes, as required. Pursuing DSM

1 initiatives requires various forms of approval by the British Columbia Utilities
2 Commission (**BCUC**). Thus the IRP provides the long-term planning context for
3 future applications and associated review processes.

4 **9.1.1 Recommended Action Summary**

5 The BRP before Expected LNG addresses the energy and capacity load-resource
6 gaps from F2017 onward set out in section 2.4, after reflecting the DSM Target and
7 Electricity Purchase Agreement (**EPAs**) portfolio cost management initiatives
8 discussed in Chapter 4. This BRP is based on, among other things, the
9 December 2012 mid Load Forecast.

10 The LNG BRP addresses the incremental LNG expected load of 3,000 GWh/year
11 and 360 MW as discussed in section 2.2.

12 CRP1 addresses contingencies without Expected LNG load, and CRP2 addresses
13 contingencies with Expected LNG load.

14 [Table 9-1](#) provides an overview of the 18 Recommended Actions for the BRP, LNG
15 BRP and CRPs.

1

Table 9-1 IRP Recommended Action Description

Category	IRP Recommended Action	
BASE RESOURCE PLAN		
DSM (Conservation)	1. Moderate current spending and maintain long-term target	Target expenditures of \$445 million on conservation and efficiency measures during the fiscal years 2014 to 2016. Prepare to increase spending to achieve 7,800 gigawatt-hours per year in energy savings, and 1,400 MW in capacity savings, by F2021.
	2. Pursue DSM capacity conservation	Implement a voluntary industrial load curtailment program from F2015 to F2018 to determine how much capacity savings can be acquired and relied upon over the long term.
	3. Explore more codes and standards	Explore additional opportunities to leverage more codes and standards to achieve conservation savings at a lower cost and to gain knowledge and confidence about their potential to address future or unexpected load growth.
Portfolio Cost Management	4. Optimize existing portfolio of IPP resources	Optimize the current portfolio of IPP resources according to the key principle of reducing near-term costs while maintaining cost-effective options for long-term need.
	5. Investigate customer incentive mechanisms	Investigate incentive-based pricing mechanisms over the short term that could encourage potential new customers and existing industrial and commercial customers looking to establish new operations or expand existing operations in BC Hydro's service area.
Supply-Side Resources	6. Continue to advance Site C	Build Site C to add 5,100 GWh/year of annual energy and 1,100 MW of dependable capacity to the system for the earliest in service date (ISD) of F2024 (for all six generating units) subject to: environmental certification; fulfilling the Crown's duty to consult, and where appropriate, accommodate Aboriginal groups; and B.C. Government approval to proceed with construction.
	7. Pursue bridging options for capacity	Fill the short-term gap in peak capacity with cost-effective market purchases first and power from the Columbia River Treaty second.
Transmission Resources	8. Advance reinforcement along existing GMS-WSN-KLY 500 kV transmission line	Advance reinforcement of the existing GM Shrum-Williston-Kelly Lake 500 kV transmission lines to be available by F2024.
	9. Reinforce South Peace transmission	Review alternatives for reinforcing the South Peace Regional Transmission Network to meet expected load.
Supply-Side Resources	10. Support Clean Energy Strategy	Advance a set of actions that will support a healthy, diverse clean energy sector and promote clean energy opportunities for First Nations' communities

Category	IRP Recommended Action	
LNG BASE RESOURCE PLAN		
Supply-Side Resources	11. Explore natural gas-fired generation for the North Coast	Working with industry, explore natural gas supply options on the north coast to enhance transmission reliability and to meet the expected load.
	12. Explore clean energy supply options, if LNG demand exceeds available resources	Explore clean or renewable energy supply options and be prepared to advance a procurement process to acquire energy from clean power projects, as required to meet LNG needs that exceed existing and committed supply.
Transmission Resources	13. Advance reinforcement of the transmission line to Terrace	Advance reinforcement of the existing 500 kV transmission line from Prince George to Terrace, which includes development of three new series capacitor stations and improvements in the existing BC Hydro substations to be available by F2020.
Other	14. Explore supply options for Horn River Basin and northeast gas industry	Continue discussions with B.C.'s northeast gas industry and undertake studies to keep open electricity supply options, including transmission connection to the integrated system and local gas-fired generation.
CONTINGENCY RESOURCE PLAN		
Supply-Side Resources	15. Advance Revelstoke Unit 6 Resource Smart project	Advance the Revelstoke Generation Station Unit 6 Resource Smart project to preserve its earliest in-service date of F2021 with the potential to add up to 500 megawatts of peak capacity.
	16. Advance GM Shrum Resource Smart project	Advance Resource Smart upgrades to GM Shrum Generating Station Units 1–5 with the potential to gradually add up to 220 MW of peak capacity starting in F2021.
	17. Investigate natural gas-fired generation for capacity	Working with industry, explore natural gas supply options to reduce their potential lead time to in-service and to develop an understanding of where and how to site such resources, should they be needed.
Other	18. Investigate Fort Nelson area supply options	Investigate procurement options to serve future Fort Nelson load.

1 **9.1.2 Action Plan Alignment with BRP & CRP Scenarios**

2 [Table 9-2](#) is a summary of how the Recommended Actions are developed to align to
 3 the BRP, the BRP for Expected LNG load, and the two CRPs.

1
2

Table 9-2 IRP Recommended Action Category Summary

IRP Recommended Action		Category	BRP	LNG BRP	CRP1 and CRP2
1	BC Hydro DSM Target	DSM (Conservation)	<input type="checkbox"/>		
2	DSM Capacity Options	DSM (Conservation)	<input type="checkbox"/>		
3	DSM Codes and Standards Support	DSM (Conservation)	<input type="checkbox"/>		
4	IPP EPA Portfolio	Portfolio Cost Management	<input type="checkbox"/>		
5	Customer Incentive Mechanisms	Portfolio Cost Management	<input type="checkbox"/>		
6	Site C	Supply-Side Resources	<input type="checkbox"/>		
7	Bridging Capacity from Market Resources	Supply-Side Resources	<input type="checkbox"/>		
8	Existing GMS-WSN-KLY 500 kV Transmission Corridor	Transmission Resources	<input type="checkbox"/>		
9	South Peace Transmission	Transmission Resources	<input type="checkbox"/>		
10	Support Clean Energy Strategy	Supply-Side Resources	<input type="checkbox"/>		<input type="checkbox"/>
11	Natural Gas-Fired Generation for the North Coast	Supply-Side Resources		<input type="checkbox"/>	
12	Clean or Renewable Energy for High LNG Demand	Supply-Side Resources		<input type="checkbox"/>	
13	Reinforcement of 500 kV Line to Terrace	Transmission Resources		<input type="checkbox"/>	
14	Horn River Basin and Northeast Gas industry	Other		<input type="checkbox"/>	
15	Revelstoke Unit 6	Supply-Side Resources			<input type="checkbox"/>
16	GMS Units 1-5 Capacity Increase	Supply-Side Resources			<input type="checkbox"/>
17	Natural Gas-Fired Contingency Options	Supply-Side Resources			<input type="checkbox"/>
18	Fort Nelson Supply	Other			<input type="checkbox"/>

1 9.1.3 Chapter Structure

2 The remainder of this chapter is laid out as follows:

- 3 • Section [9.2](#) describes the ten BRP Recommended Actions without Expected
4 LNG load, shows the energy and capacity LRBs after implementation of the ten
5 Actions, and provides BC Hydro's Long Run Marginal Cost (**LRMC**) for the
6 period F2014 to F2033. The Clean Energy Strategy Recommended Action 10,
7 as described in Chapter 8, contains elements that support of the BRP as well
8 as preparatory actions that support the CRPs.
- 9 • Section 9.3 describes the four BRP Recommended Actions to address
10 Expected LNG load, with an emphasis on a flexible and staged approach to
11 address LNG load uncertainty
- 12 • Section 9.4 provides a description of the four Recommended Actions
13 associated with BC Hydro's two CRPs, along with a summary of the foundation
14 for the CRPs
- 15 • Section 9.5 contains additional recommendations relating to: electrification,
16 export market analysis, transmission planning for generation clusters, and the
17 future IRP submission cycle.

18 9.2 Base Resource Plan

19 BC Hydro's BRP before Expected LNG provides a 20-year view of the portfolio of
20 generation and transmission resources needed to address the energy and capacity
21 load-resource gaps depicted in section 2.4. The ten BRP Recommended Actions will
22 allow BC Hydro to meet its current and future customers' electricity needs on a
23 reliable and cost-effective basis.

24 To ensure fair and open access to the transmission system, BC Hydro has a number
25 of procedures governed by its Open Access Transmission Tariff (**OATT**), including
26 the use of a queue to ensure transmission service requests are dealt with in a
27 'first-come, first-served' manner. Once the IRP is approved, BC Hydro will submit

1 this BRP and the LNG BRP described in section [9.3](#) as transmission service
2 requests under the OATT tariff. Transmission requests for contingency plans are
3 discussed in section [9.4](#).

4 This section includes the following subsections:

- 5 • Subsections [9.2.1](#) to [9.2.9](#) present the ten BRP Recommended Actions, along
6 with their justification, their execution plan and risk mitigation, and their
7 respective future approval processes
- 8 • Subsection [9.2.11](#) depicts the energy and capacity LRBs that will result from
9 successful implementation of the nine BRP Recommended Actions
- 10 • Subsection [9.2.12](#) summarizes BC Hydro's energy and capacity LRMCs for the
11 period F2014 to F2033.

12 **9.2.1 Recommended Action 1: Moderate current DSM spending and** 13 **maintain long-term target**

14 ***Target expenditures of \$445 million (\$175 million, \$145 million, and***
15 ***\$125 million per year) on conservation and efficiency measures during F2014***
16 ***to F2016. Prepare to increase spending to achieve 7,800 GWh/year in energy***
17 ***savings, and 1,400 MW in capacity savings, by F2021.***

18 The Recommended Action is to continue working toward BC Hydro's current DSM
19 target originally established in the 2008 LTAP. The remaining savings of the original
20 target is 7,800 GWh by F2021. This is equivalent to reducing new electricity demand
21 by approximately 78 per cent over that period without Expected LNG load (the
22 corresponding figure with Expected LNG load is about 69 per cent). The DSM plan
23 to achieve that target would involve investment in DSM programs at about the same
24 rate as has been done over the past four years, but which is reduced from the
25 previous DSM plan shown in the F2012-F2014 Revenue Requirements Application
26 (RRA), as described in Chapter 4.

1 Implementation of the DSM plan as currently conceived to achieve the DSM target is
2 forecast to save approximately 7,000 GWh/year and 1,300 MW by F2021, with
3 losses:

- 4 • While the current DSM plan F2021 savings are somewhat lower than the target,
5 in the following years the DSM plan is expected to result in the same level of
6 savings as that target
- 7 • The DSM target of 7,800 GWh/year is a P50, which is a mid-level estimate
8 established in the 2008 LTAP, and as such, some variation between current
9 plan savings and the target is expected. As described in Chapter 4, DSM
10 energy savings for Option 2/DSM Target are P50 estimates and there is
11 uncertainty with over or under-delivery of energy savings represented by the
12 high and low forecasts. The difference between the planned and targeted
13 energy savings in F2021 is within a reasonable variance (i.e., +/- 10 per cent)
14 and is within 2 per cent of the DSM target levels by the Site C earliest ISD of
15 F2024.

16 Depending on actual DSM performance, expenditures and program activity levels
17 can be adjusted in future years. For this section [9.2.1](#), energy savings, associated
18 capacity savings and expenditures are based on the plan to achieve the DSM target.

19 The utility cost (**UC**), which is the implementation cost of pursuing the DSM target
20 over the period of F2014 to F2016 is estimated to be approximately \$445 million.

21 [Table 9-3](#) below summarizes the UC by component type.

1
2

**Table 9-3 Utility Cost of DSM Target (\$ million)
(cumulative over the years indicated)**

	3 years: F2014 to F2016	8 years: F2014 to F2021	20 years: F2014 to F2033
Codes and Standards	9	24	67
Rate Structures	10	21	51
Programs – Total			
• Programs – Residential	56	154	470
• Programs – Commercial	131	382	1,271
• Programs – Industrial	173	465	1,220
Programs – Sub-total	360	1,001	2,961
Supporting Initiatives	67	182	512
Total	445	1,228	3,591

3 The DSM plan will have approximately \$6.5 billion in aggregate customer bill savings
4 over the 20-year period.

5 The energy and associated capacity savings in F2021 from implementation of the
6 plan to achieve the recommended DSM target are set out in [Table 9-4](#) and [Table 9-5](#)
7 respectively.

8
9
10

**Table 9-4 DSM Implementation Plan: Cumulative
Energy Savings since F2013 at Customer
Meter in F2021**

	Codes and Standards (GWh/year)	Rate Structures (GWh/year)	Programs (GWh/year)	Total (GWh/year)
Residential	1,639	472	339	2,449
Commercial	617	356	778	1,751
Industrial	84	304	1,717	2,105
Total	2,340	1,132	2,834	6,306

1
2
3

Table 9-5 DSM Implementation Plan: Cumulative Capacity Savings since F2013 in F2021 at Customer Meter

	Codes and Standards (MW)	Rate Structures (MW)	Programs (MW)	Total (MW)
Residential	423	101	66	590
Commercial	123	49	106	278
Industrial	9	39	195	243
Total	555	189	367	1,111

4 **9.2.1.1 Justification**

5 The plan to achieve the DSM target is technically feasible, cost-effective as
6 measured by total resource cost (**TRC**) and UC, and achievable.

7 As is apparent from [Table 9-6](#), codes and standards and conservation (stepped) rate
8 structures have the lowest UC. BC Hydro’s expenditures in support of codes and
9 standards are justified on the grounds that they are cost-effective even if only
10 1 per cent of savings are attributable to BC Hydro’s efforts. BC Hydro is confident
11 that its expenditures in support of codes and standards will be critical to the
12 achievement of considerably more than 1 per cent of the savings.

13 Beginning in April 2006, BC Hydro implemented four conservation rates with
14 inclining block (stepped) rate structures for residential, commercial and industrial
15 customers. Given the LRMC described in section [9.2.12](#), BC Hydro is in the process
16 of revisiting the stepped rate pricing signals starting with the Residential Inclining
17 Block (**RIB**) rate.¹ However, BC Hydro is not proposing a return to flat rates given:
18 1) there is a need for energy in F2017 without any further DSM initiatives; and
19 2) conservation rate structures are longer-term initiatives that are not easily
20 re-introduced.

¹ The inclining block rate structure for BC Hydro’s largest industrial customers, Rate Schedule 1823 (referred to as the Transmission Service Rate or **TSR**) is being examined as part of the Industrial Electricity Policy Review.

1 The remainder of this section focuses on the DSM program component of the DSM
2 target.

3 **Need:** BC Hydro forecasts an energy gap and a capacity gap from F2017 onward.
4 To address these gaps, BC Hydro looks first to DSM and the associated energy
5 savings from codes and standards, stepped rate structures and programs. However,
6 the tools employed to achieve the DSM target are integrated. Significant
7 adjustments to any of the tools could impact the ability to achieve the planned level
8 of energy savings delivered by the other tools.

9 As the activity level with programs is more flexible and easier to ramp up or down
10 over shorter time periods, BC Hydro looks to adjust the DSM program component in
11 the near term to reduce upward rate pressures, while still maintaining the flexibility to
12 ramp up. This action is described below in section [9.2.1.2](#).

13 **Cost-Effectiveness:** Activities should be cost-effective to ensure BC Hydro's
14 investments in DSM will generally be lower than the LRMC and reduce overall
15 revenue requirements while providing broad opportunities for participation across
16 customer sectors. Cost-effectiveness is measured by the TRC and UC.

17 As set out in Chapter 3, pursuing the plan to achieve the DSM target would deliver
18 electricity savings at an average unit cost of approximately \$32/MWh.² [Table 9-6](#)
19 below shows the cost-effectiveness of the plan to achieve the DSM target at both a
20 tool and individual program level using the LRMC range of between \$85/MWh and
21 \$100/MWh (described in section [9.2.12](#) below); and sets out the Net TRC and
22 savings pertaining to DSM programs:

- 23 • All three DSM tools (codes and standards, rate structures and programs)
24 encompassed by the plan to achieve the DSM target across all sectors have a
25 TRC benefit-cost ratio greater than 1.0, which is the BCUC accepted standard

² The net DSM cost of \$8/MWh reflects deemed natural-gas benefits and deemed non-energy benefits as defined in the DSM Regulation.

-
- 1 • Programs with a TRC benefit-cost ratio greater than 1.0 indicate the program
2 costs are lower than the LRMC. With the exception of the DSM New Home
3 program, and the Low Income program using a LRMC of \$85/MWh, all
4 programs have a TRC ratio of at least 1.0. The New Home program is expected
5 to be substantially complete by F2015.
- 6 • With the exception of the Low Income program, all DSM tools encompassed by
7 the plan to achieve the DSM target across all sectors have a UC benefit-cost
8 ratio greater than 1.0. A benefit-cost ratio above 1.0 indicates that the program
9 would lower BC Hydro revenue requirements and therefore the aggregate
10 customer bill.

1
2

Table 9-6 DSM Implementation Plan – UC and TRC Benefit-Cost Ratios at Alternate LRMCS³

	LRMC at \$100/MWh		LRMC at \$85/MWh	
	UC Test	TRC Test	UC Test	TRC Test
Codes and Standards	117.1	5.5	102.8	4.9
Rate Structures	16.4	10.0	14.3	8.8
DSM Programs				
<i><u>Residential Sector</u></i>				
Behaviour	3.5	4.8	3.1	4.2
Refrigerator Buy-Back	1.5	2.1	1.3	1.8
Low Income	0.9	1.0	0.8	0.9
New Home	1.3	0.7	1.2	0.6
Residential Rebate	1.8	1.8	1.6	1.6
Renovation Rebate	2.5	1.2	2.2	1.1
Load Displacement	<u>6.5</u>	<u>2.4</u>	<u>5.5</u>	<u>2.0</u>
<i>Residential Sector Total</i>	<i>2.4</i>	<i>2.0</i>	<i>2.1</i>	<i>1.8</i>
<i><u>Commercial Sector</u></i>				
Power Smart Partner	1.9	1.7	1.6	1.5
Product Incentive	2.2	1.6	1.9	1.4
New Construction	2.2	1.4	1.9	1.2
Lead by Example	1.1	1.1	1.0	1.0
Load Displacement	<u>2.5</u>	<u>1.4</u>	<u>2.1</u>	<u>1.2</u>
<i>Commercial Sector Total</i>	<i>2.0</i>	<i>1.6</i>	<i>1.7</i>	<i>1.4</i>
<i><u>Industrial Sector</u></i>				
Power Smart Partner – Transmission	4.0	2.3	3.5	2.0
Power Smart Partner – Distribution	1.9	1.7	1.6	1.5
Load Displacement	<u>3.2</u>	<u>2.9</u>	<u>2.8</u>	<u>2.5</u>
<i>Industrial Sector Total</i>	<i>3.2</i>	<i>2.3</i>	<i>2.8</i>	<i>2.0</i>
Total Programs	2.6	2.0	2.2	1.7
Portfolio Total	5.2	3.1	4.6	2.7

³ Benefit-cost ratios for rate structures and programs include supporting initiative costs. Supporting initiatives include public awareness and education, community engagement, technology innovation, information technology, and indirect and portfolio enabling.

1

Table 9-7 DSM Programs TRC and Savings

<i>DSM Programs (sorted by net TRC)</i>	<i>Net TRC (\$/MWh)*</i>	<i>Forecast Savings @ F2021 (GWh/year)</i>	<i>Cumulative Savings (GWh)</i>	<i>% of Total Cumulative Savings (%)</i>
Behaviour	6	135	135	5
Load Displacement - Ind	27	432	567	20
Power Smart Partner - Transmission	36	1,021	1,588	56
Load Displacement - Res	42	0	1,588	56
Refrigerator Buy-back	43	66	1,653	58
Residential Rebate	46	53	1,706	60
Power Smart Partner - Distribution	51	265	1,971	70
Power Smart Partner - Com	52	450	2,421	85
Product Incentive	55	173	2,594	92
New Construction	60	123	2,717	96
Load Displacement - Com	69	4	2,721	96
Lead by Example	71	28	2,749	97
Renovation Rebate	77	56	2,805	99
Low Income	88	20	2,825	100
New Home	113	8	2,834	100

2
3

* Net TRC shown is net of generation, transmission and distribution capacity benefits, non-energy benefits and natural gas savings benefits.

4
5
6
7
8
9
10

The plan to achieve the DSM target encompasses a comprehensive portfolio of DSM measures with a broad offering to all customer sectors designed to complement one another and capture synergies. Refer to section [9.2.1.2](#) for more detail concerning the percentage of BC Hydro’s DSM program spend by customer sector for the F2014 to F2016 period. The DSM plan will result in approximately \$6.5 billion in aggregate customer bill reductions. The DSM program component is flexible and can be changed over time in response to new information.

11
12
13
14

Environmental and Economic Development Benefits: DSM avoids the environmental impacts associated with the construction of new generation facilities. DSM provides economic development benefits through increased GDP and the direct creation of jobs for customers and trade allies from the implementation of

1 energy savings initiatives. It also provides opportunities for customers to save
2 money on their electricity bills and for industry to improve its competitiveness.

3 **Policy Alignment:** The DSM target aligns with several of the energy objectives
4 contained in section 2 of the *CEA*, as discussed in section 1.2.3. A key *CEA*
5 objective for DSM is the objective to reduce the expected increase in demand by at
6 least 66 per cent by 2020 (*CEA* objective 2(b)). The DSM target achieves a
7 78 per cent reduction in the expected increase in demand without potential LNG
8 load.⁴

9 **9.2.1.2 Execution**

10 BC Hydro is proposing to adjust expenditures for DSM programs over the next
11 three years while maintaining the potential to achieve higher DSM savings in the
12 long term. A primary challenge in adjusting DSM programs is ensuring that programs
13 remain a viable, low-cost resource to address future energy and capacity gaps. In
14 Chapter 4, BC Hydro examined two 'alternative means' (functionally different ways)
15 of achieving the DSM target in F2021:

- 16 • DSM Alternative Means 1 (status quo – no DSM program expenditure
17 reduction)
- 18 • DSM Alternative Means 2 (near-term expenditure reductions, ramping back up
19 to the DSM target generally by F2021)

20 A potential third path to the DSM target was also explored, which would reduce
21 expenditures further than Alternative Means 2 in the near term (to \$100 million in
22 F2016) and aggressively ramps up to higher levels of activity in F2017. However,
23 even with the aggressive ramp-up rate, this path fails to return to the energy savings
24 levels of the DSM target by F2021. There are additional energy savings delivery

⁴ The DSM target achieves a 69 per cent reduction in demand if Expected LNG load is included.

1 risks associated with a further reduction of expenditures and the aggressive ramp-up
2 rate.

3 BC Hydro recommends DSM Alternative Means 2. The planned adjustments to DSM
4 program activities and expenditures in the near term result in potential savings of
5 \$330 million over F2015 to F2022 relative to Alternative Means 1. These reduced
6 expenditures will result in almost 900 GWh/year of lower cumulative DSM energy
7 savings by F2021. F2014 is a transition year as approximately \$65 million in project
8 incentives is already committed.

9 In developing these reduced expenditures and maintaining the ability to ramp up,
10 BC Hydro employed the following principles: 1) eliminate projects or activities that
11 have a short energy savings persistence and thus only contribute to the near-term
12 surplus period; 2) consider 'lost opportunities' by (a) continuing to offer incentives for
13 energy savings opportunities that will not be available in the future (e.g., one-time
14 opportunities for incremental improvement to building envelope upgrades or new
15 construction) and (b) deferring incentives for energy savings opportunities that are
16 not needed now but will have a predictable uptake regardless of when they are
17 offered; 3) maintain program activities to retain a level of customer and trades
18 engagement and relationships so that DSM programs can be ramped up to
19 long-term savings targets as needed; 4) consider cost-effectiveness of DSM
20 programs from both the UC and TRC perspectives; and 5) consider broad
21 opportunities for customers to participate.

22 To maximize the range of ratepayers able to participate in DSM and benefit from
23 lower bills, BC Hydro needs to strike a portfolio level balance between ensuring
24 overall cost-effectiveness and equity. One example in this regard is the Low Income
25 program. Consistent with stakeholder and First Nations consultation input, BC Hydro
26 proposes to maintain the program and not reduce the offer. Other considerations
27 include the availability of opportunities to each sector and the barriers in each
28 market.

1 [Table 9-8](#) sets out the percentage of BC Hydro’s DSM program spend by sector for
 2 the F2014 to F2016 period and [Table 9-9](#) sets out the energy savings delivered from
 3 each customer class. While residential expenditures are lower, they deliver a
 4 considerable amount of savings through codes and standards activity.

5 **Table 9-8 Percentage of DSM Program Spend by**
 6 **Sector (F2014-F2016)**

Residential (%)	Commercial (%)	Industrial (%)
16	36	48

7 **Table 9-9 Percentage of DSM Energy Savings by**
 8 **Sector (F2021) (includes programs,**
 9 **codes and standards, and rate**
 10 **structures)**

Residential (%)	Commercial (%)	Industrial (%)
39	28	33

11 **Risk Mitigation:** Over the medium and longer term, risk mitigation is aimed at two
 12 key risks: (1) deliverability of energy and capacity savings; and (2) costs to deliver
 13 those savings. DSM risk mitigation includes:

- 14 • **Initiative Design:** DSM initiatives are designed to consider risk. For example,
 15 DSM programs are designed to successfully attract customer participation
 16 based on information from market research, jurisdictional reviews and
 17 consultations with customers, retailers and trade allies
- 18 • **Incentive Design:** Several DSM programs use incentive structures that ensure
 19 BC Hydro provides an appropriate financial incentive for individual projects and
 20 limits the amount needed to achieve DSM electricity savings
- 21 • **Tracking Performance Metrics:** BC Hydro tracks program electricity savings
 22 and costs on a monthly basis. BC Hydro also tracks leading and lagging
 23 performance indicators for each DSM initiative.

-
- 1 • **Savings Estimates and Verification:** BC Hydro undertakes a comprehensive
2 approach to estimate the electricity savings from each DSM initiative and
3 periodically updates its savings information based on the results
- 4 • **Management Oversight:** Regular oversight is done at both the DSM initiative
5 and plan levels. During the implementation of a program or initiative, risks are
6 monitored through the tracking of indicators as described above. Management
7 judgement, industry input and stakeholder feedback are then combined with
8 these key performance indicators when assessing changes to programs and
9 initiatives.
- 10 • **Plan and Initiative Adjustments:** Adjustments are made at the initiative and
11 plan levels as required. For example, if a program is not performing as
12 expected or if there is new information that could impact a program,
13 adjustments can be made to the program.

14 BC Hydro also addresses DSM deliverability risk through the two CRPs set out in
15 section [9.4](#).

16 **9.2.1.3 Future Review Process**

17 Implementation of the DSM target will require two applications to the BCUC in the
18 next six months:

- 19 • **RIB:** BC Hydro submitted a RIB rate application to the BCUC in November
20 2013 pursuant to sections 58 to 61 of the *Utilities Commission Act (UCA)* to
21 request approval of new pricing principles⁵ that would apply for F2015 and
22 F2016
- 23 • **DSM Expenditures for F2014 to F2016:** BC Hydro will file a DSM expenditure
24 schedule for F2014 to F2016 pursuant to subsection 44.2(1)(a) of the *UCA* with
25 the BCUC for acceptance with expenditures of \$175 million, \$145 million and

⁵ A pricing principle is a high level guiding principle that determines how price changes are applied to individual elements of a rate.

1 \$125 million for the three years. In considering whether to accept the DSM
2 expenditure schedule for F2014 to F2016, the BCUC must, pursuant to
3 subsection 44.2(5.1) of the *UCA*, consider the interests of persons in B.C. who
4 receive or may receive service from BC Hydro; and consider and be guided by
5 the applicable section 2 *CEA* British Columbia's energy objectives, an
6 applicable approved IRP, and the extent to which the proposed DSM initiatives
7 are cost-effective within the meaning of the DSM Regulation. BC Hydro has
8 consulted with interveners as to the timing for the F2014 to F2016 DSM
9 expenditure schedule filing and plans to file in February 2014 as part of or
10 contemporaneously with the F2015/F2016 RRA.

11 **9.2.2 Recommended Action 2: Pursue DSM capacity conservation**

12 ***Implement a voluntary industrial load curtailment program from F2015 to***
13 ***F2018 to determine how much capacity savings can be acquired and relied***
14 ***upon over the long term. Pilot voluntary capacity-focused programs (direct***
15 ***load control) for residential, commercial and industrial customers over***
16 ***two years, starting in F2015.***

17 While the DSM target described in section [9.2.1.1](#) has significant associated
18 capacity savings of 1,400 MW in F2021, additional capacity savings may be possible
19 through DSM capacity activities (also referred to as peak reduction, peak shaving or
20 load shifting). Capacity-focused DSM is grouped into two broad categories:

- 21 • **Industrial Load Curtailment:** This DSM option targets customers who agree to
22 curtail load on short notice provided by BC Hydro during peak periods.
23 BC Hydro proposes to implement a voluntary load curtailment program with
24 BC Hydro's industrial customers to be developed and implemented in stages
25 between F2015 and F2018. Opportunities to accelerate the timeline may be
26 discovered. This program will identify how much long-term capacity savings are
27 available and can be relied upon for long-term planning purposes.

- 1 • **Capacity Programs:** This DSM option would consist of voluntary programs that
 2 leverage equipment and load management systems to enable peak load
 3 reductions to occur. BC Hydro proposes to pilot capacity-focused programs
 4 (direct load control) for residential, commercial and industrial customers over
 5 two years, starting in F2015.

6 [Table 9-10](#) summarizes the UC of capacity-focused DSM.

7 **Table 9-10 Utility Cost of Capacity-Focused DSM**
 8 **(\$ million)**

	Two years: F2015 to F2016
Industrial Load Curtailment	0.75
Capacity-Focused Programs	5.00
Total	5.75

9 As described in Chapter 3, capacity-focused DSM represents a new capacity
 10 resource to BC Hydro and is subject to uncertainty with respect to its ability to
 11 reduce the system peak over the long term.

12 In general, experience is needed to see how savings for each initiative translates
 13 into peak reduction for the entire BC Hydro integrated system. BC Hydro has had
 14 experience with load curtailment programs for large industrial customers. To date,
 15 these programs have not resulted in a long-term commitment either by BC Hydro to
 16 acquire load curtailment, or customers to interrupt or adjust operations when and as
 17 required. Other jurisdictions have established practices of relying on long-term load
 18 curtailment for peaking capacity and some forms of operational reserve. BC Hydro
 19 will consider these jurisdictional practices, taking into account their differences and
 20 experiences. For these reasons, BC Hydro will not yet rely on capacity savings from
 21 capacity-focused DSM for resource planning purposes, and thus potential
 22 capacity-focused DSM savings are not included in the DSM target at this time.

1 **9.2.2.1 Justification**

2 **Need:** Assuming implementation of the DSM target and EPA renewals, there is a
3 need for capacity resources beginning in F2019 with or without Expected LNG load.
4 BC Hydro proposes to address the short-term peak capacity gap (without LNG load)
5 from F2019 to F2023 with a series of bridging measures such as market purchases
6 and power from the Columbia River Treaty (referred to as the Canadian Entitlement
7 or **CE**). Capacity-focused DSM provides the capacity potential to reduce the need for
8 bridging resources. Implementation will provide BC Hydro with information on the
9 cost and impacts of capacity-focused DSM, which will inform decisions on whether
10 to rely on capacity-focused DSM as a long-term capacity resource.

11 **Cost-Effectiveness:** Industrial load curtailment and capacity-focused programs
12 have the potential to deliver cost-effective capacity savings over the long term. Costs
13 would be managed against BC Hydro's capacity LRMC.

14 **Environmental Attributes:** Capacity-focused DSM may avoid the need for some of
15 the market bridging mechanisms, resulting in a lower environmental footprint.

16 **Policy Alignment:** Capacity-focused DSM would support BC Hydro in meeting the
17 legally binding self-sufficiency requirement (*CEA*, subsection 6(2)).

18 **9.2.2.2 Execution**

19 BC Hydro will design and then launch a voluntary industrial load curtailment offer
20 and capacity-focused programs (direct load control). For load curtailment, BC Hydro
21 envisions the following:

- 22 • F2015: BC Hydro will work with industry to explore the level of interest and
23 curtailment opportunity, and to develop conceptual program offers, including
24 contractual terms and conditions
- 25 • F2016 – F2017: BC Hydro will test the conceptual offers to understand the
26 industry's response and key integration aspects. BC Hydro will launch the full
27 program offer allowing industry to respond to and be comfortable with the

1 program. The program can then be expanded (by number of participants or
2 level of participant commitment in hours or MW) based on future BC Hydro
3 need (MW) and value (\$/kW-year).

4 The following steps are anticipated for the direct load control part of
5 capacity-focused DSM programs:

- 6 • F2015 – F2016: BC Hydro will implement a voluntary two-year pilot program for
7 residential, commercial and industrial customers in a specific region to test
8 conceptual offers, understand key integration aspects, and design the program
9 offer
- 10 • In F2017, BC Hydro will launch the full program

11 BC Hydro will employ the same risk mitigation tactics as for the DSM target. Refer to
12 section [9.2.1.2](#).

13 **9.2.2.3 Future Approval Process**

14 BC Hydro will file an expenditure schedule with the BCUC for acceptance of
15 expenditures for F2014 to F2016 pursuant to subsection 44.2(1)(a) of the *UCA*, as
16 part of the DSM expenditure schedule described in section [9.2.1.3](#) with respect to
17 the DSM target.

18 **9.2.3 Recommended Action 3: Explore more codes and standards**

19 ***Explore additional opportunities to leverage more codes and standards to***
20 ***achieve conservation savings at a lower cost beyond the current target and to***
21 ***gain knowledge and confidence about their potential to address future or***
22 ***unexpected load growth.***

23 This action has an approximate cost of \$1.5 million per year for F2015 and F2016.
24 (There are no F2014 expenditures).

9.2.3.1 Justification

1 Opportunities to leverage additional levels of DSM-related codes and standards
2 support provides the potential to deliver additional cost-effective electricity savings.
3 However, there is considerable uncertainty regarding the implementation and
4 achievement of these additional electricity savings. This action will investigate and
5 further develop the range of codes and standards tactics to reduce uncertainty about
6 their feasibility and/or savings estimates and ultimately inform subsequent IRPs. By
7 doing so, it is expected that this Recommended Action will support further
8 government work. An example is the Pacific Coast Collaborative's⁶ "2012 West
9 Coast Action Plan on Jobs" that among other things seeks to jointly develop energy
10 efficiency standards for appliances such as television set-top boxes, lighting,
11 television, battery chargers, computer/servers and standby losses for a broad range
12 of electronics.
13

9.2.3.2 Execution

14 BC Hydro will undertake a range of activities focused on additional codes and
15 standards, including: 1) strategy development; 2) market research, studies and
16 opportunity assessments; 3) measure design, including modeling and cost-benefit
17 analysis; 4) customer, trade ally and/or stakeholder engagement; and 5) pilot
18 programs. BC Hydro will design and manage these activities to achieve the
19 objectives of enhanced certainty at a reasonable cost.
20

9.2.3.3 Future Approval Process

21 BC Hydro will file an expenditure schedule with the BCUC for acceptance of
22 expenditures for F2014 to F2016 pursuant to subsection 44.2(1)(a) of the *UCA*, as
23 part of the DSM expenditure schedule described in section [9.2.1.3](#) with respect to
24 the DSM target.
25

⁶ On June 30, 2008, B.C., Alaska, California, Oregon and Washington State signed the Pacific Coast Collaborative Agreement.

1 9.2.4 Recommended Action 4: Optimize existing portfolio of IPP 2 resources

3 *Optimize the current portfolio of IPP resources according to the key principle*
4 *of reducing near-term costs while maintaining cost-effective options for*
5 *long-term need.*

6 The combined Independent Power Producer (**IPP**) supply and targeted DSM results
7 in BC Hydro having an adequate energy supply until F2028 and adequate capacity
8 supply until F2019, as shown in section 4.2.6. BC Hydro is undertaking time-critical
9 actions over the next few months to prudently manage the costs of the energy
10 resources that it has acquired, committed to or planned to target over the next
11 five years. These actions include negotiating agreements to defer commercial
12 operation date (**COD**), downsize or terminate pre-COD EPAs. Based on the EPA
13 actions, BC Hydro expects to achieve an energy supply reduction of contracted
14 energy by F2021 of roughly 1,800 GWh/year, translating into a reduction in
15 attrition-adjusted forecasted firm energy supply of about 160 GWh/year by F2021.

16 9.2.4.1 Justification

17 The energy and capacity LRBs depicted in section 4.4.2.6 after implementation of
18 the DSM target and EPA renewal assumptions show:

- 19 • There is an energy gap beginning in F2028 and a capacity gap beginning in
20 F2019 without Expected LNG load
- 21 • The corresponding energy and capacity gaps begin in F2022 and F2019,
22 respectively, with Expected LNG load

23 BC Hydro identified three categories of potential EPA portfolio supply reductions:

- 24 1. Pre-COD EPAs where there is some ability to defer COD, downsize capacity or
25 terminate the EPA
- 26 2. EPA renewals where contracts are coming to end of life
- 27 3. New EPAs

1 For all three categories, as described in section 4.2.5.1, projects were assessed
2 based on cost, implementation risk, system benefits and economic development
3 benefits.

4 **9.2.4.2 Execution**

5 **Termination, Deferral or Downsizing of Pre-COD EPAs:** To date, BC Hydro has
6 executed mutual agreements to terminate four EPAs, representing 147 MW in
7 nameplate capacity and 980 GWh in total annual generation (prior to attrition
8 adjustment). BC Hydro is in discussions with IPPs where development of pre-COD
9 EPA projects has stalled, with the objective of obtaining mutual agreement to
10 terminate these contracts.

11 BC Hydro is continuing to discuss options for deferral or downsizing of EPAs with
12 developers, where feasible options exist.

13 **EPA Renewals:** As described in section 4.2.5.1, prior to this IRP BC Hydro
14 assumed that no bioenergy EPAs would be renewed upon expiry due to pricing and
15 fuel supply risks, and that all other EPAs would be renewed for the remainder of the
16 planning horizon. For planning purposes, BC Hydro now assumes that about
17 50 per cent of the bioenergy EPAs will be renewed, and about 75 per cent of the
18 run-of-river hydroelectric EPAs that are up for renewal in the next five years will be
19 renewed. These EPA renewal planning assumptions would result in about
20 1,800 GWh/year of firm energy in F2021 and about 6,400 GWh/year of firm energy
21 in F2033.

22 However, IPP projects will be individually assessed as EPAs come up for renewal.
23 BC Hydro recognizes that EPAs can provide beneficial products such as voltage
24 support, dependable capacity (valued using Revelstoke Unit 6 cost of capacity) and
25 dispatchability. A recent example is BC Hydro's plan to exercise an option to extend
26 the EPA term for the 120 MW McMahon Cogeneration natural gas-fired facility
27 located near Taylor, B.C., provides cost-effective firm energy, dispatchability and
28 capacity support to the local transmission system. Consultation with First Nations

1 would be required where there are physical or operational changes to the projects
2 triggered by the renewal.

3 By way of illustration, renewing about 2,000 GWh/year by F2021 would cost about
4 \$2.5 billion (through to F2033 in as-spent dollars).

5 **New EPAs:** BC Hydro is continuing to negotiate in good faith with First Nations and
6 other parties where there are agreements committing BC Hydro to negotiate EPAs.
7 For further actions on new IPPs, see the Clean Energy Strategy Recommended
8 Action 10 in section [9.2.10.2](#) on SOP and Net Metering.

9 **9.2.4.3 Future Approval Process**

10 BC Hydro anticipates that its management of the IPP EPA portfolio will be informed
11 by the IRP review and approval process and through future RRA processes.

12 **9.2.5 Recommended Action 5: Investigate customer incentive** 13 **mechanisms**

14 ***Investigate incentive-based pricing mechanisms over the short-term that could***
15 ***encourage potential new customers and existing industrial and commercial***
16 ***customers looking to establish new operations or expand existing operations***
17 ***in BC Hydro's service area.***

18 **9.2.5.1 Justification**

19 Because domestic rates are higher than the price that can be obtained on the spot
20 market, one potential strategy to get higher value for the available energy is to
21 increase domestic demand. This is only worthwhile if the increased load is
22 temporary and there is benefit in the initiative. Initiatives that boost demand over a
23 longer timeframe will increase rates and revenue requirements once the additional
24 electricity supplies are needed.

1 **9.2.5.2 Execution**

2 To date, BC Hydro has focused on identifying potential incremental loads from
3 existing TSR customers, which is currently approximately 300 GWh/year. Going
4 forward, BC Hydro will identify potential new customer loads. Section 4.2.5.4
5 identifies the various design considerations that would need to be considered.

6 **9.2.5.3 Future Approval Process**

7 The future approval process depends on the implementation mechanism:

- 8 • Stand-alone legislation: Precedents include the B.C. *Power for Jobs*
9 *Development Act*⁷ which specifically provided that the BCUC did not have
10 jurisdiction in respect of the 'development power rates' offered by BC Hydro.
11 Under the *Power for Jobs Development Act* an administrator was appointed to
12 determine if there was surplus energy and to review applications from an
13 economic, environmental and societal interest perspective.
- 14 • Programs/contracts under section 9 of the *CEA*: Use of this mechanism
15 requires Cabinet regulation
- 16 • A tariff to be filed with the BCUC pursuant to sections 58 to 61 of the *UCA*: The
17 BCUC has broad discretion to determine if a rate is just, reasonable, not unduly
18 discriminatory and/or not unduly preferential. A tariff may not permit tailoring for
19 particular customer circumstances.

20 **9.2.6 Recommended Action 6: Continue to advance Site C**

21 ***Build Site C to add 5,100 GWh/year of annual energy and 1,100 MW of***
22 ***dependable capacity to the system for the earliest in service date of F2024 (for***
23 ***all six generating units) subject to: environmental certification; fulfilling the***
24 ***Crown's duty to consult, and where appropriate, accommodate Aboriginal***
25 ***groups; and Provincial Government approval to proceed with construction.***

⁷ S.B.C. 1997, c.51.

1 Site C consists of the development of a proposed third dam and hydroelectric
2 generating station on the Peace River in northeast B.C. Site C would be the third
3 project downstream of BC Hydro's existing generating facilities at GM Shrum (**GMS**)
4 and Peace Canyon and the respective Williston and Dinosaur reservoirs. Site C
5 would be publicly owned and would become one of BC Hydro's Heritage assets.

6 Site C triggers *B.C. Environmental Assessment Act (BCEAA)* and *Canadian*
7 *Environmental Assessment Act (CEAA)*.⁸ Site C is currently in a harmonized
8 federal-provincial environmental review,⁹ which includes a Joint Review Panel (**JRP**)
9 process. The environmental assessment process for Site C started in August 2011
10 and is anticipated to take approximately three years to complete. Details concerning
11 the harmonized federal-provincial environmental review are provided below.

12 Site C earliest ISD is F2024 for all six generating units, with the first power from
13 Site C in late F2023. An in service date of F2024 is considered reasonably
14 achievable, subject to environmental certification; fulfilling of the Crown's duty to
15 consult, and where appropriate, accommodate Aboriginal groups; and Provincial
16 Government approval to proceed with construction. BC Hydro has also included a
17 F2026 ISD to provide a basis for evaluation in Chapter 6 of this IRP.

⁸ The Executive Director of the EAO issued a section 10 *BCEAA* order on August 2, 2011, determining the Site C is a reviewable project pursuant to Part 4 of the *B.C. Reviewable Projects Regulation*, B.C. Reg. 370/2002; the Agency determined on September 30, 2011 that the requirements to commence an environmental assessment under *CEAA* had been met.

⁹ A joint Agreement to Conduct a Cooperative Environmental Assessment, Including the Establishment of a Joint Review Panel, of the Site C Clean Energy Project between the Minister of Environment, Canada and the Minister of Environment, British Columbia was issued on September 30, 2011 after a public comment period, and amended on February 13, 2012.

1 The final cost estimate for a capital project can only be known after a competitive
2 procurement process is complete and final bids for construction contracts are
3 accepted. Due to engineering, environmental and consultation work done in
4 Stages 2 and 3 (described below in section [9.2.6.1](#)), Site C has reached an
5 advanced level of project definition. The Site C cost estimate of \$7.9 billion is
6 commensurate with a Class 3 cost estimate according to the estimating practices of
7 the Association for Advancement of Cost Engineering (**AACE**),¹⁰ as compared to the
8 majority of other IRP resource options that are based on lower accuracy Class 4 or 5
9 estimates. As described below in section [9.2.6.2](#), the Site C cost estimate includes
10 adjustments for inflation and the cost of financing during construction, and has
11 undergone both internal and external review.

12 **9.2.6.1 Justification**

13 **Need:** There is a need for Site C based on the LRB analysis in Chapters 2, 4 and 6
14 even after taking into account the pursuit of the DSM target set out in Chapter 6.
15 With the implementation of the DSM target and EPA renewals, new resources are
16 required to meet the energy and capacity needs of BC Hydro's customers:

- 17 • There is an energy gap beginning in F2028 and a capacity gap beginning in
18 F2019 without Expected LNG load
- 19 • The corresponding energy and capacity gaps are F2022 and F2019
20 respectively with Expected LNG load.

21 It is difficult to precisely time the addition of any new electricity resource with the
22 exact year of forecasted energy or capacity gaps, particular large hydroelectric
23 facilities such as Site C. There are a number of uncertainties that could result in
24 higher or lower customer demand, and lower or higher resource delivery, including:

¹⁰ As defined in AACE Recommended Practice No. 69R-12, Cost Estimate Classification System – As Applied in Engineering, Procurement and Construction for the Hydropower Industry (revised January 25, 2013), page 9 of 14. The BCUC requires Class 3 cost estimates for CPCN applications; refer to section 5 of the BCUC's 2010 *Certificate of Public Convenience and Necessity Application Guidelines* (BCUC Order No. G-50-10, March 19, 2010).

-
- 1 • **Load Forecast Variability:** BC Hydro's load forecast is sensitive to a number
2 of variables, including economic conditions. Factors that can lead to a lower
3 load than forecast include a reduction in the growth in China and elsewhere,
4 leading to a slowing of commodity demand and lower prices. Factors that can
5 lead to higher than forecast electricity sales include strengthening world
6 demand for commodities and electrification.
 - 7 • **Expected LNG Load:** BC Hydro has considered an Expected LNG load of
8 3,000 GWh/year and 360 MW within an overall range of about 800 GWh/year to
9 about 6,600 GWh/year of additional energy demand, corresponding to about
10 100 MW to 800 MW of additional peak demand
 - 11 • **DSM Delivery Risk:** The current DSM target is a significant step up from DSM
12 targets BC Hydro pursued prior to the 2008 LTAP. The consequences of DSM
13 not delivering the anticipated capacity savings are of particular concern
14 because while generally external markets can be counted on for supply of
15 energy across the year (albeit with costs), during winter peak periods there are
16 issues with: 1) the illiquid (thinly traded) nature of the market for capacity;
17 2) insufficient transmission capacity; and 3) the U.S. market potentially not
18 having surplus to sell.

19 These uncertainties underscore the need to review a range of future resource
20 requirements, rather than solely single-point estimates for LRB energy and capacity
21 gaps.

22 BC Hydro examined a number of sensitivity cases: 1) large gap (i.e., high load
23 growth with low DSM savings level) and small gap (low load growth with low DSM
24 savings level); 2) high and low market price scenarios; 3) a lower cost of capital
25 assumption for IPP projects; 4) higher capital costs for Site C and some
26 combinations of higher capital costs for resource alternatives; 5) different wind
27 integration costs; and (6) some low probability compound sensitivities. In general,
28 Site C has a Present Value (**PV**) advantage over viable alternative Clean Generation

1 portfolios except in the scenario associated with long-term low load growth, and in
2 the implausible scenario of a 30 per cent capital cost increase for Site C while the
3 cost of alternatives held constant. When compared to the Clean + Thermal
4 Generation portfolio, Site C has a cost disadvantage in the scenarios that are
5 generally low probability associated with long-term low load growth, low market
6 prices and higher Site C capital costs.

7 BC Hydro considers it prudent to continue to proceed with Site C for its earliest ISD
8 of F2024 given these uncertainties and PV results. Detailed discussion of the timing
9 for the need of Site C to meet load requirements is provided in section 6.4.2.

10 **Cost-Effectiveness:** Resources that are viable alternatives to Site C in various
11 combinations are: (1) DSM Option 3; (2) clean or renewable energy e.g., wind,
12 run-of-river, biomass; (3) clean or renewable capacity i.e., Revelstoke Unit 6, GMS
13 Units 1-5 Capacity Increase and pumped storage; and (4) natural gas-fired
14 generation within the CEA 93 per cent clean or renewable parameter. All Site C and
15 viable alternative portfolios assumed as a baseline condition achievement of
16 BC Hydro's DSM target. As demonstrated in section 6.4, Site C is a cost-effective
17 resource.

18 Site C is a dispatchable resource, and provides ancillary benefits to the BC Hydro
19 integrated system including shaping and firming, and wind integration capability. In
20 contrast, generation from many viable clean or renewable resources such as wind or
21 run-of-river are determined by environmental considerations such as wind speeds or
22 seasonal river flows, and as a result, these intermittent resources cannot be
23 economically dispatched in response to changes in market prices. For example,
24 run-of-river generation generally peaks in the spring and early summer when
25 customer demand is lowest. Facilities such as Site C which are downstream of large
26 hydroelectric storage reservoirs can be operated to have lower generation during the
27 spring and early summer allowing run-of-river generation to be used to serve load as

1 much as possible. Some of these additional benefits are not captured in the PV
2 analysis, further discussion of these additional benefits is provided in section 6.4.5.

3 **Environmental and Economic Development Attributes:** The environmental
4 footprint analysis provided no basis to rethink BC Hydro's current actions regarding
5 Site C. The economic development impacts of the Site C portfolio analysis show that
6 portfolios including Site C provide higher amounts of Provincial gross domestic
7 product (**GDP**) and employment. Detailed discussions of environmental and
8 economic development attributes are included in section 6.4.4 and 6.4.5
9 respectively.

10 **9.2.6.2 Execution**

11 BC Hydro adopted a multi-stage approach for the planning and evaluation of Site C
12 given the long lead time and the scope of evaluation and development work required
13 for a major hydroelectric facility. This approach provides multiple decision-making
14 points during project development, and focuses on specific deliverables and
15 objectives at each stage:

- 16 • Stage 1 (Review of Project Feasibility) took place from 2004 to 2007. The
17 review concluded that it would be prudent to continue to investigate Site C as a
18 potential resource option to address the electricity supply gap within BC Hydro's
19 service area.
- 20 • BC Hydro moved to Stage 2 (Consultation and Technical Review) following
21 direction by the B.C. Government in the 2007 BC Energy Plan. Stage 2
22 included consultations with Aboriginal groups, the public and stakeholders, as
23 well as advancing environmental studies, field studies, engineering design and
24 technical work. Based on Stage 2 key findings, BC Hydro recommended
25 proceeding to the next stage of project planning and development, including an
26 environmental and regulatory review.

-
- 1 • BC Hydro entered Stage 3 (Environmental and Regulatory Review) in
2 April 2010, following a decision by the B.C. Government to advance the project
3 to the next stage of development. Stage 3 includes an environmental
4 assessment process by federal and provincial regulatory agencies.
 - 5 • Should BC Hydro receive environmental certification at the end of Stage 3 for
6 Site C, Stage 4 would include a decision by BC Hydro's Board of Directors and
7 the B.C. Government to proceed to full project construction
 - 8 • Stage 5 (Construction) is the final stage, involving an approximately seven-year
9 construction period, with one additional year for final project commissioning,
10 site reclamation and demobilization

11 As part of Stage 3, the Site C project is undergoing a harmonized environmental
12 assessment by lead by the Canadian Environmental Assessment Agency (**Agency**)
13 and the Environment Assessment Office (**EAO**), which includes a Joint Review
14 Panel (**JRP**) process. The environmental assessment process commenced in
15 August 2011 and is anticipated to take approximately three years to complete. The
16 environmental assessment process for Site C includes several public comment
17 periods, as well as public hearings under a JRP.


18 Milestones of the environmental assessment process for Site C to date include:

- 19 • **May 2011:** BC Hydro initiated the environmental assessment process by
20 submitting a Project Description Report to the Agency and the EAO
- 21 • **August 2011:** The Project Description Report was formally accepted by the
22 Agency and EAO, which commenced the formal environmental assessment
23 process
- 24 • **September 2011:** A draft agreement was released by the federal and B.C.
25 Ministers of Environment for a harmonized environmental assessment of
26 Site C, including a JRP process. The agreement was subject to a 30-day public
27 comment period.

-
- 1 • **February 2012:** The agreement for a harmonized environmental assessment of
2 Site C was finalized by the regulatory agencies in February (and amended
3 following the implementation of *CEAA 2012*). This agreement provided
4 guidance on expected timing for each review stage.
- 5 • **April 2012:** Draft Environment Impact Statement (**EIS**) Guidelines for Site C
6 were issued by the Agency and the EAO for a 45-day public comment period,
7 which included open house sessions in key communities in northern B.C. and
8 Alberta
- 9 • **September 2012:** Final EIS Guidelines were provided to BC Hydro by the
10 Agency and the EAO. The EIS Guidelines set out the information that must be
11 included in the EIS for Site C.
- 12 • **January 2013:** The Site C EIS was filed with Agency and the EAO. The EIS is
13 a detailed report of potential environmental, economic, social, health and
14 heritage effects of Site C and, where effects cannot be avoided, it identifies
15 options for mitigation. The report also includes a review of the need for Site C
16 and analysis of potential alternatives and benefits of the project.
- 17 • **February/March 2013:** The Site C EIS was issued for a 60-day public
18 comment period, which included open house sessions in key communities in
19 northern B.C. and Alberta
- 20 • **July 2013:** The Amended EIS, reflecting changes requested by the Agency and
21 EAO, was filed with the Agency and the EAO
- 22 **August 2013:** Commencement of the JRP stage of the environmental assessment.
- 23 [Figure 9-1](#) provides a high level summary of the process. Based on the schedule
24 provided by the environmental assessment agencies, the process is expected to be
25 completed in the fall of 2014.

1

Figure 9-1 Environmental Assessment Process



2 *Risk Mitigation*

3 BC Hydro has reviewed the key project risks and has mitigation strategies in place
 4 for each risk identified, as summarized in [Table 9-11](#) below.

5

Table 9-11 Key Project Risks and Risk Management

Risk: Regulatory Schedule	
Description	Risk Management
<p>The regulatory process and schedule for Site C is determined by the federal and provincial regulatory bodies, and may be subject to changes in schedule and/or scope.</p>	<p>Prior to commencing the formal environmental assessment process, BC Hydro undertook project definition work, early environmental studies and other work to determine whether it was prudent to proceed to the environmental assessment stage. This work also included the establishment of several Technical Advisory Committees on key regulatory topics to consult with regulatory bodies and stakeholders regarding the potential scope of required studies. This preparatory work enabled some anticipation of the requirements of the environmental assessment process, and mitigates the risks of a process delay.</p> <p>Site C is now undergoing the formal environmental assessment process. In February 2012, the federal and provincial governments announced that an agreement had been finalized for a harmonized environmental review of Site C. This agreement identified defined timelines associated with the key steps of the environmental assessment process. To date, these defined timelines have been met and the regulatory process is on schedule.</p>

Risk: Achieving Accommodation Agreements with First Nations, where appropriate	
Description	Risk Management
<p>The Crown has a duty to consult, and where appropriate, accommodate Aboriginal groups.</p>	<p>BC Hydro and Aboriginal groups are engaged in consultation and engagement processes that will continue through all stages Site C. To date, BC Hydro has engaged approximately 50 Aboriginal groups in B.C., Alberta, Saskatchewan and the Northwest Territories.</p> <p>BC Hydro has concluded 13 consultation agreements representing 16 First Nations to date. Others remain under discussion. Consultation activities include:</p> <ul style="list-style-type: none"> • Providing access to and facilitating an understanding of project-related information, including but not limited to the need for and alternatives to Site C; • Identifying and understanding the issues, interests and concerns brought forward by Aboriginal groups about Site C; • Creating opportunities to receive input from Aboriginal groups into the planning, design, construction and operation of Site C; • Acquiring, considering and incorporating traditional land use information; • Facilitating participation in the environmental assessment process through provision of capacity funding and access to technical expertise as it relates Site C; • Negotiating IBAs where appropriate; • Identifying potential training, employment, contracting and broader economic opportunities related to the project that may be of interest to Aboriginal groups or individuals.
Risk: Project Design	
Description	Risk Management
<p>New technical information could require a change in project design or construction.</p>	<p>BC Hydro undertook significant site investigation work in the design phase of the project. This allowed BC Hydro to characterize ground conditions for design and construction purposes.</p> <p>As a result of these investigations and associated engineering work, the project design has been upgraded from the historical project design to meet current seismic, safety and environmental guidelines. The project design for Site C is robust and capable of meeting unexpected conditions. Key design upgrades have resulted in improved foundation stability, greater seismic protection, enhanced spillway safety and additional generating capacity.</p> <p>In keeping with BC Hydro and international practice for major projects, an external technical advisory board composed of global experts in hydroelectric development reviewed and provided feedback on BC Hydro's design choices for Site C.</p>

Risk: Project Costs	
Description	Risk Management
There is the risk of additional costs or delays during the construction phase.	<p>Due to engineering, environmental and consultation work done in Stages 2 and 3, Site C has reached an advanced level of project definition. As a result, the \$7.9 billion project cost estimate is at a higher level of accuracy than previous estimates (the Site C cost estimate is a Class 3 cost estimate). BC Hydro is utilizing project management and project control methods to deliver the project within this mandate.</p> <p>The Site C cost estimate includes contingencies (18 per cent on direct construction costs and 10 per cent on indirect costs, excluding some costs in reserves). This an appropriate level of contingency given the level of uncertainty in future conditions.</p> <p>BC Hydro’s capital cost estimate for Site C has undergone an external peer review by KPMG, which determined that the methodologies and assumptions used in the cost estimate are appropriate.</p> <p>The project procurement approach has been designed to, among other things, efficiently allocate and manage project risks to reduce the likelihood of construction cost overruns or delays.</p>
Risk: Labour	
Description	Risk Management
Availability of labour could be constrained during the construction period.	<p>BC Hydro is working with contractors, employers, educational institutions, local and Aboriginal community groups, employment agencies and related organizations to advance initiatives to secure an available supply of qualified local workers.</p> <p>Some examples of initiatives aimed at providing local labour opportunities include undertaking skilled trades capacity building. Examples of capacity building include providing \$1 million to support trades and skills training at Northern Lights College, and other contributions aimed at attracting new entrants into trades training.</p> <p>The Site C cost estimate includes an appropriate level of contingency to reflect uncertainty in future conditions.</p>

1 **9.2.6.3 Future Review Process**

2 **Environmental Assessment:** As described above, Site C has entered the JRP
 3 stage of the harmonized federal-provincial environmental assessment process. A
 4 large number of federal, provincial and local government permits and approvals will
 5 be required during the construction and operational phases of Site C, including
 6 authorization from Fisheries and Oceans Canada pursuant to sections 32 and 35(2)
 7 of the Canada *Fisheries Act*.¹¹

¹¹ R.S.C. 1985, c.F-14.

1 **BCUC:** BC Hydro is exempt from any requirement to obtain a Certificate of Public
2 Convenience and Necessity (**CPCN**) for Site C pursuant to subsection 7(1)(d) of the
3 *CEA*. BC Hydro anticipates that the costs for Site C would be amortized over a long
4 period. This amortization period and rate impact would be determined through a
5 future regulatory process with the BCUC.

6 **9.2.7 Recommended Action 7: Pursue bridging options for capacity**
7 ***Fill the short-term gap in peak capacity with cost-effective market purchases***
8 ***first and power from the Columbia River Treaty second.***

9 Site C is expected to be available by F2024. There is a five-year capacity gap with or
10 without Expected LNG load from F2019 to F2023. BC Hydro proposes to rely on the
11 market, backed up by the CE provided under the Columbia River Treaty, for up to
12 about 300 MW to meet any system capacity shortages during this period because
13 the reliance is for a short period and because the market/CE is cost-effective as
14 compared to B.C.-based capacity resources that could be in-service by F2021 and
15 would only be needed for about five years.¹²

16 However, there is uncertainty with respect to the CE. While the Columbia River
17 Treaty has no termination date, either Canada or the U.S. can unilaterally terminate
18 most of the provisions of the Columbia River Treaty any time after
19 September 16, 2024, providing at least 10 years' notice is given. In addition,
20 planning to rely on the market for the five-year F2019 to F2023 period does not meet
21 the self-sufficiency requirement set out in subsection 6(2) of the *CEA*. Lieutenant
22 Governor-in-Council (**LGIC**) authorization is required.

23 For Expected LNG load, BC Hydro would advance natural gas-fired SCGTs for the
24 North Coast in a staged and flexible manner as back-up for transmission outages
25 and reliability. Refer to section [9.3.2](#).

¹² Burrard would continue to be available to provide transmission support services and in the case of emergency as permitted by section 13 of the *CEA*.

9.2.7.1 Justification

Relying upon the markets and the CE as bridging resources for up to about 300 MW for the five-year F2019 to F2023 period is beneficial for BC Hydro's ratepayers. The costs to maintain the market and CE capacity options is lower than the alternative solutions of either building new natural gas-fired generation or Revelstoke Unit 6 solely for a five-year period before Site C's earliest ISD. The market and CE capacity option-related costs are expected to be incidental business expenses.

9.2.7.2 Execution

To ensure BC Hydro has adequate capacity resources available to bridge to Site C, BC Hydro and Powerex will undertake two activities:

- Continue to monitor market conditions and U.S./Alberta transmission system development to facilitate and ensure that BC Hydro has access to up to about 300 MW of market purchases during all hours of the year and with a specific focus on BC Hydro's winter system peak load conditions
- Manage CE, trade commitments and market optimization to about 300 MW of the CE to be available to back up the 300 MW of market purchases

9.2.7.3 Future Approval Process


Relying upon the market and CE for short-term capacity needs from F2019 to F2023 does not meet the self-sufficiency requirements in subsection 6(2) of the CEA. Subsection 6(3) of the CEA provides an exception to the self-sufficiency requirement found in subsection 6(2). The LGIC may by regulation authorize BC Hydro to enter into contracts for purposes of not meeting the self-sufficiency requirement.

9.2.8 Recommend Action 8: Advance reinforcement along existing GMS-WSN-KLY 500 kV transmission

Advance reinforcement of the existing GM Shrum-Williston-Kelly Lake 500 kV transmission lines to be available by F2024.

1 The northern transmission system transmits power from the GM Shrum (**GMS**)
 2 generating facilities in the Peace River region through to Williston (**WSN**) in the
 3 Prince George region to connect with the Interior-to-Lower Mainland system at Kelly
 4 Lake (**KLY**) near Clinton, B.C. Three parallel 500 kV transmission lines (with five
 5 segments – 5L1, 5L2, 5L3, 5L4 and 5L7) deliver power from GMS to WSN and three
 6 500 kV transmission lines (5L11, 5L12 and 5L13) deliver power from WSN to KLY.

7 **Figure 9-2 Northern Region Transmission**



8 The available transfer capabilities (**ATC**) of the GMS-WSN and WSN-KLY
 9 transmission line segments (cut-planes) are expected to be exceeded by dispatch of

1 power from the existing and new resources in the Peace River region. To provide
2 adequate incremental transfer capabilities, these cut-planes have to be reinforced.

3 Non-wire upgrades contemplated include the addition of shunt compensation at
4 WSN and KLY Substations and enhancing the series compensation at Kennedy and
5 McLeese series capacitor stations. The shunt compensation is expected to add
6 580 MW to 650 MW to the total transfer capability (**TTC**), while the enhance series
7 compensation are expected to add 630 MW to 750 MW to the TTC.

8 The cost to complete further study work over the next five years is estimated to be
9 \$5.0 million. BC Hydro will have a total cost estimate with an accuracy range of
10 +35 per cent/-15 per cent when the study work is completed. The transmission
11 upgrades are planning level estimates and detailed analytical studies are required to
12 finalize scope and cost.

13 **9.2.8.1 Justification**

14 In the various portfolios that were analyzed in Chapter 6 of the IRP, the need to
15 reinforce the GMS-WSN-KLY transmission line was either by non-wire upgrades or
16 additional transmission lines. Portfolios were also analyzed both with and without
17 Site C as a resource. The results indicate that for portfolios without Site C, the ATC
18 of GMS-WSN-KLY transmission cut-planes will be exceeded by F2029 (with
19 Expected LNG load) and by F2032 (without any potential LNG load) due to the need
20 for new generating resources. In portfolios with Site C, the need for the non-wire
21 upgrades advances from F2029 to F2024.

22 In the majority of cases, the incremental transfer capabilities of the non-wire
23 upgrades is expected to push the need for new transmission lines in the GMS-WSN
24 and WSN-KLY 500 kV corridors beyond the 30-year planning horizon. In a few
25 remaining portfolios these lines will only be needed towards the end of the 30-year
26 planning period. Given that the majority of the analyzed mid gap portfolios did not
27 require a new transmission line on the GMS-WSN-KLY corridor, the non-wire
28 upgrades are being recommended.

1 **9.2.8.2 Execution**

2 BC Hydro would initiate further studies to confirm scope and cost of the required
3 non-wire transmission upgrades on the GMS-WSN and/or WSN-KLY cut-planes for
4 a F2024 ISD.

5 **9.2.8.3 Future Approval Process**

6 Pursuant to BC Hydro's Capital Project Filing Guidelines, BC Hydro would apply for
7 a CPCN from the BCUC pursuant to subsection 46(1) of the *UCA* if the cost of
8 identified projects is greater than \$100 million.

9 **9.2.9 Recommended Action 9: Reinforce South Peace transmission**

10 ***Review alternatives for reinforcing the South Peace Regional Transmission*** 11 ***Network to meet expected load.***

12 The recently approved Dawson Creek/Chetwynd Area Transmission (**DCAT**) project
13 will enhance the transmission capacities in the Dawson Creek and Groundbirch
14 sub-regions. Continued load growth in these and other areas encompassing the
15 South Peace region indicate further regional transmission reinforcements are
16 required. BC Hydro must continue to advance its current regional planning activity
17 referred to as the Peace Region Electrical Supply (**PRES**) study¹³ to confirm the
18 preferred regional capacity addition alternative following DCAT.

19 **9.2.9.1 Justification**

20 Electricity demand in the South Peace area is growing due to natural gas exploration
21 and development of the Montney shale gas basin. Over the next 10 years, annual
22 load growth in South Peace is expected to be about 10 times that of the rest of
23 BC Hydro's service area. DCAT will increase the N-0 transfer capability to Dawson
24 Creek and Groundbirch areas to 400 MW. The available capacity is expected to
25 diminish as a result of the growing demand in South Peace region. Additional N-0

¹³ PRES was formerly referred to as GDAT (GMS to Dawson Creek Area Transmission).

1 transmission capacity is expected to be required by F2019. As discussed in
2 section 6.2, the South Peace region is an area where the need to build small,
3 redundant gas units along with the need to operate natural gas-fired units is
4 expected to result in transmission being the preferred supply option.

5 **9.2.9.2 Execution**

6 BC Hydro should complete Identification Phase studies to determine the preferred
7 alternative for providing incremental transmission capacity in South Peace region
8 and secure a F2019 in-service date for the identified upgrades. These studies would,
9 among other things, identify and evaluate alternatives, including local natural
10 gas-fired generation. These studies are expected to be completed by the end of
11 F2014 at an estimated cost of \$1.2 million. BC Hydro will have a total cost estimate
12 with a +35 per cent /-15 per cent accuracy range when these studies are completed.

13 **9.2.9.3 Future Approval Process**

14 Pursuant to BC Hydro's Capital Project Filing Guidelines, BC Hydro would apply for
15 a CPCN from the BCUC pursuant to subsection 46(1) of the *UCA* if the cost of
16 identified projects is greater than \$100 million.

17 **9.2.10 Recommended Action 10: Supporting Clean Energy Sector**

18 ***Advance a set of actions that will support a healthy, diverse clean energy***
19 ***sector and promote clean energy opportunities for First Nations' communities.***

20 This Recommended Action, as described in Chapter 8, Clean Energy Strategy, was
21 developed in response to the request from the Minister and to address stakeholder
22 comments received during the last IRP consultation period.

23 **9.2.10.1 Justification**

24 As described in section 8.3, the Clean Energy Strategy and this Recommended
25 Action address the Minister's request to do more to support the clean energy sector

1 in B.C and promote clean energy opportunities for First Nations communities, which
2 also advances the following *CEA* objectives:

- 3 • Objective 2(c), “to generate at least 93% of the electricity in British Columbia
4 from clean or renewable resources...”
- 5 • Objective 2(h) to encourage the switching from one kind of energy source or use
6 to another that decreases greenhouse gas emissions in British Columbia
- 7 • Objective 2(i) “to foster the development of First Nation and rural communities
8 through the use and development of clean or renewable resources.”

9 In scoping the Clean Energy Strategy, BC Hydro was guided by its energy and
10 capacity LRBs and by the *CEA* objective 2(f) “to ensure the authority’s rates remain
11 amongst the most competitive of rates charged of public utilities in North America.”

12 **9.2.10.2 Execution**

13 The Clean Energy Strategy describes implementation of a set of strategic
14 actionsthat will be initiated over the next two fiscal years, including engagement with
15 stakeholders and First Nations on the design and implementation of key components
16 and annual progress reviews with the B.C. Government.

17 Key features include:

- 18 1. Undertake EPAs Renewals
- 19 2. As outlined in sections 1.3, 4.2.5.1, and 8.4.1, BC Hydro continues to rely on
20 EPAs renewals as a major resource to meet future customer demand, second
21 only to DSM in terms of energy volume. By F2017, EPA renewals are expected
22 to account for 1,200 GWh/year of energy, and by F2033, about
23 6,400 GWh/year.

24 BC Hydro has offered a SOP for small-scale clean energy projects since 2008
25 and a Net Metering Program for residential and commercial customers

1 since 2003. BC Hydro recently modified various SOP rules and made changes
2 to the standard SOP EPA to re-affirm the original spirit and intent of the
3 program. For example, on March 26, 2013 BC Hydro amended the SOP rules
4 to: limit the participation of clustered projects that exceed 15 MW; better
5 manage when SOP energy supply comes on-line by maintaining flexibility to
6 extend CODs for projects by up to two years; and extend the wait period for
7 projects with terminated EPAs from three years to five years as a deterrent to
8 opportunistic behaviour with respect to EPA pricing and other terms and
9 conditions. In addition, this increased waiting period will be better aligned with
10 the timing for when new energy resources are required.

11 The overall SOP annual target for these type of resources will be increased
12 immediately with the approval of the IRP from 50 GWh/year to up to
13 150 GWh/year to facilitate the development of small-scale community projects.
14 BC Hydro will amend the SOP by removing high-efficiency cogeneration using
15 non-clean fuels from SOP eligibility to enable a greater role for clean energy. In
16 addition, a “micro-SOP” component, in the range of 100 kW to 1 MW, will be
17 introduced within the overall SOP annual target. The new component is
18 envisioned with a streamlined process to reduce development costs

19 3. Promote First Nations participation in future development in clean energy
20 projects

21 In implementing this action, BC Hydro will engage First Nations and IPPs on:

- 22 • How to introduce new elements to the SOP to encourage First Nations
23 participation.
- 24 • How to put greater emphasis on First Nations participation in clean
25 energy projects as the need for the next major call for power emerges.

26 4. Highlight Energy Acquisition as part of the IRP CRPs

1 The uncertainty that BC Hydro faces in its plans are shown in the CRPs and
2 BC Hydro will prepare to launch a major acquisition process should the large
3 gap CRP scenario materialize. The IRP and power acquisition processes
4 must be linked to balance align future energy need with supply, while also
5 reducing the adverse impact of market uncertainty on the B.C. clean energy
6 sector. BC Hydro proposes to review the IRP in two years to among other
7 things assess whether new information is observed to warrant an update to
8 the November 2013 IRP on the recommendation of a new energy call.

9 5. Pursue bilateral agreements

10 In furtherance of the CEA energy objectives, BC Hydro will work with the
11 Province to consider cost-effective bilateral procurements with benchmarking
12 practices adhering to competitive processes. Section 8.4.5 provides the
13 details in examples of these IPP bilateral agreements

14 6. Work with government to advance electrification

15 With input from government policy signals on GHG reductions to incent
16 electrification, BC Hydro will focus on advancing electrification with a focus on
17 industrial, transportation and other sectors.

18 7. Continue to encourage the use of clean or renewable electricity by the LNG
19 industry

20 BC Hydro and government continue to have discussions with LNG developers
21 to understand their electricity supply requirements and the benefits of
22 consuming electricity from BC Hydro. BC Hydro is prepared to serve all
23 electricity demands arising from the development of the industry in B.C.

24 8. Regularly update the inventory of clean or renewable resource options in B.C.

25 BC Hydro is committed to maintaining a current understanding of the
26 resource potential, prices and technical capabilities of different clean or

1 renewable technologies in B.C. In F2014, BC Hydro will commence
2 engagement with IPPs and industry experts on resource pricing and updating
3 the Resource Options Report.

4 **9.2.10.3 Future Approval Process**

5 Future resource acquisitions that are identified through the electrification activities
6 are expected to inform future IRPs and will be subject to IRP approvals.

7 Future resource acquisitions related to LNG supply contracts will be approved
8 through the provincial LNG negotiating and contracting process.

9 Any bilateral IPP EPAs would be filed with the BCUC for acceptance pursuant to
10 section 71 of the *UCA*. Incremental EPAs would be subject to BCUC review of
11 prudence through future RRA processes.

12 **9.2.11 Base Resource Plan LRBs**

13 The Recommended Actions identified in section [9.2.1](#) through to section [9.2.9](#)
14 provide BC Hydro's BRP without Expected LNG load for meeting its current and
15 future customers' electricity needs on a reliable and cost-effective basis. The BRP
16 aligns with the *CEA* energy objectives.

17 The near-term costs associated with the recommended actions to correspond to the
18 BRP Load-Resource Balances are outlined in [Table 9-12](#).

1
2

Table 9-12 F2014 to F2016 BRP Recommended Action Execution Expenditure


Recommended Action		Near-Term Execution Expenditure (in \$F2013)			
		Applicability	F2014 (\$ million)	F2015 (\$ million)	F2016 (\$ million)
DSM (Conservation)	1. Moderate current spending and maintain long-term target	Program execution	175	145	125
	2. Pursue DSM capacity conservation	Program execution	1.9	1.9	1.9
	3. Explore more codes and standards	Program execution	N/A	1.5	1.5
Portfolio Cost Management	4. Optimize existing portfolio of IPP resources	N/A			
	5. Customer incentive mechanisms	N/A			
Supply-Side Resources	6. Continue to advance Site C	Annual expenditure excluding IDC ¹⁴	88	311	376
	7. Pursue bridging options for capacity	No cost estimate			
Transmission Resources	8. Advance reinforcement along existing GMS-WSN-KLY 500 kV transmission line	Notional expenditures for technical studies	1	1	1
	9. Reinforce South Peace transmission	Notional expenditures for technical studies	1.2	N/A	N/A
	10. Supporting Clean Energy sector	Consultation and Consultant Studies	N/A	1	1

3 The LRBs for energy and capacity after implementation of the BRP Recommended
4 Actions are depicted in [Figure 9-3](#) and [Figure 9-4](#) respectively.

¹⁴ Project annual expenditures as shown exclude interest during construction (**IDC**), nominal expenditures are converted to F2013 constant dollars based on a 2% annual inflation rate; F2015 and F2016 estimates are reflective of Site C's 10-year plan.


1

Figure 9-3 Energy LRB for BRP



2

Figure 9-4 Capacity LRB for BRP



* including planning reserve requirements

1 The BRP shows that the Recommended Actions will supply sufficient energy prior to
2 Expected LNG to meet customers' needs past F2033 for energy; however, additional
3 capacity resources will need to be developed over the later stages of the F2020s. In
4 bridging to Site C, about a 300 MW reliance on market and CE will be required and
5 would be cost-effective.

6 **9.2.12 Long Run Marginal Cost**

7 BC Hydro uses the LRMC to signal the value that should be placed upon acquiring
8 new resources which include: DSM savings; IPP EPA renewals; new IPP
9 acquisitions; Resource Smart; Site C; and equipment efficiency and loss valuations.
10 As the LRMC increases, the available supply from each of the resource types
11 increases. This section highlights the LRMC based upon the BRP that will guide
12 future processes and investments. Supplying the Expected LNG load will not have a
13 material impact on the energy LRMC because BC Hydro has enough energy
14 resources to serve the Expected LNG load with the implementation of the BRP.
15 Expected LNG would not likely materially impact the capacity LRMC because
16 BC Hydro anticipates that the LNG-related need for incremental capacity will be met
17 by SCGTs, leaving Resource Smart projects such as Revelstoke Unit 6 as the
18 marginal capacity resource.

19 **9.2.12.1 Definition**

20 LRMC can be defined as the change in the long-run total cost resulting from a
21 change in the quantity of output produced. In short, LRMC represents the price of
22 the most cost-effective way of satisfying incremental customer demand. The
23 standard economic technique used to determine LRMC is to calculate the minimum
24 present-day view of the cost of meeting a permanent increment (or decrement) of
25 demand in which all capital and operating production inputs can be considered
26 variable. BC Hydro uses an approach where the incremental resource acquisitions
27 needed to supply future requirements are stated on a levelized unit electricity cost
28 basis to aid in comparing resources with differing attributes.

1 **9.2.12.2 Setting the LRMC**

2 *Energy*

3 Over the past 10 years, BC Hydro had a significant projected need for new
4 resources and the marginal resource was the acquisition of greenfield clean or
5 renewable IPPs. The LRMC reflected the results of the most recent, broadly-based
6 power acquisition process (e.g., the Clean Power Call results). Using this
7 benchmark, the LRMC based upon greenfield clean or renewable IPPs would
8 currently be \$135/MWh (F\$2013). Greenfield clean or renewable IPPs were the
9 marginal resource since there were insufficient cost-effective alternative resources
10 available to provide the needed supply for customers. This LRMC provided a price
11 signal for BC Hydro to apply to all other resource options listed above.

12 Chapter 2 demonstrates there is a need for new B.C.-based resources in F2017 and
13 that is why the energy LRMC is not based on spot market price forecasts.

14 Modifications to the self-sufficiency requirements and a lower load forecast have
15 reduced forecasted need, with the next greenfield IPP clean or renewable energy
16 acquisition not expected within the planning horizon unless LNG needs exceed the
17 3,000 GWh/year expected amount. BC Hydro currently has sufficient alternative
18 cost-effective B.C.-based resources to meet expected future needs including DSM,
19 IPP EPA renewals, Resource Smart, Site C and equipment efficiency and loss
20 valuations. The question becomes how much of these alternative resources need to
21 be acquired to meet expected demand.

22 As summarized in section [9.2.11](#), the BRP LRB includes Site C, DSM Option 2
23 /DSM Target and the recommended EPA management actions:

- 24 • As was shown in section 6.4, Site C is a cost-effective clean or renewable
25 resource and if Site C were not constructed, additional greenfield clean or
26 renewable IPPs would be needed. Site C's adjusted UEC is about \$85/MWh.
27 However, Site C is not a marginal resource because Site C is needed.

-
- 1 • BC Hydro tested varying levels of DSM in section 6.3 and demonstrated that
2 DSM Option 2 was more cost-effective than DSM Option 3. Hence, not all DSM
3 is being acquired and it is a marginal resource; e.g., incremental Option 3 DSM
4 programs.
 - 5 • In addition, the IPP EPA renewals that were analyzed in section 4.2.5.1 were
6 cost-effective and were included in the LRBs. Any EPA renewals above
7 planned assumptions would be marginal resources. As described in
8 section 4.2.5.1, BC Hydro expects to negotiate prices at or close to the spot
9 market price forecast but must consider factors such as energy product
10 attributes and associated non-energy benefits.

11 Thus, DSM and EPA renewals are marginal resources over the planning horizon
12 (i.e., thru F2033), after which BC Hydro would again require greenfield clean or
13 renewable IPPs. In the process of developing and analyzing the IRP as discussed in
14 Chapters 4 and 6, the LRMC was reduced from \$135/MWh to \$100/MWh. This
15 reduced value informed the levels of DSM modelled and the upper price limit on
16 EPA renewals. It also informed what Var and Volt Optimization (**VVO**) savings to
17 target as well as provided a price signal for internal equipment acquisition/ loss
18 evaluation decisions. Depending on the amount of LNG load that BC Hydro
19 ultimately serves and whether non-LNG load growth occurs as expected, the LRMC
20 may be reduced to about \$85/MWh and still provide an adequate supply of
21 resources over the planning horizon.

22 *Capacity*

23 The LRMC for capacity resources when needed to augment the acquisition of
24 energy and capacity resources is based upon Revelstoke Unit 6, which is lower cost
25 than SCGTs. Revelstoke Unit 6 is being advanced as a contingency resource for its
26 earliest in-service date; however, it is not expected to be needed in the BRP until
27 F2031 . The Unit Capacity Cost (**UCC**) for Revelstoke Unit 6 is between
28 \$50/kW-year and \$55/kW-year.

1 *Energy and Capacity LPMC Summary*

2 The LPMC outlook is as follows:

- 3 • Energy: \$85 to \$100 per MWh F2017 thru end of the planning
4 horizon (i.e., F2033)
- 5 • Capacity: \$50 to \$55 per kW-year F2017 thru F2032.

6 The energy and capacity LPMCs relate to the cost of procuring annual firm energy
7 and dependable capacity delivered to the Lower Mainland; hence, adjustments as
8 described in section 3.4.3 and Appendix 3A-34 (such as the costs of transporting the
9 energy and capacity to the Lower Mainland, including line losses) are included in the
10 LPMCs. Energy LPMC Implications:

11 *EPA Management*

12 As described in Chapter 4, BC Hydro's EPA renewal planning assumptions are:

13 a) 75 per cent for small run-of-river project EPAs; b) 50 per cent for bioenergy EPAs;
14 and c) 100 per cent for the remainder of EPAs. This results in about 4,700 GWh/year
15 of firm energy from EPA renewals by F2024. As described in section [9.2.4](#),
16 BC Hydro should be able to benefit from the fact that the IPP would have fully or
17 largely recovered its initial capital investment in the initial EPA term, by negotiating a
18 lower energy price recognizing that the seller's opportunity cost is selling into the
19 spot market. Section 5.6 of this IRP contains BC Hydro's reference (mid) spot
20 market forecast of Mid-C prices ranging from about \$25/MWh to \$40/MWh over the
21 next 20 years.

22 The spot market provides non-firm energy and no capacity, and generally has a term
23 of one hour.¹⁵ EPA renewals provide a different product than the spot market,
24 including a longer contract term and in some cases dependable capacity, voltage

¹⁵ Market forward fixed-price contracts are available for terms of up to five years, with less liquidity in later years.

1 support and dispatchability. Therefore there is likely to be some pricing up-lift from
2 the spot market. BC Hydro is not likely to renew EPAs with a firm energy price
3 greater than the LRMC.

4 *DSM Plans*

5 The IRP has recommended that the DSM target remain unchanged for F2021 at
6 7,800 GWh/year and 1,400 MW. The DSM plan that is recommended to achieve that
7 plan is shown in section [9.2.1](#). Contained within that DSM plan are the three DSM
8 tools (i.e., codes and standards, rates structures and programs), which are
9 influenced by the LRMC:

- 10 • The conservation rates utilize a two-tier design of which the trailing step is
11 influenced by the energy LRMC. As BC Hydro moves forward with its plans and
12 rate design applications, the new LRMC will need to be considered.
- 13 • Programs are also influenced by the LRMC in that programs with the highest
14 UC can be scaled down with the least long-term effects. As discussed in
15 section [9.2.1](#), DSM programs will generally be designed in a manner consistent
16 with the LRMC.

17 *Other Resource Decisions*

18 The other areas where BC Hydro will generally apply the LRMC include equipment
19 purchases such as conductor sizing, transformer efficiency design and purchases,
20 transmission voltage selection and VVO.

21 **9.3 LNG Base Resource Plan**

22 **9.3.1 Recommended Action 11: Explore natural gas-fired generation for** 23 **the North Coast**

24 ***Working with industry, explore natural gas supply options on the North Coast***
25 ***to enhance transmission reliability and to meet expected load.***

1 This Recommended Action would advance work to determine where and how
2 natural gas-fired generation could be built in the North Coast to reduce project lead
3 times and to be able to meet LNG load requirements as required. Acquiring SCGT
4 generation on the North Coast would support system generating capacity needed to
5 supply Expected LNG while supporting the transmission system in terms of
6 enhanced reliability of supply and ability to operate during transmission outages for
7 maintenance purposes.

8 **9.3.1.1 Justification**

9 The Prince George to Terrace Capacitor (**PGTC**) project (described in section [9.3.3](#))
10 is expected to increase the transmission system to be capable of supplying the
11 entire North Coast demand, including new non-compression LNG load, through the
12 radial series compensated 500 kV transmission line that runs from Prince George to
13 Terrace. The radial nature of the North Coast supply makes it susceptible to forced
14 and planned outages of the 500 kV line. Currently, during an outage of the 500 kV
15 line BC Hydro relies on local generation to supply a portion of the North Coast load
16 in an islanded situation. Incremental load growth in the region is expected to exceed
17 the islanding capability of the existing and committed North Coast supply in F2019.

18 The addition of SCGTs in the North Coast region would increase the capacity
19 available to carry load in the North Coast through extended contingency and
20 maintenance outages. Based on the incremental capacity requirement of 360 MW
21 for the Expected LNG load starting in F2020, four 100 MW SCGTs may be required.
22 The SCGTs would offset the need to build alternative generation in the system
23 including potentially Revelstoke Unit 6. The use of natural gas-fired generation
24 would increase the emission of GHGs, but is consistent with the British Columbia's
25 Energy Objectives Regulation. The decision on whether to proceed beyond
26 exploring natural gas supply options to committing to build SCGTs would be
27 pursuant to completion of supply agreements between BC Hydro and LNG
28 proponents.

9.3.1.2 Execution

BC Hydro will conduct technical studies to determine the amount of SCGT capacity and ancillary services needed under various islanded operation scenarios. These studies will identify the technical requirements that will allow SCGT supply of the load during both forced and maintenance outages. Detailed project specifications will need to be completed by F2015 such that a subsequent competitive procurement process can be completed and facilities constructed and in-service by F2020, which coincides with the addition of the North Coast non-compression Expected LNG load. The technical studies are estimated to take one year to complete at an estimated cost of \$0.5 million.

Assuming the technical studies confirm the need for natural gas-fired generation to support North Coast reliability levels, BC Hydro will conduct a competitive power procurement process to enter into an agreement with a private developer to provide capacity and associated ancillary services, with BC Hydro able to call for services as required. BC Hydro will continue to work with potential developers to design a cost-effective and fair procurement process that will meet LNG ISDs. The design and execution of the procurement process is expected to take nine to 12 months to complete at an estimated cost of \$1 million.

9.3.1.3 Future Approval Process

BC Hydro does not yet need to commit to the type and quantities of natural gas-fired generation required to maintain or enhance North Coast supply reliability. Expenditures for specific future resources will be contained in future RRAs or as part of EPA(s) filed with the BCUC pursuant to section 71 of the *UCA*.

9.3.2 Recommended Action 12: Explore clean or renewable supply options, if LNG demand exceeds available resources

Explore clean or renewable energy supply options and be prepared to advance a procurement process to acquire energy from clean power projects, as required to meet LNG needs that exceed existing and committed supply.

1 To ensure BC Hydro is prepared to meet both Expected LNG and potentially higher
2 volumes of LNG load, BC Hydro will examine potential clean or renewable energy
3 supplies that may be available both in the North Coast region and more generally in
4 BC Hydro's service area. BC Hydro will also contemplate what processes and
5 timeline it would have to follow to meet LNG proponent load requirements.

6 **9.3.2.1 Justification**

7 As shown in Chapter 2, BC Hydro has included a 3,000 GWh/year and 360 MW of
8 load for Expected LNG. As discussed in Chapter 6, BC Hydro has sufficient energy
9 to be able to supply Expected LNG without acquiring additional clean or renewable
10 energy resources. However, given uncertainty as to potential LNG load and the fact
11 that some LNG proponents have projected they could be in-service by F2020,
12 BC Hydro proposes to advance work on developing energy acquisition processes in
13 a staged manner.

14 **9.3.2.2 Execution**

15 Over the next 12 to 24 months, BC Hydro will continue to monitor LNG proponent
16 supply requirements and associated timing. Initial work on process development will
17 include review of the most recent acquisitions and assessing what additional
18 features may be required to meet LNG needs. Future LNG supply, as per the British
19 Columbia's Energy Objectives Regulation and the need to ensure supplies will
20 continue to make LNG proponents cost-effective, can be a mix of clean or renewable
21 and natural gas-fired generation. Exact supply mix would be determined as part of
22 future customer supply negotiations between BC Hydro, the B.C. Government and
23 LNG proponents.

24 BC Hydro will not launch a power acquisition process until a clear need has
25 emerged; however, BC Hydro will be prepared to meet LNG supply requests.
26 Anticipated funding to ensure acquisition processes are ready to be launched as
27 required range from \$50,000 to \$500,000.

1 **9.3.2.3 Future Approval Process**

2 The future approval of LNG-related energy acquisitions will be determined by the
3 supply contacts developed.

4 **9.3.3 Recommended Action 13: Advance reinforcement of the 500 kV** 5 **transmission line to Terrace**

6 ***Advance reinforcement of the existing 500 kV transmission line from Prince***
7 ***George to Terrace, which includes development of three new series capacitor***
8 ***stations and improvements in the existing BC Hydro substations to be***
9 ***available by F2020.***

10 The purpose of this project is to increase the transfer capacity of the existing 500 kV
11 transmission circuit between WSN and Skeena (**SKA**). The PGTC part of the
12 reinforcement includes the building of three capacitor stations to be located along
13 existing 500 kV transmission lines 5L61, 5L62 and 5L63 between WSN and SKA
14 and providing voltage support to Glenannan Substation. In addition to PGTC, a new
15 500/287 kV transformer (three 200 MVA units) at SKA is required.

16 **9.3.3.1 Justification**

17 The transmission PGTC upgrades are expected to increase the ability of the North
18 Coast 500 kV transmission line to serve potential increased demand for electricity in
19 northwest B.C. such as LNG Canada in the Kitimat area and potential mine load
20 along the Northwest Transmission Line (**NTL**) corridor.

21 **9.3.3.2 Execution**

22 The PGTC project is currently in the definition (preliminary design) phase. First
23 Nations consultation and stakeholder engagement is taking place to assist with the
24 selection and acquisition of appropriate sites for the capacitor stations. A detailed
25 project plan will be developed for the implementation phase of the project.

26 Progression into implementation phase at this point will be dependent on the
27 customer making a positive final investment decision, which is expected to occur by

1 the end of F2015. BC Hydro's estimated expenditures to this point and completion of
2 definition phase work are \$2.8 million. The estimated cost of the PGTC project is
3 \$125 million with an accuracy of +35 per cent /-15 per cent. Detailed work related to
4 addition of a new transformer at SKA has not yet begun. However, the transformer
5 does not cause any expansion of the substation and is considered a low-risk project
6 with shorter duration than PGTC.

7 **9.3.3.3 Future Approval Process**

8 On March 25, 2013 the B.C. government issued the Transmission Upgrade
9 Exemption Regulation (Ministerial Order No. M073), which exempts BC Hydro from
10 Part 3 of the *UCA* with respect to described transmission facilities, including series
11 capacitor stations and related facilities and equipment and SKA transformer.
12 BC Hydro is in the process of consulting with First Nations with respect to PGTC.

13 **9.3.4 Recommended Action 14: Explore supply options for Horn River** 14 **Basin and northeast gas industry**

15 ***Continue discussions with B.C.'s northeast gas industry and undertake***
16 ***studies to keep open electricity supply options, including transmission***
17 ***connection to the integrated system and local gas-fired generation.***

18 While the pace of expansion in the Horn River Basin (**HRB**) has slowed considerably
19 over the past three to four years due to low gas prices and generally poor economic
20 conditions, it is expected that natural gas prices will eventually recover to where this
21 region will again develop. The emerging LNG industry in B.C.'s northwest may be
22 the driver for further development.

23 To maintain options to electrify this region to both facilitate development and
24 potentially to manage GHGs that may be emitted, BC Hydro recommends that it
25 continue to: monitor natural gas industry developments; engage with industry to
26 keep open supply alternatives to northeast B.C. and the HRB; and continue to
27 support the B.C. Government in the development of its Climate Action Plan. Options

1 include a transmission connection to the integrated system and local natural
2 gas-fired generation.

3 **9.3.4.1 Justification**

4 In F2013, BC Hydro concluded the Northeast Transmission Line (**NETL**) feasibility
5 study work, which looked at the alternatives for extending electrical service to the
6 natural gas industry in northeast B.C., including transmission connection to the
7 integrated system and local natural gas-fired generation. That analysis, which is
8 summarized in section 6.6 and provided In Appendix 2E), addresses the following
9 questions:

- 10 • What actions are required to meet the load in Fort Nelson considering that the
11 solution may be influenced by the HRB industrial loads and supply options?
- 12 • What is BC Hydro's strategy to prepare for significant potential load growth in
13 the combined Fort Nelson and HRB region? What actions are prudent in the
14 absence of load certainty?
- 15 • What approach should BC Hydro take to support provincial energy objectives
16 on reducing GHG emissions via enabling electrification? This analysis
17 considers the amount of carbon dioxide (**CO₂**) that is produced in the HRB
18 under various natural gas production and energy supply scenarios as well as
19 reduction opportunities.

20 Although the analysis shows various outcomes depending on market and pricing
21 scenarios considered, the high-level findings are as follows:

- 22 • A combination of NETL and system clean or renewable energy strategy can
23 reduce GHG emission by 30 to 38 per cent relative to industry
24 business-as-usual (i.e., self-supply). However, this strategy is generally
25 relatively more expensive than other strategies.
- 26 • Natural gas-fired generation strategies can reduce GHG emissions by zero to
27 16 per cent relative to industry self-supply, but generally do not meet the

1 93 per cent *CEA* clean or renewable energy objective. Of the natural gas-fired
2 generation strategies, cogeneration appears to be the lowest cost option, but
3 requires a good long-term balance and consistency of heat load and electric
4 load as well as adequate addressing of commercial risks. BC Hydro-acquired
5 cogeneration shifts more GHG emissions to BC Hydro.

6 The analysis results in the following conclusions:

- 7 • First and foremost, the HRB has significant, but uncertain electrification
8 potential. Absent load certainty, all supply alternatives expose BC Hydro to
9 different types and levels of stranded investment risk.
- 10 • There remains significant uncertainty with respect to natural gas industry's
11 commitment to take electricity service
- 12 • Liability for vented CO₂ needs to be addressed; its inclusion and ownership will
13 heavily influence both the scale of HRB development and the type of work
14 supply alternative that would be most economic. With 70 per cent of total GHG
15 emissions consisting of formation CO₂, meaningful emissions reductions will
16 require carbon capture and sequestration (**CCS**).
- 17 • Lastly, in the absence of load certainty or having customers willing to fund the
18 work, it is premature to undertake significant supply actions in the near term to
19 address the potential for large-scale electrification in the region

20 Given the potential GHG impacts and the *CEA* GHG-related objectives, BC Hydro
21 continues to work with industry on identification of potential future infrastructure
22 requirements and opportunities for minimizing the overall future development
23 footprint for the northeast region.

24 **9.3.4.2 Execution**

25 In line with the recommendation, BC Hydro is continuing to observe and monitor
26 increased interest in electricity supply among natural gas producers operating in the
27 northwest portion of the Montney Basin, i.e., Peace River region north of GMS. This

1 region continues to experience increased levels of activity due to the characteristics
2 of the gas resource and proximity to existing infrastructure. By comparison with the
3 HRB, the Montney Basin resource generally has better economics, is richer in
4 natural gas liquids (in the current price environment proceeds from sales of liquids
5 help improve production returns) and has a lower CO₂ content. This region also
6 encompasses the southern portion of the assumed NETL routing. BC Hydro will be
7 working with Montney Basin natural gas producers and other potential load
8 customers to assess whether there is sufficient electrification potential to justify the
9 need for a Phase 1 (southern portion) NETL project.

10 Resource requirements for these activities and other analysis will be primarily for
11 external consulting support at an estimated cost of \$50,000 to \$100,000 over the
12 next three years.

13 **9.3.4.3 Future Approval Process**

14 No material regulatory approval processes are envisioned at this time given the
15 scope of the Recommended Action.

16 **9.3.5 LNG Base Resource Plan LRBs**

17 The Recommended Actions identified in sections [9.3.1](#) through [9.3.4](#) provide
18 BC Hydro's LNG BRP to supply Expected LNG load. They are aligned with the CEA
19 energy objectives and support the government's LNG strategy and the development
20 of the LNG industry.

21 The near-term costs associated with the recommended actions to correspond to the
22 LNG BRP Load-Resource Balance are outlined in [Table 9-13](#).


1
2

Table 9-13 F2014 to F2016 LNG BRP Recommended Action Execution Expenditure

Recommended Action		Near Term Execution Expenditure (in \$F2013)			
		Applicability	F2014 (\$ million)	F2015 (\$ million)	F2016 (\$ million)
Supply-Side Resources	11. Explore natural gas-fired generation for the North Coast	Technical studies	N/A	0.5	N/A
		To design and execute procurement process	1		
	12. Explore clean energy supply options, if LNG demand exceeds available resources	Expected funding for acquisition process	Up to 0.25	Up to 0.25	N/A
Transmission Resources	13. Advance reinforcement of the transmission line to Terrace	To complete Project Definition Phase	1.4	1.4	N/A
	14. Explore supply options for Horn River Basin and northeast gas industry	To monitor load growth in region	Up to 0.1		


3 The LRBs for energy and capacity after implementation of the LNG BRP
4 Recommended Actions are depicted in [Figure 9-5](#) and [Figure 9-6](#) respectively.

5 **Figure 9-5 Energy LRB for LNG BRP**



1

Figure 9-6 Capacity LRB for LNG BRP



* including planning reserve requirements

2 The LNG BRP shows that the Recommended Actions will supply sufficient energy to
 3 supply Expected LNG needs through F2031, but additional LNG load would advance
 4 the need for energy resources. In particular, there are short-term needs prior to
 5 Site C that can be bridged with market/CE resources, but additional LNG load would
 6 drive the need for more energy acquisitions in the next 10 years. On the capacity
 7 side, the BRP shows a reliance of up to about 300 MW from the market backed by
 8 CE. In the LNG BRP, the capacity shortfall increases to about 650 MW and exceeds
 9 the degree to which market reliance is acceptable. The additional resources to
 10 supply the incremental capacity need is expected to be about 400 MW of local
 11 natural gas-fired generation which has an ability to support the regional transmission
 12 requirements. Towards the end of the F2020's, the need for new capacity is
 13 expected to drive the GMS and Revelstoke Unit 6 capacity additions.

1 **9.4 Contingency Resource Plans**

2 **9.4.1 Contingency Planning**

3 Contingency planning is done as a reliability management tool to manage the risk
4 (probability and consequence) of not being able to meet load by identifying
5 alternative sources of supply that should be available should the BRP not materialize
6 as expected. Contingency planning is part of good utility practice, and is a
7 component of long-term resource planning recognized as important in the BCUC
8 Resource Planning Guidelines.

9 As discussed in section 6.9.4.1, the key uncertainties that should be considered in
10 developing contingency plans are load forecast uncertainty, DSM deliverability risk,
11 and effective load carrying capability (**ELCC**) of clean or renewable intermittent
12 resources. However, as concluded in section 6.9.4.3, the range of uncertainty
13 captured by load forecast and DSM delivery uncertainties is considered sufficient to
14 cover the ELCC uncertainty for the purpose of contingency planning. Generation and
15 transmission capacity requirements are the primary concern since capacity is
16 required to meet peak load requirements and maintain system security and
17 reliability.

18 The process of creating CRPs involves the consideration of the risk that BC Hydro
19 would have an insufficient supply planned to meet its customers' needs and then
20 resolves how to meet those needs. This is done through the creation of alternative
21 portfolios of resources to meet the greater needs.

22 The aim of CRPs is not to build the required resources in the portfolios but to reduce
23 the lead time for supply-side resources and the required transmission to be placed
24 in- service if a need for them need arises. To minimize the costs of contingency plan
25 actions, BC Hydro seeks to maintain ISDs by moving resources through the
26 identification and definition phases of project development, incurring minimal costs
27 and without committing to construction. If at some point lead time is insufficient to
28 maintain the contingency resource and there is either a sufficiently high likelihood

1 the resource would be required or there is a high consequence of a supply shortage,
2 BC Hydro would secure regulatory approvals (BCUC and/or environmental-related),
3 as required, for its plan to construct the contingency resource initiating final
4 implementation.

5 BC Hydro submits CRPs to the BCUC for approval pursuant to the OATT and for the
6 purposes of establishing a queue position for a transmission service request. The
7 detailed BRP and CRP tables and graphs that would be the basis of the OATT
8 submission provided to transmission planning are shown in Appendix 8A. CRPs are
9 particularly important in light of the typically long lead times for transmission projects.
10 The CRPs submitted to the BCUC must consider scenarios that reasonably test the
11 transmission pathways that occur based on the possibility of resources and loads in
12 specific locations. Without transmission planning formally including the CRPs in its
13 planning processes and ensuring the associated transmission requirements are
14 being maintained, BC Hydro's CRPs would be ineffectual.

15 As set out above, BC Hydro developed two CRPs: CRP1 addresses contingencies
16 without Expected LNG load, and CRP2 addresses contingencies with Expected LNG
17 load.

18 BC Hydro undertakes CRP planning separately for Fort Nelson given that it is not
19 interconnected to the integrated system. The Fort Nelson resource requirements and
20 transmission supply are unique and separate requirements. The Recommended
21 Action related to the Fort Nelson CRP is shown in section [9.4.6](#).

22 The load forecast uncertainty (prior to LNG load) and DSM delivery uncertainty that
23 are addressed by both CRP1 and 2 are as shown in [Table 9-14](#).

1

Table 9-14 CRP Energy and Capacity Shortfalls

Uncertainty	Rationale	Capacity Shortfall ^{16,17} (MW)		Energy Shortfall (GWh/year)	
		F2017	F2033	F2017	F2033
General Load Forecast Uncertainty	Peak load and energy requirements can increase as a result of sustained growth and/or low temperatures at winter peak.	700	1,550	5,350	10,050
DSM Deliverability Uncertainty	The DSM target has a significant range of deliverability uncertainty where the variability is driven by implementation of codes and standards, customer response to programs and rates.	100	500	550	2,600
Total Reduction		800	2,050	5,900	12,650

2 The portfolios that were created for CRP1 and CRP2 are shown in sections [9.4.5](#)
 3 and [9.4.6](#), respectively.

4 The resulting actions of the two CRPs in terms of analysis for additional transmission
 5 requirements will be undertaken when the CRPs are approved by the BCUC and
 6 included in the network transmission plan. The generation-related actions driven by
 7 both CRPs are advancing Revelstoke Unit 6, GMS Units 1-5 Capacity Increase and
 8 natural gas-fired generation.

9 **9.4.2 Recommended Action 15: Advance Revelstoke Unit 6 Resource**
 10 **Smart project**

11 ***Advance the Revelstoke Generating Station Unit 6 Resource Smart project to***
 12 ***preserve its earliest in-service date of F2021 with the potential to add up to***
 13 ***500 MW of peak capacity.***

¹⁶ Section 6.9 discusses the ability of intermittent clean or renewable resources to impact the need for new capacity resources and concludes that they are only able to offset the need minimally.

¹⁷ Deliverability risk around DSM capacity savings has been factored into the CRPs. This was performed by examining high, medium and low capacity factor scenarios for the residential, commercial and industrial sectors. Refer to Appendix 4B for a further description.

1 With Expected LNG, BC Hydro would have up to a 650 MW capacity shortfall over
 2 the five-year period (F2019 to F2023) prior to Site C’s earliest ISD. Given the CEA
 3 self-sufficiency requirement and the uncertainty in load and DSM deliverability,
 4 BC Hydro proposes to advance Revelstoke Unit 6 through definition phase activity
 5 incurring limited costs. Any commitment to construct Revelstoke Unit 6 would be
 6 informed by the following: (1) the outcome of the Site C environmental assessment
 7 review; (2) LNG proponent final investment decisions; (3) the assessment of the role
 8 of natural gas-fired generation for LNG reliability requirements; (4) any future
 9 unexpected peak load growth; and (5) any unanticipated reductions in DSM
 10 deliveries.

11 Revelstoke Unit 6 would add 488 MW of long-term (50+ years) dependable capacity
 12 to the BC Hydro system, while also providing operational and ancillary services
 13 including system shaping, operating reserves, load following and rotational energy
 14 required to support intermittent resources. The direct capital cost of Revelstoke
 15 Unit 6, in May 2012 constant dollars, is \$340 million (\$420 million loaded). BC Hydro
 16 will spend up to \$7.2 million from F2014 to F2016 to ensure Revelstoke Unit 6 is
 17 available for its earliest ISD.

18 **9.4.2.1 Justification**

19 BC Hydro has two low-cost, clean or renewable capacity options – Revelstoke Unit 6
 20 and GMS Units 1-5 Capacity Increase:

21 **Table 9-15 Clean or Renewable Capacity Options**

Option	MW	ISD	UCC
Revelstoke Unit 6	488	F2021	\$50/kW-year
GMS Units 1-5 Capacity Increase	220	F2021-F2025 (one unit per year)	\$35/kW-year

22 BC Hydro proposes to advance both Revelstoke Unit 6 and GMS Units 1-5 Capacity
 23 Increase as CRP resources and decide at a later date which should be built first as
 24 the most cost-effective capacity option.

1 **Cost Effectiveness:** Revelstoke Unit 6 and GMS Units 1-5 Capacity Increase are
2 the two lowest cost capacity options. The cost comparison of all available capacity
3 resources is discussed in section 6.9.

4 **Environmental Attributes:** Revelstoke Unit 6 installation work will be contained
5 within the existing footprint of Revelstoke Generating Station (**Revelstoke GS**), and
6 therefore is expected to have minimal additional environmental impact.

7 **Policy Alignment:** Revelstoke Unit 6 does not emit GHGs, supports the *CEA*
8 93 per cent clean energy objective and meets the legislated self-sufficiency
9 requirement in subsection 6(2) of the *CEA*.

10 **9.4.2.2 Execution**

11 Revelstoke Unit 6 is currently in the identification phase with low development
12 uncertainty and medium cost uncertainty of +50 per cent/-15 per cent. BC Hydro
13 proposes to advance Revelstoke Unit 6 through definition phase using a staged and
14 flexible approach in order to limit costs. Cost mitigation activities include:

- 15 • Complete the process to obtain environmental approvals, including obtaining an
16 Environmental Assessment Certificate (**EAC**) under *BCEAA* and a water
17 licence to increase the maximum diversion rate by 3,000 cubic feet per second,
18 and related environmental studies
- 19 • Consultation with affected First Nations and stakeholders
- 20 • Undertaking preliminary design of the project and associated transmission
21 requirements
- 22 • Updating assessments of the benefits associated with Revelstoke Unit 6
- 23 • Initiation of a staged procurement process targeted for September 2014 with
24 the issuance of a Request for Statements of Qualifications

25 Business risks include the *BCEAA* review of Revelstoke Unit 6, stakeholder
26 engagement and First Nations consultation. Scope risk is limited since Revelstoke

1 Unit 6 is fairly well defined, is similar to Revelstoke Unit 5 that went into service in
2 December 2010 and is to be located at the existing Revelstoke GS. A capacitor
3 station is required on the 500 kV transmission line (5L98) between Vaseux Lake
4 Terminal Station and Nicola Substation to increase the capacity of the transmission
5 system in the B.C interior. While the capacitor station will serve all existing
6 generation in the southern interior of B.C., Revelstoke Unit 6 would advance the
7 need for the capacitor station by about 15 to 20 years under current planning
8 assumptions.

9 **9.4.2.3 Future Approval Process**

10 Pursuant to subsection 7(1)(c) of the *CEA*, BC Hydro is exempted from the CPCN
11 requirements of sections 45 to 47 of the *UCA*. On April 11, 2013, the EAO
12 determined that BC Hydro requires an EAC under *BCEAA*. Revelstoke Unit 6 does
13 not trigger *CEAA* because the Regulations Designating Physical Activities¹⁸ provide
14 that the trigger for expansions to a hydroelectric generating station is that the
15 expansion would result in an increase in installed production capacity of: (1)
16 50 per cent or more; and (2) 200 MW or more. Revelstoke Unit 6 does not result in
17 an increase of the installed capacity of Revelstoke GS of 50 per cent or more. The
18 installed capacity of the existing Revelstoke GS with the installation of Revelstoke
19 Unit 5 is about 2,480 MW.

20 **9.4.3 Recommended Action 16: Advance GM Shrum Resource Smart** 21 **Project**

22 ***Advance Resource Smart upgrades GM Shrum Generating Station Units 1-5***
23 ***with the potential to gradually add up to 220 MW of peak capacity starting in***
24 ***F2021.***

25 As part of its continuous review of opportunities to cost-effectively upgrade existing
26 hydroelectric generation stations, BC Hydro identified a potentially low cost capacity

¹⁸ SOR/2012-147, section 3(b).

1 opportunity at GMS, a capacity increase of Units 1-5. GMS Units 1-5 Capacity
2 Increase could provide about 220 MW of dependable capacity (about 44 MW per
3 unit). GMS is located next to the W.A.C. Bennett Dam on the Peace River. GMS is
4 one of BC Hydro's largest capacity generating stations (about 2,790 MW) and one of
5 the most important components of the integrated system. The GMS Units 1-5
6 Capacity Increase conceptual-level cost estimate (loaded) is about \$104 million.
7 F2015-F2016 capital spending on GMS Units 1-5 Capacity Increase is forecasted to
8 be between \$700,000 to \$800,000 to determine feasibility and other related
9 identification phase activities.

10 **9.4.3.1 Justification**

11 GMS Units 1-5 Capacity Increase potentially may have a lower UCC than
12 Revelstoke Unit 6:

- 13 • The UCC for GMS Units 1-5 Capacity Increase is estimated to be about
14 \$35/kW-year. This is based on a conceptual-level cost estimate with a range of
15 accuracy (+100 per cent/ -35 per cent).
- 16 • Revelstoke Unit 6 has a UCC of about \$50/kW-year

17 BC Hydro must balance the timing for the need for dependable capacity, costs, the
18 difficult scheduling and coordination issues if it were to implement GMS Units 1-5
19 Capacity Increase:

-
- 1 • There is extensive work underway and planned at GMS involving 11 different
2 projects¹⁹ on all 10 generating units which impacts when BC Hydro could
3 undertake GMS Units 1-5 Capacity Increase. It is not recommended from a
4 construction coordination, resourcing and safety perspective to implement an
5 additional Units 1-5 capacity increase project while this current capital work is
6 underway inside of this operating facility. These projects are expected to
7 complete around F2020.
- 8 • GMS Units 1-5 Capacity Increase could not realistically be started until the
9 11 GMS projects are largely concluded. The high volume of work and overlap of
10 projects at GMS pose an elevated safety and reliability risk in this operating
11 facility. This is a risk that is being managed through proper co-ordination of the
12 work.

13 If the GMS capacity increase opportunity is pursued in the future, the earliest the
14 additional capacity would be available is beginning in F2021 with the first unit
15 installation and be complete in F2025 with the last unit installation. During the
16 installation B.C. Hydro would need to consider how unit outages would impact
17 existing peak supply at GMS. These considerations have been reflected in the LRBs
18 in Chapter 9.

¹⁹ The eleven projects are: (1) GMS Unit Transformer Replacement Phase 3 Replacement of Unit 4 13.8 kV to 500 kV step-up transformers; (2) GMS Units 1 to 5 Turbine Replacement - this project includes new turbine runners, wicket gates, wicket gate operating mechanisms, head covers and overhauling remaining turbine components; (3) GMS Station Service Rehabilitation Generating station service providing power for plant controls, fire systems and all auxiliary system; (4) GMS Units 6 to 8 Capacity Increase Replacement of the iso-phase bus and unit circuit breaker on Units 6 to 8 to increase GMS capacity by 90 MW (30 MW per unit); (5) GMS Units 1 to 4 Rotor Pole Rehabilitation of original (1968) rotor winding; (6) GMS Fire Alarm System Replacement of system in this underground generating station; (7) GMS Fire Protection Piping Replacement; (8) GMS Generator Monitoring System Installation Monitoring system to reduce the risk of turbine or generator failures by providing advanced warning. This project includes vibration monitoring (Units 6 to 10), shear pin monitoring (Units 6 to 10), rotor to stator air gap monitoring (Units 5 to 10) and on-line partial discharge activity monitoring (Units 1 to 10); (9) GMS Unit 7 and 8 Exciter Transformer Replacement - Replace the exciter transformers with transformers of a modified design; (10) GMS Units 6 to 10 Governor Control Replacement - Replace the governor controls with a modern, standardized control system; and (11) GMS Units 1 to 10 Control System Upgrade - Replace controls, alarms, and metering to provide automation and significantly enhanced troubleshooting capability.

1 **9.4.3.2 Execution**

2 BC Hydro will continue to review both Revelstoke Unit 6 and GMS Units 1-5
3 Capacity Increase. BC Hydro proposes to advance GMS Units 1-5 Capacity
4 Increase through identification and definition phase activity using a staged and
5 flexible approach to incur minimal costs. A schedule for GMS Units 1-5 Capacity
6 Increase project could be as follows:

- 7 • Identification phase: one-year minimum
- 8 • Definition phase: two-and-a-half-year minimum: GMS Units 1-5 Capacity
9 Increase likely triggers *BCEAA*, and BC Hydro would apply for a CPCN from
10 the BCUC. A new water license may be required due to the current diversion
11 limit at GMS, and an addendum to Peace River Water Use Plan may be
12 required.
- 13 • Implementation phase: approximately five years, with one unit being placed in
14 service each year
- 15 • If the project was initiated in F2016, GMS Units 1-5 Capacity Increase
16 construction would be timed to begin with the completion of the current projects
17 and could be fully in-service by F2025

18 **9.4.3.3 Future Approval Process**

19 Pursuant to BC Hydro's Capital Project Filing Guidelines, BC Hydro would apply for
20 a CPCN from the BCUC pursuant to subsection 46(1) of the *UCA* if project cost is
21 greater than \$100 million. BC Hydro may require an EAC pursuant to *BCEAA* as the
22 threshold for modifications to an existing hydroelectric facility is an increase in the
23 nameplate capacity of 50 MW or greater.²⁰ However, BC Hydro received a
24 section 10(1)(b) *BCEAA* determination that no EAC was required for GMS Units 6-8
25 Capacity Increase Project, which has a scope similar to GMS Capacity Increase. An

²⁰ Table 7, Column 1 of the B.C. Reviewable Projects Regulation, B.C. Reg. 370/2002.

1 additional water license may be required. GMS Units 1-5 Capacity Increase does not
2 trigger CEAA because the *Regulations Designating Physical Activities* provide that
3 the trigger for expansions to a hydroelectric generating station is that the expansion
4 would result in an increase in production capacity of: (1) 50 per cent or more; and (2)
5 200 MW or more. GMS Units 1-5 Capacity Increase does not result in an increase of
6 the production capacity of GMS of 50 per cent or more. The production capacity of
7 the existing GMS is 2,790 MW.

8 **9.4.4 Recommended Action 17: Investigate natural gas-fired generation** 9 **for capacity**

10 ***Working with industry, explore natural gas supply options to reduce their***
11 ***potential lead time to in-service and to develop an understanding of where and***
12 ***how to site such resources, should they be needed.***

13 This Recommended Action entails undertaking work to develop natural gas-fired
14 contingency options that focus on reducing the lead time to ISDs and an
15 understanding of where and how to site natural gas-fired generation in the province.
16 Working with IPPs, this will involve identifying and exploring specific natural gas-fired
17 capacity options and procurement processes, should they be needed.

18 **9.4.4.1 Justification**

19 Natural gas-fired generation is the default incremental capacity resource when no
20 other cost-effective capacity resources are available. Refer to section 6.9.

21 **9.4.4.2 Execution**

22 BC Hydro will explore and develop a shelf-ready competitive procurement process to
23 select new natural gas-fired generation projects in B.C. This work will occur in
24 advance of any commercial commitments and BC Hydro will focus activities on the
25 analysis and resolution of key development risks, and commercial and process
26 issues, to develop a credible procurement framework that could be quickly activated
27 if loads occur. BC Hydro will review other North American jurisdictions where natural
28 gas-fired capacity procurements have occurred in the last five years. The potential

1 procurement process is targeted to be completed in F2014 to ensure this option to
2 serve future loads, if they occur.

3 Some of the key considerations for analysis and design of the potential procurement
4 will be: First Nations engagement and consultation; siting; access to fuel; optimal
5 allocation risks; desired operational characteristics; required project viability;
6 developer strength; ensuring cost-effective pricing; treatment of associated energy;
7 necessary lead times; and potential transmission investments.

8 Given that little to no greenfield natural gas-fired generation project development
9 work has occurred in B.C. for the last 10 years, there are significant components in
10 siting and development of such facilities that need to be scoped. Depending on the
11 required lead times, BC Hydro may need to initiate procurement in F2015 to
12 maintain new natural gas-fired generation projects as a credible option. This could
13 involve BC Hydro developing and implementing a competitive process to enter into
14 an agreement with one or more developers to evaluate feasibility, undertake various
15 studies (such as geotechnical or environmental), undertake feasibility-level design
16 and engineering work and develop a schedule and budget for the development of
17 potential specific gas projects. Given that the work may occur in advance of any load
18 commitments, BC Hydro will be looking to sharing some of the cost of the work.

19 The risks for this Recommended Action are:

- 20 • The contingency capacity option is not maintained and BC Hydro is unable to
21 meet future load. To ensure that these resource options are available,
22 BC Hydro is committing adequate funds and effort to advance the
23 plans/options. BC Hydro will engage IPPs early in the process to ensure
24 realistic options are being developed.
- 25 • BC Hydro incurs significant costs to advance these options and they are not
26 required. To minimize the cost risk, BC Hydro will seek to find a way to risk
27 share with IPPs to develop the resources to a shelf-ready status and avoid
28 committing to major expenditures prior to need being confirmed. BC Hydro

1 would also implement clear commercial terms that provide a framework for
2 BC Hydro to defer or discontinue further activities with proponents and projects
3 if new emerging loads are deferred or do not proceed. Committing in advance
4 to project development regardless of viability, price or other terms is not in the
5 interest of ratepayers.

6 **9.4.4.3 Future Approval Process**

7 No approvals are required to explore natural gas-fired generation options and siting.
8 If BC Hydro enters into any EPAs, the contracts would be filed with the BCUC under
9 section 71 of the *UCA*. Individual natural gas-fired generation projects will likely
10 trigger *BCEAA* as the threshold is a nameplate capacity of 50 MW or greater,²¹ and
11 will require air emission permits pursuant to the B.C. *Environmental Management*
12 *Act*.²²

13 **9.4.5 CRP1**


14 CRP1 results in the portfolio shown in [Figure 9-7](#) and [Figure 9-8](#).

²¹ *Ibid.* Table 7, Column 2.

²² S.B.C. 2003, c.53.


1

Figure 9-7 Energy LRB for CRP1



2

Figure 9-8 Capacity LRB for CRP1



* including planning reserve requirements


1 CRP1 shows how BC Hydro would plan to supply a high need for new resources.
 2 BC Hydro’s main concern is to ensure adequate capacity is available to meet peak
 3 load requirements and to back up other generator-forced outages. As discussed in
 4 section 6.9, the lowest-cost capacity resources include Revelstoke Unit 6, GMS
 5 Units 1-5 Capacity Increase and SCGTs; these resources are built into CRP1. If the
 6 higher gap occurs over a short time frame, it is likely that some gas-fired generation
 7 would be required along with some market reliance.

8 While energy supply shortfalls are a lesser concern than capacity from a reliability
 9 perspective, CRP1 would likely drive the need to advance up to about 7,000
 10 GWh/year of clean energy acquisitions by F2023 in order to adhere to the CEA’s
 11 energy self-sufficiency objective.

12 **9.4.6 CRP2**


13 CRP2 adds Expected LNG to the loads that need to be supplied. The resulting
 14 portfolio that BC Hydro would plan to build is shown in [Figure 9-9](#) and [Figure 9-10](#).

15 **Figure 9-9 Energy LRB for CRP2**



1

Figure 9-10 Capacity LRB for CRP2



* including planning reserve requirements

2 The preceding CRP2 graphs show that generally more natural gas-fired generation
 3 is required. The rationale for CRP2 is to highlight and drive the incremental
 4 transmission resources that would be required for the Expected LNG case.
 5 BC Hydro contemplated having a scenario with both high LNG and non-LNG load;
 6 however, the analysis done in Chapter 6 on the North Coast region suggested that it
 7 would be unlikely that a second 500 kV transmission line would be required. Rather,
 8 it is anticipated that additional LNG would be supported by natural gas-fired
 9 generation on the North Coast.

10 **9.4.7 Recommended Action 18: Investigate Fort Nelson area supply**
 11 **options**

12 ***Investigate procurement options to serve future Fort Nelson load.***

13 Recommended Action 13 addresses electrification of the larger Horn River Basin,
 14 which would include the Fort Nelson region. In the absence of clarity on HRB

1 electrification, BC Hydro must continue to be prepared to supply loads in the Fort
2 Nelson region as described in Chapter 2.

3 BC Hydro recommends that it continue to address the Fort Nelson area
4 requirements in the following fashion:

- 5 • BC Hydro will maintain N-1 level of service to the Fort Nelson area over the
6 long term. With that in mind, and in light of load forecast uncertainties,
7 BC Hydro will avoid new supply commitments until load growth signals become
8 more certain.
- 9 • As a bridging strategy, and to the extent that relatively sizeable industrial loads
10 materialize earlier than expected, BC Hydro will provide interruptible (N-0)
11 service to such loads on a temporary basis until such time as N-1 service
12 becomes available. BC Hydro would be able to serve up to 112 MW of load with
13 combined Fort Nelson Generating Station (**FNG**) and Alberta supply on an
14 interruptible (N-0) basis.
- 15 • BC Hydro will continue to monitor Fort Nelson area load growth including
16 signposts for load developments and on-the-ground market intelligence
- 17 • BC Hydro will continue to investigate and engage in actions concerning the
18 range of potential supply options, including implementation in collaboration with
19 Alberta of a Fort Nelson Load Shedding Remedial Action Scheme (**LSRAS**)
20 and assessment of local natural gas-fired generation options to meet the range
21 of forecast capacity shortfall

22 **9.4.7.1 Justification**

23 In the mid load scenario, the load is expected to grow from its current level of about
24 30 MW (as measured by winter peak capacity) to about 43 MW by F2020 reaching
25 the N-1 threshold for planning purposes by about F2018 or F2019.

26 While BC Hydro expects load growth to be modest over the next five years
27 (F2014- F2018), there are significant uncertainties to the forecast due to potential

1 impacts from HRB development and/or other unexpected load developments. These
2 uncertainties could defer the expected capacity shortfall to beyond F2018, or cause
3 the shortfall to occur earlier than F2018.

4 Given the substantial near-term load forecast uncertainties, BC Hydro is not willing
5 to make a significant investment commitment at this point. BC Hydro is taking
6 actions to address these uncertainties and set the stage for longer-term planning
7 actions as well, without losing sight of natural gas industry and HRB developments.
8 These actions will include the close monitoring of Fort Nelson area load in order to
9 reflect these changes into its load forecast and its servicing plans.

10 **9.4.7.2 Execution**

11 Key activities include:

- 12 • In collaboration with the Alberta Electric System Operator (**AESO**) and ATCO
13 Power, complete in F2014 design and implementation of Fort Nelson LSRAS
14 that will allow BC Hydro to serve increased load on an interruptible basis until
15 additional supply is added. Estimated Cost: \$2 million
- 16 • BC Hydro will refine the assessment of identified options to meet the range of
17 forecast capacity shortfall, including the option of expanding the existing FNG
18 by adding a second unit. Resource requirements will be primarily for staff time
19 and potential for external consulting support in the range of \$50,000 to
20 \$100,000.

21 **9.4.7.3 Future Approval Process**

22 No material regulatory approval processes are envisioned at this time given the
23 scope of the Recommended Action.

24 The near-term costs associated with the Recommended Actions to correspond to
25 the LRBs in the CRPs are outlined in [Table 9-16](#).

1
2

Table 9-16 F2014 to F2016 CRPs Recommended Action Execution Expenditure

Recommended Action		Near-Term Execution Expenditure (in \$F2013)			
		Applicability	F2014	F2015	F2016
Supply-Side Resources	15. Advance Revelstoke Unit 6 Resource Smart project	To ensure in-service date availability	\$2.4 million	\$2.4 million	\$2.4 million
	16. Advance GM Shrum Resource Smart project	To determine Identification Phase feasibility	N/A	Up to \$0.4 million	Up to \$0.4 million
	17. Investigate natural gas-fired generation for capacity	N/A			
Other	18. Investigate Fort Nelson area supply options	To assess options to meet forecast capacity shortfall	\$50,000 to \$100,000		

3 **9.4.8 Transmission Contingency Plans**

4 The TCPs are intended to address the key transmission shortages that impact
5 BC Hydro’s resource plans. As demonstrated in section 6.8.6, there do not appear to
6 be any bulk transmission regions that would cause BC Hydro supply concerns over
7 the next 10 years.

8 **9.5 Additional IRP Recommendations**

9 **9.5.1 Province-Wide Electrification/GHG Reduction Initiatives**

10 Aside from the strategic planning electrification actions in support of the Clean
11 Energy Strategy, as outlined in Recommended Action 10, section [9.2.12](#); section 6.7
12 also addresses the potential implications of the CEA GHG-related objectives that
13 could drive general electrification across the economy, in end-uses such as space
14 and water heating, passenger and freight vehicles, and industrial equipment (e.g.,
15 large compressors).

16 The potential costs and impacts of general electrification would be significant.
17 BC Hydro will undertake preparatory actions and incur low costs:

-
- 1 • Continue to provide analysis and support to the B.C. Government to identify
2 where electrification would be expected to occur in response to climate policy
 - 3 • Continue distribution system studies and related activities, in conjunction with
4 smart meters and smart grid implementation, to ensure that BC Hydro's
5 transmission and distribution infrastructure is able to supply the increased loads
6 (e.g., electric vehicles, heat pumps, distributed generation, load curtailment)
7 that could result from significant electrification

8 BC Hydro's ongoing efforts to monitor provincial, national and international climate
9 policy developments and analyze potential system demand will facilitate responding
10 to potential future policy-driven electrification initiatives.

11 **9.5.2 Export Market Analysis**

12 Section 5.8 of this IRP provides an analysis of potential export market opportunities.
13 The key conclusion is that market conditions do not justify the development of new,
14 additional clean or renewable resources for the export market. Since the conditions
15 underpinning these market dynamics are expected to persist for the foreseeable
16 future, BC Hydro anticipates no incremental expenditures for export but will continue
17 to monitor the export markets for future opportunities.

18 **9.5.3 Transmission Planning for Generation Clusters**

19 In section 6.9, the IRP evaluated the nine regions in B.C. that had the highest
20 resource clean or renewable generation density (generation clusters) that may
21 benefit from the pre-building of new bulk transmission to result in a more
22 cost-effective transmission system development with a reduced environmental
23 footprint. The analysis pointed to the potential to somewhat reduce environmental
24 footprints as a result of optimal transmission configurations. However, there is only a
25 marginal financial benefit associated with developing clusters to meet customer
26 demand. In addition, there is a significant uncertainty over which resource options
27 will ultimately be developed. As such, BC Hydro will consider transmission

1 advancement for generation clusters during power acquisition processes when
2 projects in these cluster regions are being bid.

3 **9.5.4 IRP Submission Cycle and Amendments**

4 Subsection 3(6)(b) of the *CEA* provides that subsequent IRPs must be submitted
5 every five years after submission of this first IRP unless a submission date is
6 prescribed by LGIC regulation. The submission date for the next IRP is August 2018
7 in the absence of such a regulation.

8 Subsection 3(7) of the *CEA* enables BC Hydro to submit an amendment to an
9 approved IRP. BC Hydro plans to review the IRP in the fall of 2015, at which time
10 BC Hydro expects to have further information concerning, among other things: (1)
11 DSM delivery including any CPR results; (2) EPA renewal pricing and volumes; (3)
12 an environmental assessment decision concerning Site C from the B.C. Ministers of
13 Environment and of Forests, Lands and Natural Resource Operations, and the
14 federal Minister of Environment; and (4) LNG proponent decisions to take service
15 from BC Hydro and/or final investment decisions. A decision to submit an
16 amendment prior to the next IRP will depend on the outcome of this review, which
17 BC Hydro plans on sharing with interested parties including IRP Technical Advisory
18 Committee members, First Nations and the public.