



## **Operational Planning Study Report**

### **RTA to BCH transfer limit updates For Kitimat 4 Capacitor Banks**

**Report No. T&S Planning 2013 - 062**

**British Columbia Hydro and Power Authority**

© British Columbia Hydro and Power Authority 2013. All rights reserved.

Prepared by: **Jun Lu**  
Senior Engineer, Performance Planning, BC Hydro

October 16, 2013  
Date

Approved by: **Guihua Wang**  
Manager, Performance Planning, BC Hydro

October 16, 2013  
Date

## **DISCLAIMER OF WARRANTY, LIMITATION OF LIABILITY**

This report was prepared by BC HYDRO solely for the purposes described in this report, and is based on information available to BC HYDRO as of the date of this report. Accordingly, this report is suitable only for such purposes, and is subject to any changes arising after the date of this report.

Unless otherwise expressly agreed by BC HYDRO, BC HYDRO does not represent or warrant the accuracy, completeness or usefulness of this report, or any information contained in this report, for use or consideration by any third party, nor does BC HYDRO accept any liability out of reliance by a third party on this report, or any information contained in this report, or for any errors or omissions in this report. Any use or reliance by third parties is at their own risk.

## **COPYRIGHT NOTICE**

Copyright and all other intellectual property rights are expressly reserved to BC HYDRO. Without prior written approval of BC HYDRO, no part of this report shall be reproduced or distributed in any manner or form whatsoever.

## **Executive Summary**

Rio Tinto Alcan (RTA) has requested BCH Transmission Planning to conduct operation planning study to update RTA to BCH transfer limits for KIT 4 shunt capacitor bank scenario.

Study results indicated that, RTA to BCH transfer limits from transient performance perspective, with KIT 4 shunt capacitor banks, can be increased to higher numbers which are similar to the scenario with KIT 5 shunt capacitor banks. The current transfer limits containing in the BC Hydro's operating order 7T-30 (issued on March 21, 2012) were estimated based on a conservative approach.

Detailed study results are summarized in Appendix A and will be used for updating operating order 7T-30.

## Table of Contents

|   |          |
|---|----------|
| <b>1. BACKGROUND</b> .....  | <b>1</b> |
| <b>2. STUDY CONDITIONS AND ASSUMPTIONS</b> .....  | <b>1</b> |
| <b>3. STUDY CRITERIA</b> .....  | <b>2</b> |
| <b>4. STUDY RESULTS</b> .....   | <b>2</b> |
| <b>APPENDIX A: RTA TO BCH TRANSFER LIMITS</b> .....   | <b>3</b> |
| Table A - 1 RTA to BCH Transfer limits (with separation scheme at KIT).....                   | 4        |
| Table A - 2 Calculation formulas for Parameters A and B (with separation scheme at KIT) ..... | 4        |

## 1. Background

RTA has requested BCH to conduct operational planning study to update RTA to BCH transfer limits for 4 shunt capacitor bank scenario under system normal conditions due to:

### (1) Changes in RTA System

- The shunt capacitor associated with potline 8 has de-rated to 36.8 MVAR from 55 MVAR when potline 8 was shutdown, around August 2010.
- The shunt capacitor associated with Potline 2 was blown out in April 2013, and may not be available in the future.

### (2) Deficiency in existing OO 7T-30

- RTA to BCH transfer limits for the case of 4 shunt capacitor banks in service under system normal condition were not studied. The transfers in 7T-30 were estimated based on a conservative approach and very restrictive.

## 2. Study Conditions and Assumptions

The studies are conducted based on the following conditions and assumptions:

- Base case: Bulk system 2013 light summer base case
- North Coast region system normal – All major transmission system equipment in service
- 5 shunt capacitor banks available while one bank maybe out of service at KIT
- Three generation patterns at KMO:
  - 8 units with a total maximum generation of 880 MW,
  - 7 units with a total maximum generation of 840 MW,
  - 6 units with a total maximum generation of 720 MW.
- KIT load range from 302 MW to 480 MW
- MIN load range from 0 MW to 50 MW
- KIT Separation Scheme in service
- Out-of-step Protection on 2L103 (KIT-MIN) in service

### 3. Study Criteria

- Separation Scheme Protection  
The separation scheme consists of two relays installed by RTA at KIT to detect multi-phase faults in the RTA system and in the BCH system. If either relay detects a multi-phase fault, then the KIT to MIN line 2L103 will be tripped immediately.
- Out-of-Step protection  
The MIN terminal of 2L103 is equipped with an Out-of-Step relay that will detect power swings between the KMO generators and the BCH system, and the MIN Out-of-Step settings are as follows:

| Protection        | Settings  |
|-------------------|---|
| Out-of-Step Relay | Apparent impedance looking from MIN to KIT: 0.18 – 0.16 p.u.<br>Apparent impedance looking from MIN to SKA: 0.18 – 0.16 p.u.<br>Apparent impedance crossing I 0.18 – 0.16 I gap time: 2 cycles<br><br>Supervision voltage: 0.85p.u.<br>Supervision voltage delay time: 5 cycles |

The transfer limits and KMO generations shedding requirement are based on the Out-of-Step Relay setting as that the system performance in MIN area is protected.

### 4. Study Results

Study results indicate that

- From transient stability performance perspective with 4 shunt capacitor banks in service at KIT, RTA to BCH transfer limits can be increased to higher numbers, close to the case with 5 banks in service at KIT.
- In some situations, 4 capacitor banks at KIT would have better transient performance than 5 shunt capacitor banks due to the reduced KIT load (range between 302 MW to 480 MW) has reduced shunt compensation requirement, with 4 shunt capacitors in service would result in higher KMO unit terminal voltages to maintain KIT 287 kV bus voltage at 1.0 pu. As a result, KMO units have better transient performance.
- The existing generation shedding requirements for contingency of 2L101 (SKA to RUP) are still applicable for the new cases with 4 capacitor banks in service at KIT.

Detailed study results are summarized in Appendix A. Nomogram A-1 to A-3 are the updated RTA-BCH transfer limits

## Appendix A: RTA to BCH Transfer Limits

The RTA to BCH transfer limit, with separation scheme at KIT, for system normal condition and one of Kemano - Kitimat lines OOS is defined as:

a) With RTA 420 GS RAS in-service:

PT (P\_2L103) is the lesser of

- 420 MW, or
- 2L103 Rating , or
- $(A + B * L_{MIN})$

b) With RTA 420 GS RAS OOS:

PT (P\_2L103) is the lesser of

- 420 MW, or
- Lesser of (2L103 Rating , 495 MW) - Largest Potline Load, or
- $(A + B * L_{MIN})$

Where Parameters A and B depend on  $L_{KIT}$  and are calculated in Table A -2.

### Notes:

1. RTA 420 GS RAS is a RAS scheme implemented by RTA to avoid 2L103 from thermal overload, or from tripping by the excessive power relay on the loss of one of the Potlines at KIT (35 -100 MW) when KIT is connected to the BC Hydro system.
2.  $L_{KIT}$  is defined as the net power difference between power flowing into KIT on 87L (KMO-KIT) and 88L (KMO-KIT) and power going out of KIT on 2L103
  - $L_{KIT}$  is assumed to vary between 302 to 480 MW.
  - If  $L_{KIT} < 302$  MW, set  $L_{KIT} = 302$  MW.
  - If  $L_{KIT} > 480$  MW, the results are not applicable.
3.  $L_{MIN}$  is defined as the net power difference between power flowing into MIN on 2L103 and power going out of MIN on 2L99
  - $L_{MIN}$  is assumed to vary between 0 to 50 MW.



**Table A - 1 RTA to BCH Transfer limits (with separation scheme at KIT)**


| System Condition                              | Case Number | Number of Kitimat Capacitor Banks In-Service | Number of Kemano Units Online | Kitimat Load $L_{KIT}$ (MW) | Kitimat to Minette Transfer Limit $P_T$ (= $P_{2L103}$ ) range (MW) | Comments |
|---|-------------|--|-------------------------------|-----------------------------|---|----------|
| System Normal (with separation scheme at KIT) | 1           | 4  | 8                             | $302 < L_{KIT} \leq 440$    | 420 MW  |          |
|   |             |  |                               | $440 < L_{KIT} \leq 480$    | 380 MW ~ 420 MW   |          |
|   | 2           | 4  | 7                             | $302 < L_{KIT} \leq 318$    | 420 MW  |          |
|   |             |  |                               | $318 < L_{KIT} \leq 379$    | 380 MW ~ 420 MW   |          |
|   |             |  |                               | $379 < L_{KIT} \leq 420$    | 370 MW ~ 380 MW   |          |
|   |             |  |                               | $420 < L_{KIT} \leq 440$    | 350 MW ~ 370 MW   |          |
|   |             |  |                               | $440 < L_{KIT} \leq 480$    | 310 MW ~ 350 MW   |          |
|   | 3           | 4  | 6                             | $302 < L_{KIT} \leq 318$    | 380 MW ~ 395 MW   |          |
|   |             |  |                               | $318 < L_{KIT} \leq 348$    | 330 MW ~ 380 MW   |          |
|   |             |  |                               | $348 < L_{KIT} \leq 379$    | 310 MW ~ 330 MW   |          |
|   |             |  |                               | $379 < L_{KIT} \leq 420$    | 280 MW ~ 310 MW   |          |
|   |             |  |                               | $420 < L_{KIT} \leq 440$    | 260 MW ~ 280 MW   |          |
|   |             |  |                               | $440 < L_{KIT} \leq 480$    | 225 MW ~ 260 MW   |          |

**Table A - 2 Calculation formulas for Parameters A and B (with separation scheme at KIT)**

| System Condition                              | Number of Kitimat Capacitor Banks In-Service | Number of Kemano Units Online | Kitimat Load $L_{KIT}$ (MW)             | Calculation Formulas for A and B        |                                     |
|---|--|-------------------------------|---|---|-------------------------------------|
| System Normal (with separation scheme at KIT) | 4  | 8                             | $302 < L_{KIT} \leq 440$                | $A = 420$                               | $B = 0.0$                           |
|   |  |                               | $440 < L_{KIT} \leq 480$                | $A = 420 - 1.0 \times (L_{KIT} - 440)$  | $B = 0.0$                           |
|   | 4  | 7                             | $302 < L_{KIT} \leq 318$                | $A = 420$                               | $B = 0.0$                           |
|   |  |                               | $318 < L_{KIT} \leq 379$                | $A = 420 - 0.66 \times (L_{KIT} - 318)$ | $B = 0.0 - 0.8 \times (A - 420)/40$ |
|   |  |                               | $379 < L_{KIT} \leq 420$                | $A = 380 - 0.24 \times (L_{KIT} - 379)$ | $B = 0.8 + 0.6 \times (A - 380)/10$ |
|   |  |                               | $420 < L_{KIT} \leq 440$                | $A = 370 - 1.0 \times (L_{KIT} - 420)$  | $B = 0.2$                           |
|   |  |                               | $440 < L_{KIT} \leq 480$                | $A = 350 - 1.0 \times (L_{KIT} - 440)$  | $B = 0.2 + 0.2 \times (A - 350)/40$ |
|   | 4  | 6                             | $302 < L_{KIT} \leq 318$                | $A = 395 - 1.0 \times (L_{KIT} - 303)$  | $B = 0.0$                           |
|   |  |                               | $318 < L_{KIT} \leq 348$                | $A = 380 - 1.67 \times (L_{KIT} - 318)$ | $B = 0.0 - 0.4 \times (A - 380)/50$ |
|   |  |                               | $348 < L_{KIT} \leq 379$                | $A = 330 - 0.65 \times (L_{KIT} - 348)$ | $B = 0.4 + 0.1 \times (A - 330)/20$ |
|   |  |                               | $379 < L_{KIT} \leq 420$                | $A = 310 - 0.73 \times (L_{KIT} - 379)$ | $B = 0.3 + 0.3 \times (A - 310)/30$ |
|   |  |                               | $420 < L_{KIT} \leq 440$                | $A = 280 - 1.0 \times (L_{KIT} - 420)$  | $B = 0.0$                           |
| $440 < L_{KIT} \leq 480$                      |  |                               | $A = 260 - 0.88 \times (L_{KIT} - 440)$ | $B = 0.0$                               |                                     |

### Nomogram A-1


#### RTA to BCH Transfer limit Under system normal condition with 8 units at KMO and 4 capacitor banks at KIT



- Limited by maximum allowable real power over 2L103
- Limited by acceptable transient performance or KMO reactive power reserves

**Nomogram A-2**


**RTA to BCH Transfer limit  
 Under system normal condition with 7 units at KMO and 4 capacitor banks at KIT**



- Limited by maximum allowable real power over 2L103
- Limited by acceptable transient performance or KMO reactive power reserves

**Nomogram A-3**

**RTA to BCH Transfer limit  
 Under system normal condition with 6 units at KMO and 4 capacitor banks at KIT**



- Limited by maximum allowable real power over 2L103
- Limited by acceptable transient performance or KMO reactive power reserves