

Forced Outage Indices For 230 and 138 kV Bus Sections and T4 of CKY Substation
(Based on outage data from Jan. 1, 1999 to Dec. 31, 2008)

Note: No outages are found in the database for those unlisted feeder bus sections.

Bus name	Number of Forced Sustained Outages	Failure Frequency	Total Outage Duration (hrs)	Average Duration/per failure	Unavailability %
CKY 2B1	0	0.0	0.00	0.00	0.0000
CKY 2B2	0	0.0	0.00	0.00	0.0000
CKY 2B3	0	0.0	0.00	0.00	0.0000
CKY 2B4	1	0.1	0.00	0.00	0.0000
CKY 2B6	0	0.0	0.00	0.00	0.0000
CKY 2B8	0	0.0	0.00	0.00	0.0000
CKY 2B9	1	0.1	2.26	2.26	0.0026
CKY 2B10	0	0.0	0.00	0.00	0.0000
CKY 2B20	0	0.0	0.00	0.00	0.0000
CKY 1B2	0	0.0	0.00	0.00	0.0000
CKY T4	3	0.3	413.50	137.83	0.4720

Disclaimer:

BRITISH COLUMBIA TRANSMISSION CORPORATION (“BCTC”) MAKES NO WARRANTIES, EXPRESS OR IMPLIED, WHETHER ARISING BY OPERATION OF LAW, COURSE OF PERFORMANCE OR DEALING, CUSTOM, USAGE IN THE TRADE OR PROFESSION, OR OTHERWISE, INCLUDING WITHOUT IMITATION WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE WITH REGARD TO ACCURACY, CONTENT, OBSERVATIONS OR CONCLUSIONS.

Any use of this note, and any interpretations, opinions, conclusions, decisions or assumptions reached or made based on or in reliance on, in whole or in part, on this note, is solely at the risk of the party making such use, without recourse to BCTC or its directors, officers, employees or agents. In no event will BCTC or its directors, officers, employees or agents be liable for any damage, injury or loss that is in any way connected to this note including without limitation any indirect, special, incidental, punitive or consequential damages of any kind including loss of revenue, loss of profit or cost of capital.