

Due to a Third Party Request the following data has been posted on July 10, 2008
 Forced Outage Indices For Feeder Bus Sections and Substations of CSQ, SPG, MUR and MAN
 (Based on outage data from Jan. 1, 1998 to Dec. 31, 2007)

Note: No outages are found in the database for those unlisted feeder bus sections.

Bus name	Number of Forced Sustained Outages	Failure Frequency	Total Outage Duration (hrs)	Average Duration/per failure	Unavailability %
CSQ 12B102	1	0.1	1.18	1.18	0.0014
CSQ 12B61	1	0.1	0.43	0.43	0.0005
CSQ 12B62	2	0.2	1.32	0.66	0.0015
CSQ Substation	1	0.1	2.43	2.43	0.0028
Bus name	Number of Forced Sustained Outages	Failure Frequency	Total Outage Duration (hrs)	Average Duration/per failure	Unavailability %
SPG 12B111	3	0.3	1.87	0.62	0.0021
SPG 12B112	2	0.2	0.62	0.31	0.0007
SPG 12B31	1	0.1	0.02	0.02	0.0000
SPG 12B33	1	0.1	1.03	1.03	0.0012
SPG 12B41	3	0.3	1.57	0.52	0.0018
SPG 12B43	1	0.1	0.57	0.57	0.0006
SPG Substation	1	0.1	0.03	0.03	0.0000
Bus name	Number of Forced Sustained Outages	Failure Frequency	Total Outage Duration (hrs)	Average Duration/per failure	Unavailability %
MUR 12B2 & 12B37	1	0.1	2.20	2.20	0.0025
MUR 12B34	1	0.1	0.02	0.02	0.0000
MUR 12B5 & 12B57	1	0.1	1.00	1.00	0.0011
MUR 4B50	1	0.1	0.02	0.02	0.0000
MUR Substation	1	0.1	0.77	0.77	0.0009
Bus name	Number of Forced Sustained Outages	Failure Frequency	Total Outage Duration (hrs)	Average Duration/per failure	Unavailability %
MAN 12B28 & 12B58	3	0.3	0.87	0.29	0.0010
MAN 12B31 & 12B41	2	0.2	0.68	0.34	0.0008
MAN 12B9	1	0.1	0.48	0.48	0.0006
MAN Substation	1	0.1	0.30	0.30	0.0003

CSQ = Cathedral Square Substation

SPG = Sperling Substation

MUR = Murrin Substation

MAN = Mainwaring Substation

Disclaimer:

BRITISH COLUMBIA TRANSMISSION CORPORATION ("BCTC") MAKES NO

WARRANTIES, EXPRESS OR IMPLIED, WHETHER ARISING BY OPERATION OF LAW, COURSE OF PERFORMANCE OR DEALING, CUSTOM, USAGE IN THE TRADE OR PROFESSION, OR OTHERWISE, INCLUDING WITHOUT IMITATION WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE WITH REGARD TO ACCURACY, CONTENT, OBSERVATIONS OR CONCLUSIONS.

Any use of this note, and any interpretations, opinions, conclusions, decisions or assumptions reached or made based on or in reliance on, in whole or in part, on this note, is solely at the risk of the party making such use, without recourse to BCTC or its directors, officers, employees or agents. In no event will BCTC or its directors, officers, employees or agents be liable for any damage, injury or loss that is in any way connected to this note including without limitation any indirect, special, incidental, punitive or consequential damages of any kind including loss of revenue, loss of profit or cost of capital.