

Total Fault Rate of KI1 Substation and Connected 60 kV Transmission Lines

At the requests of third parties, BCTC was asked to provide forced outage data for KI1 and connected 60 kV transmission lines.

Base on the last ten years' reliability data up to December 31, 2006, totally 60 faults occurred on the equipment in KI1 substation and connected 60 kV transmission lines. The fault rate is 6 per year. The 60 faults include phase to ground and also phase to phase contingences due to lack of information to separate them.

Disclaimer:

BRITISH COLUMBIA TRANSMISSION CORPORATION ("BCTC") MAKES NO WARRANTIES, EXPRESS OR IMPLIED, WHETHER ARISING BY OPERATION OF LAW, COURSE OF PERFORMANCE OR DEALING, CUSTOM, USAGE IN THE TRADE OR PROFESSION, OR OTHERWISE, INCLUDING WITHOUT IMITATION WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE WITH REGARD TO ACCURACY, CONTENT, OBSERVATIONS OR CONCLUSIONS.

Any use of this note, and any interpretations, opinions, conclusions, decisions or assumptions reached or made based on or in reliance on, in whole or in part, on this note, is solely at the risk of the party making such use, without recourse to BCTC or its directors, officers, employees or agents. In no event will BCTC or its directors, officers, employees or agents be liable for any damage, injury or loss that is in any way connected to this note including without limitation any indirect, special, incidental, punitive or consequential damages of any kind including loss of revenue, loss of profit or cost of capital.