

BRITISH COLUMBIA CONTROL AREA TRANSMISSION LINE FORCED OUTAGES

(Last Updated: 2003-Nov-27)

A. DISCLAIMER

This document was prepared solely for general guidance. Neither B.C. Transmission Corporation, the British Columbia Control Area Operator, the Transmission Facility Owner nor any of their employees or agents make any representations, express or implied, to any third parties as to:

1. the merchantability or fitness for any particular purpose of,
2. the accuracy, completeness or usefulness of, or
3. property rights of any person in,

any information, product or process disclosed in this report. B.C. Transmission Corporation does not accept any liability of any kind arising in any way out of the use of, or reliance by any third party on any information, product or process described in this document. This document may be reproduced in whole or in part by any means whatsoever without the express written permission of B.C. Transmission Corporation, the BCCAO or the TFO.

B. CONTACT INFORMATION

For further information, contact:

Manager, System Performance Assessment
B.C. Transmission Corporation
Suite 1100, IV Bentall Centre
1055 Dunsmuir Street
PO Box 49260
Vancouver, BC
V7X 1V5
Phone: (604) 699-7339
Email: gerry.garnett@bctc.com

C. TRANSMISSION LINE FORCED OUTAGES

The following is a listing of forced outages on circuit 3L2, the 360 kV transmission line connecting B.C. Hydro's Bridge River Terminal station with the Rosedale station. Single Pole Reclosing was installed on this circuit during 2003. It is expected that the forced outage rate of this line will decrease as a result.

Event Start/ Estimated Completion	Outage Duration
1991/10/02 06:41:00	<1 minute
1993/06/30 13:04:00	3 hours 47 minutes
1993/07/13 16:18:00	3 minutes
1993/08/03 22:59:00	7 minutes
1993/08/24 01:22:00	10 minutes
1993/09/11 13:08:00	<1 minute
1993/12/13 16:06:00	1 hour 8 minutes
1993/12/17 08:46:00	12 minutes
1994/08/03 16:24:00	12 minutes
1995/08/30 05:04:00	3 minutes
1996/05/29 16:49:00	4 hours 0 minutes
1997/01/01 09:06:00	12 minutes
1997/06/25 20:17:21	19 minutes
1997/09/01 18:14:00	4 minutes
1997/11/23 18:04:00	38 minutes
1998/06/04 15:06:00	5 minutes
1998/08/04 15:11:00	1 hour 40 minutes
1998/09/25 07:26:00	4 hours 43 minutes

Event Start/ Estimated Completion	Outage Duration
1999/08/18 00:21:00	3 minutes
2000/06/28 13:53:00	8 minutes
2000/08/02 03:04:00	2 minutes
2000/08/02 13:47:00	27 hours 30 minutes
2000/08/09 15:00:00	9 days 1 hour
2001/02/15 01:36:00	14 hours 8 minutes
2001/05/08 05:04:00	2 minutes
2001/09/05 08:16:00	25 minutes
2001/10/15 07:01:00	16 minutes
2002/01/26 07:11:25	<1 minute
2002/01/26 07:15:15	5 hours 13 minutes
2002/09/03 10:52:00	10 minutes
2003/04/11 07:41:54	14 minutes
2003/08/20 12:54:00	2 hours 2 minutes
2003/08/30 04:17:00	<1 minute
2003/09/16 14:49:44	1 hour 47 minutes