

Planned Outages

A. DISCLAIMER			
This document was prepared solely for general guidance. Neither B.C. Transmission Corporation, the British Columbia Control Area Operator, the Transmission Facility Owner nor any of their employees or agents make any representations, express or implied, to any third parties as to:			
1. the merchantability or fitness for any particular purpose of,			
2. the accuracy, completeness or usefulness of, or			
3. property rights of any person in, any information, product or process disclosed in this report.			
B.C. Transmission Corporation does not accept any liability of any kind arising in any way out of the use of, or reliance by any third party on any information, product or process described in this document. This document may be reproduced in whole or in part by any means whatsoever without the express written permission of B.C. Transmission Corporation, the BCCAO or the TFO.			
Created: 10/28/2004 8:18:03 AM			
		Planned Switching	
Outage Number	Equipment Requested	Start	Actual Duration
1-010029	5L61, WSN 5RX1 OOS, FLS G1 RMR Max gen, G2 RMR max gen, RPG G1 RMR Max Generate, G2 RMR Max Generate	2004-06-16 00:00	00 05:27:55
3-000115	5L61 Clearance, WSN 5D1CB11, 5RX1 Clearance OOS BRL RMR 6-8 MW, FLS RMR 5-6 MW, RPG RMR 45 MW	2003-08-28 18:00	00 07:40:00
1-000611	5L61 Transfer Trip channels OOS while 5L61 OOS OOS	2003-06-13 21:00	00 07:00:00
1-013245	5L62, GLN 5B3 OOS FLS RMR min of 6 MW, RPG RMR min of 45 MW	2004-08-30 07:00	00 09:04:02
3-000067	GLN 5RX5 OOS 5L62 Operating Restriction: switching for isolation of 5RX5, RPG RMR 1 unit - MUO O.A.T	2003-06-09 21:00	00 00:58:25 (total outage estimation during the 3 days maintenance)
	5L63		None
1-014422	2L99, MIN 2CVT2 OOS	2004-09-15 13:00	00 14:12:07
1-008181	2L103 OOS	2004-03-03 10:00	00 14:06:28
1-014138	2L101 OOS, FLS RMR 6 MW, RPG RMR Maximum 35 MW	2004-09-09 07:30	00 07:14:35
1-005114	2L101 OOS, SKA 2CC5 OOS	2003-11-15 07:00	00 14:07:56
1-001339	1L387 OOS	2003-07-13 03:30	00 08:38:32
	1L381		None

Note: CROW outage scheduler started 2003. Planned outages before 2003 not captured in CROW.