

**Forced Outage Statistics (1990-01-01 to 2004-12-31):-**

STW 1CB1 (Stewart 138 kV circuit breaker):

Forced Outage: Occurrence rate = 0.2 outage/ year, average duration = 0.09 hour/ outage.

**DISCLAIMER**

This document was prepared solely for general guidance. Neither B.C. Transmission Corporation, the British Columbia Control Area Operator, the Transmission Facility Owner nor any of their employees or agents make any representations, express or implied, to any third parties as to:

1. the merchantability or fitness for any particular purpose of,
2. the accuracy, completeness or usefulness of, or
3. property rights of any person in, any information, product or process disclosed in this report.

B.C. Transmission Corporation does not accept any liability of any kind arising in any way out of the use of, or reliance by any third party on any information, product or process described in this document. This document may be reproduced in whole or in part by any means whatsoever without the express written permission of B.C. Transmission Corporation, the BCCAO or the TFO.